

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9010040251 DOC. DATE: 90/09/28 NOTARIZED: NO DOCKET #
 FACIL: 50-387 Susquehanna Steam Electric Station, Unit 1, Pennsylv 05000387
 50-388 Susquehanna Steam Electric Station, Unit 2, Pennsylv 05000388
 AUTH. NAME AUTHOR AFFILIATION
 KEISER, H.W. Pennsylvania Power & Light Co.
 RECIPIENT NAME RECIPIENT AFFILIATION
 MARTIN, T.T. Region 1 (Post 820201)

SUBJECT: Extends appreciation for Region I waiver of compliance on diesel limiting condition of operation.

DISTRIBUTION CODE: IE01D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 1
 TITLE: General (50 Dkt)-Insp Rept/Notice of Violation Response

NOTES: LPDR 1 cy Transcripts. 05000387
 LPDR 1 cy Transcripts. 05000388

	RECIPIENT ID CODE/NAME	COPIES		RECIPIENT ID CODE/NAME	COPIES	
		LTR	ENCL		LTR	ENCL
	PD1-2 PD	1	1	THADANI, M	1	1
INTERNAL:	ACRS	2	2	AEOD	1	1
	AEOD/DEIIB	1	1	AEOD/TPAD	1	1
	DEDRO	1	1	NRR MORISSEAU, D	1	1
	NRR SHANKMAN, S	1	1	NRR/DLPQ/LPEB10	1	1
	NRR/DOEA DIR 11	1	1	NRR/DREP/PEPB9D	1	1
	NRR/DRIS/DIR	1	1	NRR/DST/DIR 8E2	1	1
	NRR/PMAS/ILRB12	1	1	NUDOCS-ABSTRACT	1	1
	OE DIR	1	1	OGC/HDS2	1	1
	<u>REG FTLE</u> 02	1	1	RGN1 FILE 01	1	1
EXTERNAL:	NRC PDR	1	1	NSIC	1	1
NOTES:		2	2			

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR 25 ENCL ~~25~~ 0

R
I
D
S
/
A
D
D
S

R
I
D
S
/
A
D
D
S



Pennsylvania Power & Light Company

Two North Ninth Street • Allentown, PA 18101-1179 • 215/770-5151

Harold W. Keiser
Senior Vice President-Nuclear
215/770-4194

SEP 28 1990

Mr. Thomas T. Martin
Regional Administrator
U.S. Nuclear Regulatory Commission
Region I
475 Allendale Road
King of Prussia, PA 19406

SUSQUEHANNA STEAM ELECTRIC STATION
REGION I EFFORT ON DIESEL LCO EXTENSION
PLA-3451 FILES A17-2/R41-2

Dear Mr. Martin:

As you are well aware, PP&L recently undertook an intensive effort to repair diesel generator intercoolers that were inadvertently damaged during maintenance. In order to avoid a dual unit shutdown, we requested that your staff perform an expedited review of our request for a waiver of compliance that would temporarily extend the LCO for the diesel generators. Upon determining that our request was reasonable, your review was completed in a fast, quality manner that supported our needs.

PP&L wishes to extend our gratitude for the efforts of the Region I staff, which were of particular note in that they had to occur over the Labor Day weekend.

Very truly yours,

H. W. Keiser

cc: ~~Dr. W. R. Butler~~, NRC Project Director - NRR (OWFN)
Mr. C. W. Hehl, Director, Div. of Reactor Projects - Region I
Mr. A. R. Blough, Branch Chief - Region I
Mr. P. Swetland, Section Chief - Region I
Mr. G. S. Barber, NRC Resident Inspector - SSES

00100
9010040251 900928
PDR ADOCK 05000387
P PDC

mla-4
cur

IE01
1/0