

TABLE 3.6.3-1 (Continued)  
PRIMARY CONTAINMENT ISOLATION VALVES

<u>VALVE FUNCTION AND NUMBER</u>	<u>MAXIMUM ISOLATION TIME (Seconds)</u>	<u>ISOLATION SIGNALS(S) (a)</u>
<u>Automatic Isolation Valves (Continued)</u>		
<u>Suppression Pool Cleanup (b)</u>		
HV-25766	35	A, Z
HV-25768	30	A, Z
<u>MPCI Vacuum Breaker</u>		
HV-255F075	15	LB, Z
HV-255F079	15	LB, Z
<u>RCIC Vacuum Breaker</u>		
HV-249F062	10	KB, Z
HV-249F084	10	KB, Z
<u>TIP Ball Valves (d)</u>		
CS1-J004 A, B, C, D, E	5	A, Z
b. <u>Manual Isolation Valves</u>		
<u>MSIV-LCS Bleed Valve</u>		
HV-239F001 B, F, K, P		
<u>Feedwater (e)</u>		
HV-241F032 A, B		
<u>RWCU Return</u>		
HV-24182 A, B		
<u>RCIC Injection</u>		
HV-249F013		
2-49-020		

Insert  
Ⓐ →

9010150231 901002  
PDR ADOCK 05000388  
P PDC

INSERT A

TABLE 3.6.3-1 (continued)  
PRIMARY CONTAINMENT ISOLATION VALVES

<u>VALVE FUNCTION AND NUMBER</u>	<u>MAXIMUM ISOLATION TIME (Seconds)</u>	<u>ISOLATION SIGNAL(s)</u>
----------------------------------	---	----------------------------

a. Automatic Isolation Valves (Continued)

Containment Radiation  
Detection System

SV-257100 A,B	N/A	(f)
SV-257101 A,B	N/A	(f)
SV-257102 A,B	N/A	(f)
SV-257103 A,B	N/A	(f)
SV-257104	N/A	(f)
SV-257105	N/A	(f)
SV-257106	N/A	(f)
SV-257107	N/A	(f)

↑  
ADD TO PAGE 3/4.6-22

TABLE 3.6.3-1 (Continued)

PRIMARY CONTAINMENT ISOLATION VALVES  
NOTATION

- (a) See Specification 3.3.2, Table 3.3.2-1, for isolation signal(s) that operates each automatic isolation valve. All power-operated isolation valves may be opened or closed remote-manually.
- (b) Isolation barrier remains water filled or a water seal remains in the line post-LOCA. Isolation valve is tested with water. Isolation valve leakage is not included in 0.60 L<sub>a</sub> total Type B and C tests.
- (c) Redundant isolation boundary for this valve is provided by the closed system whose integrity is verified by Type A test.
- (d) Automatic isolation signal causes TIP to retract; ball valve closes when probe is fully retracted.
- (e) Power assisted check valve.

(f) Solenoid valves not capable of being opened due to the absence of permanently installed electrical power.

