

TAB 3.3.3-1 (Continued)

EMERGENCY CORE COOLING SYSTEM ACTUATION INSTRUMENTATION

SUSQUEHANNA - UNIT 1

3/4 3-29

Amendment No. 44

<u>TRIP FUNCTION</u>	<u>MINIMUM OPERABLE CHANNELS PER TRIP SYSTEM</u>	<u>APPLICABLE OPERATIONAL CONDITIONS</u>	<u>ACTION</u>
4. AUTOMATIC DEPRESSURIZATION SYSTEM^{##}			
a. Reactor Vessel Water Level - Low Low Low, Level 1	2(f)	1, 2, 3	30
b. Drywell Pressure - High	2(f)	1, 2, 3	30
c. ADS Timer	1(f)	1, 2, 3	31
d. Core Spray Pump Discharge Pressure - High (Permissive)	2(d)(f)	1, 2, 3	31
e. 50% LPCI Mode Pump Discharge Pressure - High (Permissive)	2(d)(e)(f)	1, 2, 3	31
f. Reactor Vessel Water Level - Low, Level 3 (Permissive)	1(f)	1, 2, 3	31
g. ADS Drywell Pressure Bypass Timer	2(f)	1, 2, 3	31
h. Manual Inhibit	1	1, 2, 3	33
i. Manual Initiation	1/valve	1, 2, 3	33

	<u>TOTAL NO. OF CHANNELS</u>	<u>CHANNELS TO TRIP</u>	<u>MINIMUM CHANNELS OPERABLE</u>	<u>APPLICABLE OPERATIONAL CONDITIONS</u>	<u>ACTION</u>
5. LOSS OF POWER					
a. 4.16 kv ESS Bus Under-voltage (Loss of Voltage, <20%)	1/bus	1/bus	1/bus	1, 2, 3, 4**, 5**	35
b. 4.16 kv ESS Bus Under-voltage (Degraded Voltage, <65%)	2/bus	2/bus	2/bus	1, 2, 3, 4**, 5**	36
c. 4.16 kv ESS Bus Under-voltage (Degraded Voltage <93% <94%)	2/bus	2/bus	2/bus	1, 2, 3, 4**, 5**	36

See footnotes on next page.

9010290048 901019
PDR ADOCK 05000387
P PNU



11
12
13
14
15

TABLE 3.3.3-2 (Continued)

EMERGENCY CORE COOLING SYSTEM ACTUATION INSTRUMENTATION SETPOINTS

<u>TRIP FUNCTION</u>	<u>TRIP SETPOINT</u>	<u>ALLOWABLE VALUE</u>
4. <u>AUTOMATIC DEPRESSURIZATION SYSTEM</u>		
a. Reactor Water Level - Low Low Low, Level 1	≥ -129 inches*	≥ -136 inches
b. Drywell Pressure - High	≤ 1.72 psig	≤ 1.88 psig
c. ADS Timer	≤ 102 seconds	≤ 114 seconds
d. Core Spray Pump Discharge Pressure - High	145 ± 10 psig	145 ± 20 psig
e. RHR LPCI Mode Pump Discharge Pressure - High	125 ± 4 psig	125 ± 10 psig
f. Reactor Vessel Water Level-Low, Level 3	≥ 13 inches	≥ 11.5 inches
g. ADS Drywell Pressure Bypass Timer	≤ 420 seconds	≤ 450 seconds
h. Manual Inhibit	NA	NA
i. Manual Initiation	NA	NA
5. <u>LOSS OF POWER</u>		
a. 4.16 kv ESS Bus Undervoltage (Loss of Voltage, <20%)	a. 4.16 kv Basis - 840 ± 16.8 volts b. 120 v Basis - 24 ± 0.48 volts c. 0.5 ± 0.1 second time delay	840 ± 59.6 volts 24 ± 1.7 volts 0.5 ± 0.1 second time delay
b. 4.16 kv ESS Bus Undervoltage (Degraded Voltage, <65%)	a. 4.16 kv Basis - 2695 ± 53.9 volts b. 120 v Basis - 77 ± 1.54 volts c. 3.0 ± 0.3 second time delay	2695 ± 191.3 volts 77 ± 5.5 volts 3 ± 0.3 second time delay
c. 4.16 kv ESS Bus Undervoltage (Degraded Voltage, <84%) <i><93%</i>	a. 4.16 kv Basis - 3403 ± 69.7 volts b. 120 v Basis - 99.5 ± 1.99 volts c. 5 minute \pm 30 second time delay without LOCA 10 ± 1.0 second time delay with LOCA 110.5 ± 1.10	3403 ± 69.7 volts 99.5 ± 1.99 volts 5 minutes \pm 30 second time delay without LOCA 10 ± 1.0 second time delay with LOCA $110.5 \pm 1.91, -1.91$

*See Bases Figure B 3/4 3-1.

SUSQUEHANNA - UNIT 1

3/4 3-32

Amendment No. 44



11
12
13

TABLE 3.3.3-3

EMERGENCY CORE COOLING SYSTEM RESPONSE TIMES

<u>TRIP FUNCTION</u>	<u>RESPONSE TIME (Seconds)</u>
<u>1. CORE SPRAY SYSTEM</u>	
a. Reactor Vessel Water Level-Low Low Low, Level 1	<27
b. Drywell Pressure-High	<27
c. Reactor Vessel Steam Dome Pressure-Low	<27
d. Manual Initiation	NA
<u>2. LOW PRESSURE COOLANT INJECTION MODE OF RHR SYSTEM</u>	
a. Reactor Vessel Water Level-Low Low Low, Level 1	<40
b. Drywell Pressure-High	<40
c. Reactor Vessel Steam Dome Pressure-Low	
1) System Initiation	<40
2) Recirculation Discharge Valve Closure	<40
d. Manual Initiation	NA
<u>3. HIGH PRESSURE COOLANT INJECTION SYSTEM</u>	
a. Reactor Vessel Water Level - Low Low, Level 2	<30
b. Drywell Pressure - High	<30
c. Condensate Storage Tank Level-Low	NA
d. Reactor Vessel Water Level-High, Level 8	NA
e. Suppression Pool Water Level-High	NA
f. Manual Initiation	NA
<u>4. AUTOMATIC DEPRESSURIZATION SYSTEM</u>	
a. Reactor Vessel Water Level-Low Low Low, Level 1	NA
b. Drywell Pressure-High	NA
c. ADS Timer	NA
d. Core Spray Pump Discharge Pressure-High	NA
e. RHR LPCI Mode Pump Discharge Pressure-High	NA
f. Reactor Vessel Water Level-Low, Level 3	NA
g. ADS Drywell Pressure Bypass Timer	NA
h. Manual Inhibit	NA
i. Manual Initiation	NA
<u>5. LOSS OF POWER</u>	
a. 4.16 kV ESS Bus Undervoltage (Loss of Voltage <20%)	NA
b. 4.16 kV ESS Bus Undervoltage (Degraded Voltage <65%)	NA
c. 4.16 kV ESS Bus Undervoltage (Degraded Voltage <84%)	NA
<93%	

1 2 3
4 5 6
7 8 9

TABLE 3.3.3-1 (Continued)

EMERGENCY CORE COOLING SYSTEM ACTUATION INSTRUMENTATION

<u>TRIP FUNCTION</u>	<u>MINIMUM OPERABLE CHANNELS PER TRIP SYSTEM</u>	<u>APPLICABLE OPERATIONAL CONDITIONS</u>	<u>ACTION</u>
4. AUTOMATIC DEPRESSURIZATION SYSTEM^{##}			
a. Reactor Vessel Water Level - Low Low Low, Level 1	2(f)	1, 2, 3	30
b. Drywell Pressure - High	2(f)	1, 2, 3	30
c. ADS Timer	1(f)	1, 2, 3	31
d. Core Spray Pump Discharge Pressure - High (Permissive).	2(d)(f)	1, 2, 3	31
e. RHR LPCI Mode Pump Discharge Pressure - High (Permissive)	2(d)(e)(f)	1, 2, 3	31
f. Reactor Vessel Water Level - Low, Level 3 (Permissive)	1(f)	1, 2, 3	31
g. ADS Drywell Pressure Bypass Timer	2(f)	1, 2, 3	31
h. Manual Inhibit	1	1, 2, 3	33
i. Manual Initiation	1/valve	1, 2, 3	31

	<u>TOTAL NO. OF CHANNELS</u>	<u>CHANNELS TO TRIP</u>	<u>MINIMUM CHANNELS OPERABLE</u>	<u>APPLICABLE OPERATIONAL CONDITIONS</u>	<u>ACTION</u>
5. LOSS OF POWER					
a. 4.16 kv ESS Bus Under-voltage (Loss of Voltage, <20%)	1/bus	1/bus	1/bus	1, 2, 3, 4**, 5**	35
b. 4.16 kv ESS Bus Under-voltage (Degraded Voltage, <65%)	2/bus	2/bus	2/bus	1, 2, 3, 4**, 5**	36
c. 4.16 kv ESS Bus Under-voltage (Degraded Voltage <84%)	2/bus	2/bus	2/bus	1, 2, 3, 4**, 5**	36

See footnotes on next page.

SUSQUEHANNA - UNIT 2

3/4 3-29

Amendment No. 11

TABLE 3.3.3-2 (Continued)

EMERGENCY CORE COOLING SYSTEM ACTUATION INSTRUMENTATION SETPOINTS

<u>TRIP FUNCTION</u>	<u>TRIP SETPOINT</u>	<u>ALLOWABLE VALUE</u>
4. AUTOMATIC DEPRESSURIZATION SYSTEM		
a. Reactor Water Level - Low Low Low, Level 1	≥ -129 inches*	≥ -136 inches
b. Drywell Pressure - High	≤ 1.72 psig	≤ 1.08 psig
c. ADS Timer	≤ 102 seconds	≤ 114 seconds
d. Core Spray Pump Discharge Pressure - High	145 ± 10 psig	145 ± 20 psig
e. RHR LPCI Mode Pump Discharge Pressure - High	125 ± 4 psig	125 ± 10 psig
f. Reactor Vessel Water Level-Low, Level 3	$\geq .13$ inches	≥ 11.5 inches
g. ADS Drywell Pressure Bypass Timer	≤ 420 seconds	≤ 450 seconds
h. Manual Inhibit	NA	NA
i. Manual Initiation	NA	NA
5. LOSS OF POWER		
a. 4.16 kv ESS Bus Undervoltage (Loss of Voltage, <20%)	a. 4.16 kv Basis - 840 ± 16.8 volts b. 120 v Basis - 24 ± 0.48 volts c. 0.5 ± 0.1 second time delay	840 ± 59.6 volts 24 ± 1.7 volts 0.5 ± 0.1 second time delay
b. 4.16 kv ESS Bus Undervoltage (Degraded Voltage, <65%)	a. 4.16 kv Basis - 2695 ± 53.9 volts b. 120 v Basis - 77 ± 1.54 volts c. 3.0 ± 0.3 second time delay	2695 ± 191.3 volts 77 ± 5.5 volts 3 ± 0.3 second time delay
c. 4.16 kv ESS Bus Undervoltage (Degraded Voltage, <84%) <i><93%</i>	a. 4.16 kv Basis - 3403 ± 69.7 volts b. 120 v Basis - 99.5 ± 1.99 volts c. 5 minute \pm 30 second time delay without LOCA 10 \pm 1.0 second time delay with LOCA	3868 ± 78.7 $3868 + 67, - 67$ $3401 \pm 247.3, - 69.7$ volts 99.5 ± 1.99 volts $\rightarrow 90.5 \pm 1.1$ volts, ± 1.99 volts 5 minutes \pm 30 second time delay without LOCA 10 \pm 1.0 second time delay with LOCA 110.5 ± 1.10

*See Bases Figure B 3/4 3-1.

SUSQUEHANNA - UNIT 2

3/4 3-32

Amendment No. 11



100
100
100

TABLE 3.3.3-3

EMERGENCY CORE COOLING SYSTEM RESPONSE TIMES

<u>TRIP FUNCTION</u>	<u>RESPONSE TIME (Seconds)</u>
<u>1. CORE SPRAY SYSTEM</u>	
a. Reactor Vessel Water Level-Low Low Low, Level 1	<27
b. Drywell Pressure-High	≤27
c. Reactor Vessel Steam Dome Pressure-Low	≤27
d. Manual Initiation	NA
<u>2. LOW PRESSURE COOLANT INJECTION MODE OF RHR SYSTEM</u>	
a. Reactor Vessel Water Level-Low Low Low, Level 1	<40
b. Drywell Pressure-High	≤40
c. Reactor Vessel Steam Dome Pressure-Low	
1) System Initiation	<40
2) Recirculation Discharge Valve Closure	≤40
d. Manual Initiation	NA
<u>3. HIGH PRESSURE COOLANT INJECTION SYSTEM</u>	
a. Reactor Vessel Water Level - Low Low, Level 2	<30
b. Drywell Pressure - High	≤30
c. Condensate Storage Tank Level-Low	NA
d. Reactor Vessel Water Level-High, Level 8	NA
e. Suppression Pool Water Level-High	NA
f. Manual Initiation	NA
<u>4. AUTOMATIC DEPRESSURIZATION SYSTEM</u>	
a. Reactor Vessel Water Level-Low Low Low, Level 1	NA
b. Drywell Pressure-High	NA
c. ADS Timer	NA
d. Core Spray Pump Discharge Pressure-High	NA
e. RHR LPCI Mode Pump Discharge Pressure-High	NA
f. Reactor Vessel Water Level-Low, Level 3	NA
g. ADS Drywell Pressure Bypass Timer	NA
h. Manual Inhibit	NA
i. Manual Initiation	NA
<u>5. LOSS OF POWER</u>	
a. 4.16 kV ESS Bus Undervoltage (Loss of Voltage <20%)	NA
b. 4.16 kV ESS Bus Undervoltage (Degraded Voltage <65%)	NA
c. 4.16 kV ESS Bus Undervoltage (Degraded Voltage <40%)	NA

<93%

