

TABLE 3.6.3-1

PRIMARY CONTAINMENT ISOLATION VALVES

<u>VALVE FUNCTION AND NUMBER</u>	<u>MAXIMUM ISOLATION TIME (Seconds)</u>	<u>ISOLATION SIGNAL(S)^(a)</u>
a. <u>Automatic Isolation Valves</u>		
<u>MSIV</u>		
HV-241F022 A,B,C,D	5	X,C,D,E,P,UA
HV-241F028 A,B,C,D	5	X,C,D,E,P,UA
<u>MSL Drain</u>		
HV-241F016	10	X,C,D,E,P,UA
HV-241F019	10	X,C,D,E,P,UA
<u>RCIC Steam Supply</u>		
HV-249F007	20	K,KB
HV-249F008	20	K,KB
HV-249F088	3	K,KB
<u>HPCI Steam Supply</u>		
HV-255F002	50	L,LB
HV-255F003	50	L,LB
HV-255F100	3	L,LB
<u>RHR - Shutdown Cooling Suction</u>		
HV-251F008	52	A,M,UB
HV-251F009	52	A,M,UB
<u>RWCU Suction^(b)</u>		
HV-244F001*	30	B,J,W
HV-244F004	30	I,B,J,W
<u>RHR - Reactor Vessel Head Spray</u>		
HV-251F022	30	A,M,UB,Z
HV-251F023	20	A,M,UB,Z

* The RWCU HV-244F001 valve may be considered OPERABLE with its current minimum torque switch setting for the period beginning October 30, 1990 until an outage of sufficient duration to revise the setting occurs.

