

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9101180171 DOC. DATE: 91/01/14 NOTARIZED: NO DOCKET #
 FACIL: 50-387 Susquehanna Steam Electric Station, Unit 1, Pennsylv 05000387
 AUTH. NAME AUTHOR AFFILIATION
 KEISER, H.W. Pennsylvania Power & Light Co.
 RECIP. NAME RECIPIENT AFFILIATION
 MARTIN, T.T. Region 1 (Post 820201)

SUBJECT: Lists snubber sample plan for fourth refueling & insp outage. Util will test Pacific Scientific Size 1,3,10 & 35 snubbers per Spec 4.7.4e.3 instead of Spec 4.7.4e.2.

DISTRIBUTION CODE: IE01D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 2
 TITLE: General (50 Dkt)-Insp Post/Notice of Violation Response

NOTES: LPDR 1 cy Transcripts. 05000387

| | RECIPIENT ID CODE/NAME | COPIES LTR ENCL | RECIPIENT ID CODE/NAME | COPIES LTR ENCL |
|-----------|------------------------|-----------------|------------------------|-----------------|
| | PD1-2 PD | 1 1 | THADANI, M | 1 1 |
| INTERNAL: | ACRS | 2 2 | AEOD | 1 1 |
| | AEOD/DEIIB | 1 1 | AEOD/TPAB | 1 1 |
| | DEDRO | 1 1 | NRR MORISSEAU, D | 1 1 |
| | NRR SHANKMAN, S | 1 1 | NRR/DLPQ/LPEB10 | 1 1 |
| | NRR/DOEA/OEAB | 1 1 | NRR/DREP/PEPB9D | 1 1 |
| | NRR/DRIS/DIR | 1 1 | NRR/DST/DIR 8E2 | 1 1 |
| | NRR/PMAS/ILRB12 | 1 1 | NUDOCS-ABSTRACT | 1 1 |
| | OE DIR | 1 1 | OGC/HDS2 | 1 1 |
| | <u>REG FILE</u> 02 | 1 1 | RGN1 FILE 01 | 1 1 |
| EXTERNAL: | EG&G/BRYCE, J.H. | 1 1 | NRC PDR | 1 1 |
| | NSIC | 1 1 | | |
| NOTES: | | 2 2 | | |

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK, ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR 26 ENCL ~~26~~ 0

M/H-4
ee

R
I
D
S
/
A
D
D
S
/
A
D
D
S



Pennsylvania Power & Light Company

Two North Ninth Street • Allentown, PA 18101-1179 • 215/774-5151

Harold W. Keiser
Senior Vice President-Nuclear
215/774-4194

JAN 14 1991

Mr. T. T. Martin
Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

SUSQUEHANNA STEAM ELECTRIC STATION
SNUBBER SAMPLE PLAN - UNIT 2 FOURTH
REFUELING AND INSPECTION OUTAGE
PLA-3481 FILES A17-2/R41-2

Docket No. 50-387

Reference: PLA-3224, H.W. Keiser to W.T. Russell, dated July 27, 1989

Dear Mr. Martin:

Via the referenced letter, PP&L notified the NRC of the snubber sample plan for the Susquehanna SES Unit 2 third refueling and inspection outage, as required by Technical Specification 4.7.4e. This specification also requires us to notify you prior to the beginning of any subsequent outage if the sample plan has changed since the last test period. This transmittal fulfills that requirement.

The sample plan for the SSES Unit 2 fourth refueling and inspection outage is identical to that of the third refueling and inspection outage with two exceptions. PP&L has chosen to test the Pacific Scientific (PSA) size 1, 3 and 10 snubbers and the PSA size 35 snubbers in accordance with Specification 4.7.4e.3 rather than Specification 4.7.4e.2.

Therefore, the sample plan for the SSES Unit 2 fourth refueling and inspection outage will be as follows:

| <u>Type</u> | <u>Sample Plan</u> |
|-----------------------------------|------------------------|
| 1. PSA - 1/4 and 1/2 | Specification 4.7.4e.1 |
| 2. PSA - 1, 3, and 10 | Specification 4.7.4e.3 |
| 3. PSA - 35 | Specification 4.7.4e.3 |
| 4. PSA - 100 | Specification 4.7.4e.1 |
| 5. Main Steam Outside Containment | Specification 4.7.4e.1 |

9101180171 910114
FLK ADOCK 05000387
Q PDR

TEO
1/10

Any questions on this transmittal should be directed to Mr. R.R. Sgarro at (215) 774-7916.

Very truly yours,



H. W. Keiser

cc: ENRC Document Control Desk (original)
Mr. M.C. Thadani, NRC Project Manager (OWFN)
Mr. G.S. Barber, NRC Sr. Resident Inspector (SSES)