

TABLE 3.6.3-1 (Continued)

PRIMARY CONTAINMENT ISOLATION VALVES

<u>VALVE FUNCTION AND NUMBER</u>	<u>MAXIMUM ISOLATION TIME (Seconds)</u>	<u>ISOLATION SIGNAL(s)^(a)</u>
<u>Automatic Isolation Valves (Continued)</u>		
<u>Suppression Pool Cleanup^(b)</u>		
HV-15766	30	A,Z
HV-15768	30	A,Z
<u>HPCI Vacuum Breaker</u>		
HV-155F075	15	LB,Z
HV-155F079	15	LB,Z
<u>RCIC Vacuum Breaker</u>		
HV-149F062	10	KB,Z
HV-149F084	10	KB,Z
<u>TIP Ball Valves^(d)</u>		
C51-J004 A,B,C,D,E	5	A,Z
<u>Containment Radiation Detection System</u>		
SV-157100 A,B	N/A	B,Y (F)
SV-157101 A,B	N/A	B,Y (F)
SV-157102 A,B	N/A	B,Y (F)
SV-157103 A,B	N/A	B,Y (F)
SV-157104	N/A	B,Y (F)
SV-157105	N/A	B,Y (F)
SV-157106	N/A	B,Y (F)
SV-157107	N/A	B,Y (F)
b. <u>Manual Isolation Valves</u>		
<u>MSIV-LCS Bleed Valve</u>		
HV-139F001 B,F,K,P		
<u>Feedwater^(e)</u>		
HV-141F032 A,B		
<u>RWCU Return</u>		
HV-14182 A,B		
<u>RCIC Injection</u>		
HV-149F013		
1-49-020		

9101240260 910114
PDR ADOCK 05000387
P PDR

TABLE 3.6.3-1 (Continued)

PRIMARY CONTAINMENT ISOLATION VALVES
NOTATION

- (a) See Specification 3.3.2, Table 3.3.2-1, for isolation signal(s) that operates each automatic isolation valve. All power operated isolation valves may be opened or closed remote-manually.
- (b) Isolation barrier remains water filled or a water seal remains in the line post-LOCA. Isolation valve is tested with water. Isolation valve leakage is not included in 0.60 La total Type B and C tests.
- (c) Redundant isolation boundary for this valve is provided by the closed system whose integrity is verified by Type A test.
- (d) Automatic isolation signal causes TIP to retract; ball valve closes when probe is fully retracted.
- (e) Power assisted check valve.
- ~~(f) Solenoid valves not capable of being opened due to the absence of permanently installed electrical power.~~

INSERT A

TABLE 3.6.3-1 (continued)
PRIMARY CONTAINMENT ISOLATION VALVES

<u>VALVE FUNCTION AND NUMBER</u>	<u>MAXIMUM ISOLATION TIME (Seconds)</u>	<u>ISOLATION SIGNAL(s)</u>
----------------------------------	---	----------------------------

a. Automatic Isolation Valves (Continued)

Added per this TS change

<u>Containment Radiation Detection System</u>		
SV-257100 A,B	N/A	B,B
SV-257101 A,B	N/A	B,B
SV-257102 A,B	N/A	B,B
SV-257103 A,B	N/A	B,B
SV-257104	N/A	B,B
SV-257105	N/A	B,B
SV-257106	N/A	B,B
SV-257107	N/A	B,B

ADD TO PAGE 3/4.6-22

Added per TS-214

Deleted per this TS change

ADD TO PAGE 3/4.6-28

Added per TS-214
~~(f) Solenoid valves not capable of being opened due to the absence of permanently installed electrical power.~~

