

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9106260066 DOC. DATE: 91/06/21 NOTARIZED: NO DOCKET #
 FACIL: 50-387 Susquehanna Steam Electric Station, Unit 1, Pennsylva 05000387
 50-388 Susquehanna Steam Electric Station, Unit 2, Pennsylva 05000388
 AUTH. NAME AUTHOR AFFILIATION
 KEISER, H.W. Pennsylvania Power & Light Co.
 RECIPIENT NAME RECIPIENT AFFILIATION
 BUTLER, W.R. Project Directorate I-2

SUBJECT: Forwards revised response to Question 4 of 910604 request for addl info re MCPR operating limits.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 4
 TITLE: OR Submittal: General Distribution

NOTES: LPDR 1 cy Transcripts. 05000387 /
 LPDR 1 cy Transcripts. 05000388

	RECIPIENT		COPIES		RECIPIENT		COPIES	
	ID CODE/NAME		LTR	ENCL	ID CODE/NAME		LTR	ENCL
	PD1-2 LA		1	1	PD1-2 PD		1	1
	RALEIGH, J		2	2				
INTERNAL:	ACRS		6	6	NRR/DET/ECMB 7D		1	1
	NRR/DET/ESGB		1	1	NRR/DOEA/OTSB11		1	1
	NRR/DST 8E2		1	1	NRR/DST/SELB 7E		1	1
	NRR/DST/SICB8H7		1	1	NRR/DST/SRXB 8E		1	1
	NUDOCS-ABSTRACT		1	1	OC/LEMB		1	0
	OGC/HDS2		1	0	<u>REG FILE</u> 01		1	1
	RES/DSIR/EIB		1	1				
EXTERNAL:	NRC PDR		1	1	NSIC		1	1
NOTES:			2	2				


NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK, ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR 26 ENCL 24

M/A-T

R
I
D
S
/
A
D
D
S





Pennsylvania Power & Light Company

Two North Ninth Street • Allentown, PA 18101-1179 • 215/774-5151

Harold W. Keiser
Senior Vice President-Nuclear
215/774-4194

JUN 21 1991

Director of Nuclear Reactor Regulation
Attention: Dr. W. R. Butler, Project Director
Project Directorate I-2
Division of Reactor Projects
U.S. Nuclear Regulatory Commission
Washington, DC 20555

**SUSQUEHANNA STEAM ELECTRIC STATION
REVISED RESPONSE TO QUESTION #4
OF RAI ON PL-NF-90-001
PLA-3595 FILES A7-8C/A17-2/R41-2**

**Docket Nos. 50-387
and 50-388**

Reference: PLA-3578, H. W. Keiser to W. R. Butler, "Final Response to RAI on PL-NF-90-001" dated June 4, 1991.

Dear Dr. Butler:

Based on recent discussions with Mr. Larry Phillips and Mr. Larry Kopp of NRR, PP&L is providing the attached revision to our response to Question 4 of the referenced submittal.

Any questions on the attachment should be directed to Mr. R. Sgarro at (215) 774-7916. PP&L appreciates the continuing NRC efforts in support of this review.

Very truly yours,

H. W. Keiser

Attachment

9106260066 910621
PDR ADOCK 05000387
P PDR

ADD 1/1

11

1. The first part of the document is a list of names and addresses.

2. The second part of the document is a list of names and addresses.

3. The third part of the document is a list of names and addresses.

4. The fourth part of the document is a list of names and addresses.

5. The fifth part of the document is a list of names and addresses.

- 2 -

FILES A7-8C/A17-2/ PLA-3595
R41-2
Dr. W. R. Butler

cc: ~~Document Control Desk (original)~~
NRC Region I
Mr. G. S. Barber, NRC Sr. Resident Inspector - SSES
Mr. J. J. Raleigh, NRC Project Manager - OWFN

QUESTION 4

Without the SCU methodology, the safety limit and event-specific RCPR will be calculated separately in determining the operating limit MCPR. Modify the technical specifications to include the safety limit MCPR.

RESPONSE 4

In the PP&L SCU methodology, the operating limit MCPR is determined directly to demonstrate compliance with the applicable SAFDL (see response to Question 3). As demonstrated by the responses to Questions 1 and 2 (Reference 4-1), PP&L believes its SCU methodology is a logical extension of currently used NRC approved SCU methods and that the PP&L method conforms to the applicable regulations. Therefore, use of the SAFDL (i.e., 99.9% of the fuel rods expected to avoid boiling transition) as the "THERMAL POWER, High Pressure and High Flow" safety limit in the technical specifications is appropriate. In addition, the analyses performed to date demonstrate that the application of PP&L's SCU methodology produces more conservative MCPR operating limits than those produced by our current fuel vendor's NRC approved licensing methods. These analyses are a further demonstration of the overall conservatism of the PP&L approach.

However, interactions with the NRC have indicated that the staff would prefer that a MCPR value which assures that 99.9% of the fuel pins are expected to avoid boiling transition be included as the "THERMAL POWER, High Pressure and High Flow" safety limit. Therefore, a MCPR safety limit value, which is calculated using ANF's NRC approved methodology will continue to be included in the Susquehanna Technical Specifications. For Unit 2 Cycle 5, the safety limit MCPR was calculated to be 1.06.

As further confirmation of the adequacy of the MCPR operating limits calculated using PP&L's SCU methodology, additional analyses will be supplied as part of each reload licensing submittal. These analyses determine the Δ CPR for all events which utilize the PP&L SCU methodology (i.e., GLRWOB, FWCF, and RWE events). The analyses will be based on expected plant and system

The following table shows the results of the experiments conducted on the 15th and 16th of the month. The data indicates a significant increase in the rate of reaction when the temperature is raised from 25°C to 35°C. This is consistent with the Arrhenius equation, which predicts that the rate constant increases exponentially with temperature.

performance for the cycle being evaluated and no explicit code uncertainty will be applied. As an example, confirmatory calculations were performed for the GLRWOB and RWE events for Unit 2 Cycle 5, and the results are presented in Table 4-1 along with the MCPR operating limits produced by PP&L's SCU methodology.

TABLE 4-1
RESULTS OF U2C5 CONFIRMATORY CALCULATIONS

<u>EVENT</u>	<u>CONFIRMATORY CALC ΔCPR</u>	<u>CONFIRMATORY CALC ΔCPR + 1.06</u>	<u>SCU METHOD MCPR OL</u>
GLRWOB	0.20	1.26	1.32
RWE	0.16	1.22	1.27

Reference

4-1 "Initial Response to RAI on PL-NF-90-001(SCU Questions)", Susquehanna Letter PLA-3566, April 23, 1991.