

# ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

## REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9107300213      DOC. DATE: 91/07/26      NOTARIZED: NO      DOCKET #  
 FACIL: 50-387 Susquehanna Steam Electric Station, Unit 1, Pennsylv      05000387  
 50-388 Susquehanna Steam Electric Station, Unit 2, Pennsylv      05000388

AUTH. NAME      AUTHOR AFFILIATION  
 KEISER, H.W.      Pennsylvania Power & Light Co.  
 RECIPIENT NAME      RECIPIENT AFFILIATION  
                          Project Directorate I-2

SUBJECT: Submits revised insp requirements for RHR pump motor oil cooler. All RHR coolers will be replaced within 5 yrs & results of destructive testing will be used to calculate required replacement interval for installed coils.

DISTRIBUTION CODE: A001D      COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 2  
 TITLE: OR Submittal: General Distribution

NOTES: LPDR 1 cy Transcripts.      05000387  
 LPDR 1 cy Transcripts.      05000388

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID	CODE/NAME	LTTR	ENCL		ID	CODE/NAME	LTTR	ENCL
	PD1-2	LA	1	1		PD1-2	PD	1	1
		THADANI, M.	2	2					
INTERNAL:	ACRS		6	6		NRR/DET/ECMB	7D	1	1
	NRR/DET/ESGB		1	1		NRR/DOEA/OTSB11		1	1
	NRR/DST	8E2	1	1		NRR/DST/SELB	7E	1	1
	NRR/DST/SICB8H7		1	1		NRR/DST/SRXB	8E	1	1
	NUDOCS-ABSTRACT		1	1		OC/LFMB		1	0
	OGC/HDS2		1	0		<u>REG FILE 01</u>		1	1
	RES/DSIR/EIB		1	1					
EXTERNAL:	NRC	PDR	1	1		NSIC		1	1
NOTES:			2	2					

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK, ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR 26 ENCL 24 <sup>0</sup>

R  
I  
D  
S  
/  
A  
D  
D  
S



**Pennsylvania Power & Light Company**

Two North Ninth Street • Allentown, PA 18101-1179 • 215/774-5151

JUL 26 1991

Harold W. Keiser  
Senior Vice President-Nuclear  
215/774-4194

Director of Nuclear Reactor Regulation  
Attention: Dr. W. R. Butler, Project Director  
Project Directorate I-2  
Division of Reactor Projects  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

**SUSQUEHANNA STEAM ELECTRIC STATION  
RHR PUMP MOTOR OIL COOLER INSPECTION  
PLA-3617 FILES R41-2/A22-7D**

Docket Nos. 50-387  
and 50-388

*Reference: Letter, PLA-3457, H.W. Keiser to W.R. Butler, "Final Report on RHR Motor Oil Cooler Failures", dated November 12, 1990.*

Dear Dr. Butler: -

In the referenced letter, PP&L committed to revise the current inspection requirements for the RHR pump motor oil coolers in order to insure that they are replaced prior to the end of their useful life and to evaluate the need for a replacement material for the copper coils.

The purpose of this letter is to inform you of our plans with respect to resolving these issues. The following describes our approach with respect to each of these issues:

- Ensure Replacement Prior To The End Of Useful Life - The required replacement interval for these coolers has been established at five years, pending receipt of more definitive failure data. Our plan for the replacement is as follows:
  - All RHR motor oil coolers will be replaced within approximately five years (end of U1-8RIO and U2-7RIO).
  - As coils are replaced, they will be destructively examined to determine the extent of corrosion.
  - The results of the destructive testing will be used to calculate the required replacement interval for the installed coils.

9107300213	910726
PDR	ADOCK
05000387	PDR

ADD 1/10



Handwritten scribbles and marks in the top right corner.

Faint, illegible text or markings in the upper right quadrant.

1950

1950

Faint, illegible text or markings in the middle left section.

Faint, illegible text or markings in the lower left section.

Faint, illegible text or markings in the bottom right corner.

In addition, to help preserve the life of the coolers,

- The ESW systems will continue to be run in a manner to minimize stagnation in either loop.
- Procedures are being developed to periodically add biocide to the ESW system.
- Evaluation of Replacement Material
  - We have concluded that a replacement material is not required to ensure the ability of the coolers to perform their safety function. Although we will continue to pursue the merits of a material change, the decision to make such a change will be based on a benefit/cost analysis balancing material costs, expected replacement interval, maintenance costs, and ALARA.

We believe this response completes our commitment to you and closes the issue.

Very truly yours,



H. W. Ketsler

cc: NRC Document Control Desk (original)  
NRC Region I  
Mr. G. S. Barber, NRC Sr. Resident Inspector  
Mr. J. J. Raleigh, NRC Project Manager



Handwritten scribbles and marks in the top right corner.

Faint, illegible handwritten text in the upper middle section.

Faint, illegible handwritten text in the middle section.

Faint, illegible handwritten marks in the lower right section.