



NUCLEAR FUELS & SYSTEMS ENGINEERING
ANALYSIS/CALCULATION COVER SHEET

Calc. No. SE-B-NA-078
Superseded by
SRMS File Code R2-1

TITLE: Conservative Calculation of Offsite and Control Room Doses
for a 25 GPM Reactor Water Leak Taking No Credit for
Secondary Containment (Quality)

SSES UNIT B

SSES CYCLE NA

Rev. No.	Total No. of Pages	Prepared By	Date	Reviewed By	Date	Approved By	Date
0	20	David G. Matchick	4/1/89	J. H. Reilly	11/21/89	Michael B. Detamore	11/21/89
1	30	David A. Matchick	8/15/90	Jack H. Reilly	8/15/90	Michael B. Detamore	8/20/90
2	30	David A. Matchick	1/31/91	Jack H. Reilly	2/1/91	Michael B. Detamore	2/7/91

DC220.0-A1 Rev. 0

9108260206 910819
PDR. ADOCK 05000387
PDR

00
22
1

00

00 00 00



00
00
00

00

00

00

00

00

00

00

00

00

00

00

00

PP&L

REVISION DESCRIPTION INDEX

Rev. No.	Revised Pages	Affected Sections	Description/Purpose of Revision
1	Added pages 19-27	Added Appendix C	Extend calculation to evaluate a 50 GPM Reactor Water Leak for 48 hours.
2	11, 17, 24, 26	Section III, Appendix B, Appendix C	Correct Control Room Whole Body Dose by multiplying by .25, which is missing in the Control Room Whole Body Dose formula on pages 17 and 24 and revise summary table on pages 11 and 26 into correct control room whole body data.

1947

1948

1949

1950

1951

1952

1953

1954

1955

1956

1957



Dept. _____

PENNSYLVANIA POWER & LIGHT COMPANY
CALCULATION SHEET

ER No. _____

Date _____ 19 _____

~~Designed by~~ _____

PROJECT _____


Sht. No. _____ of _____

Approved by JMK

TABLE OF CONTENTS

PAGE NO.


I.	OBJECTIVE	1
II.	METHODOLOGY	3
III.	RESULTS / CONCLUSIONS	10
IV.	REFERENCES	12
APPENDIX A:	Parameter Values.	13
APPENDIX B:	Numerical Calculations	14
APPENDIX C:	Extension of Calculation to a leak of 50GPM for a 48 hr Period.	19



Dept. _____ PENNSYLVANIA POWER & LIGHT COMPANY ER No. _____
Date _____ 19. _____ CALCULATION SHEET
Designed by _____ PROJECT _____ Snt. No. 1
Approved by _____

I. OBJECTIVE

The purpose of this calculation is to perform a conservative, worst case evaluation of the offsite and control room doses resulting from a steam (water) leak of reactor grade water of 25 gpm into secondary containment. No credit for removal, holdup or decay of 4.0 $\mu\text{Ci/gm}$ of Dose-Equivalent Iodine-131 is to be taken. As such, no credit for the secondary containment is taken for iodine removal. The conservative situation modeled in this analysis is shown in Figure 1. The period of the leak is assumed to be 16 hours, after which environmental testing is terminated.





Dept. _____
Date _____ 19 ____
Designed by _____
Approved by _____

PENNSYLVANIA POWER & LIGHT COMPANY
CALCULATION SHEET
PROJECT _____

ER No. _____
Sh. No. 2 of 2

Figure 1:
Evaluation Scenario





Dept. _____ PENNSYLVANIA POWER & LIGHT COMPANY ER No. _____
 Date _____ 19 _____ CALCULATION SHEET
 Designed by _____ PROJECT _____ Sht. No. 3 of _____
 Approved by _____

II. Methodology

Because a worst case scenario is to be employed, a bounding hand calculation employing methodology outlined in SSES-FSAR Chapter 15-Accident Analyses (Ref. 1) is used. A source term concentration of $4.0 \text{ } \mu\text{Ci/gm}$ of Dose Equivalent I-131 (Reference 2) is assumed. At this concentration, reactor operation must enter a LCO and be in hot shutdown in 12 hours as per SSES TS(U1/U2) 3/4.4.5 (Reference 3). A 25 gpm leak of this concentration is assumed to exist for 4 hours prior to entering the 12 hour LCO period. Thus a leak of 25 gpm


1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

101



Dept. _____ PENNSYLVANIA POWER & LIGHT COMPANY
Date _____ 19____ CALCULATION SHEET
Designed by _____ PROJECT _____ ER No. _____
Approved by _____ Sht. No. 4 of _____

of 4.0 MCi/gm of Dose Equivalent Iodine-131
is assumed to exist for a period of 16 hours.
This leak is assumed to pass directly to the
environment with no removal, holdup or
decay. Thyroid, whole body and Control Room skin doses
are determined for this source term. Noble
Gases in coolant are assumed to be processed
by the Offgas System, and do not carry over
with reactor coolant. Additionally, all
particulate activity is assumed to be retained
in secondary containment and does not
volatilize as does the iodine. No dose contribution
from particulates or noble gases is calculated.



Dept. _____ PENNSYLVANIA POWER & LIGHT COMPANY ER No. _____
 Date _____ 19 _____ CALCULATION SHEET
 Designed by _____ PROJECT _____ Sht. No. 5
 Approved by _____

This calculation is calculated offsite dose
 one inch from the SB - FSA. For
 The Thyroid Dose, Equation 15B-2 of Ref 1 is
 used:

$$D_{\text{thyroid}}^{\text{os}} = X/Q_i \times BR_i \times Q_I^c \times TDCF \quad (\text{SSES-FSAR 15B-2})$$

$D_{\text{thyroid}}^{\text{os}}$ = Offsite thyroid dose for time period i

X/Q_i = Dispersion Factor for SB, LPZ for i th time period i

BR_i = Breathing Rate at SB, LPZ for time period i

Q_I^c = Total I-131 emitted in time period i

$TDCF$ = Thyroid Dose Conversion Factor for Iodine 131,

This equation is evaluated for the periods of
 0-8hrs and 8hrs to 16 hrs to account for the
 change in X/Q at 8 hours. Numerical values of
 the parameters shown are found in Appendix A

Whole body doses are calculated using

Dept. _____ PENNSYLVANIA POWER & LIGHT COMPANY ER No. _____
 Date _____ 19 _____ CALCULATION SHEET
 Designed by _____ PROJECT _____ Sht. No. 6 of _____
 Approved by _____

The normal whole-body dose equation (Equation 15B-1) is
 of the form $D_{wb}^{os} = k \left(\frac{X}{Q} \right) Q_I \bar{E}_I$ (Equation developed in reference 5):

$$D_{wb}^{os} = .25 \times \frac{X}{Q_i} \times Q_I^i \times \bar{E}_I \quad (\text{Equation 15B-1})$$

where

D_{wb}^{os} = Offsite whole body dose for time period i


X/Q_i = Dispersion Factor for SB, LP \bar{E} for time period i

Q_I^i = total I-131 emitted in time period i

\bar{E}_I = .374 mSv/disint (Table 15B-2)

This equation is evaluated for the periods of 0-8 hrs and 8 hrs to 16 hrs to account for the change in X/Q at 8 hours.

Doses to control room operators as per 10CFR50 Appendix A-GDC19 is also evaluated for this conservative scenario. Since the



Dept. _____ PENNSYLVANIA POWER & LIGHT COMPANY ER No. _____
 Date _____ 19 _____ CALCULATION SHEET
 Designed by _____ PROJECT _____ Sht. No. 7 of _____
 Approved by _____

release of iodine will cause a high concentration of radioactivity in the reactor building, air inlet, the control room is assumed to be operating in the emergency mode and the CSEOASS filter train, operating with an iodine removal efficiency of .99. With this efficiency, the Iodine Protection Factor (IPF) (Reference 4) is 85.46. The control room thyroid dose is then formulated as

$$D_{\text{Thyroid}}^{\text{CR}} = \frac{K}{Q_i} \times BR_{\text{CR}} \times Q_i^i \times TDCF \times \frac{1}{IPF}$$

where

$D_{\text{Thyroid}}^{\text{CR}}$ = Control Room Thyroid Dose for time period i

$\frac{K}{Q_i}$ = Dispersion Factor for Control Room for the i th time period

18

18

18

18

18

18

18

18

18

18

18

18

18

18

18

18

18

18

18

18

18



Dept. _____ PENNSYLVANIA POWER & LIGHT COMPANY ER No. _____
 Date _____ 19 _____ CALCULATION SHEET
 Designed by _____ PROJECT _____ Sht. No. 8 of _____
 Approved by _____

BR_{CRi} = Control Room Breathing Rate for period i

Q_I^i = total iodine-131 emitted in time period i

TDCF = Thyroid Dose Conversion Factor

IPF = Iodine Protection Factor for Iodine (Ref 4)

The gamma (whole Body) dose is calculated for the i th period as

$$D_{\gamma i}^{CR} = .25 \frac{\chi^{CR}}{Q_i} \times Q_I^i \times \bar{E}_I \times \frac{1}{IPF}$$

where

$D_{\gamma i}^{CR}$ = Control Room Whole Body dose for period i


χ^{CR}/Q_i = Dispersion Factor for Control Room for the i th time period

Q_I^i = total iodine-131 emitted in time period i

$\bar{E}_I = .374 \frac{\text{MeV}}{\text{dis}}$ (Table 15B-2)

IPF = Iodine Protection Factor from Ref. 4

Due to the low energy γ @ .374 MeV/dis, it is assumed the control room walls shield operators from external iodine gamma contribution to whole body dose



Dept. _____ PENNSYLVANIA POWER & LIGHT COMPANY ER No. _____
 Date _____ 19 _____ CALCULATION SHEET
 Designed by _____ PROJECT _____ Sht. No. 9 of _____
 Approved by _____

The skin dose to control room operators can be evaluated using modified equations 15B-4 and 15B-10 from the SSES-FSAR. The skin dose (beta) for the i th time interval can be written:

$$D_{PIC}^{CR} = Q_{I}^i \times \frac{\chi^{CR}}{Q_i} \times \beta DCF \times \frac{1}{IPF}$$

D_{PIC}^{CR} = Control Room skin dose (beta) in period i

Q_I^i = Total iodine-131 emitted in time period i

χ^{CR}/Q_i = Dispersion Factor for Control Room for the i th time period.

βDCF = Beta Dose Conversion Factor, Table 15B-4
 $= 3.02 \times 10^{-2} \frac{\text{Rem/sec}}{\text{Ci/m}^3}$

IPF = Iodine Protection Factor from Reference 4

Dept. _____

PENNSYLVANIA POWER & LIGHT COMPANY
CALCULATION SHEET

ER No. _____

Date _____ 19 _____

Designed by _____

PROJECT _____

Sht. No. 10 of _____

Approved by _____

III RESULTS / CONCLUSIONS

The offsite doses and control room doses associated with the above scenario all fall below 10CFR100 and 10CFR50 Appendix A GDC 19 dose limits for the extremely conservative assumptions used in the analysis. As such, it can be reasonably assumed that a 25 GPM leak of Reactor Water (or steam) occurring in the actual plant would have even less dose consequences.

A summary Table of the calculated doses is provided in Table 1.




TABLE 1: COMPARISON OF CALCULATED DOSES TO 10CFR DOSE LIMITS.

<u>DOSE CATEGORY</u>	<u>CALCULATED DOSE (REM)</u>	<u>DOSE LIMIT (REM)</u>	<u>REGULATION</u>
2 HR* SITE BOUNDARY THYROID	16.6	300 @ 2HR	10CFR 100
2 HR* SITE BOUNDARY WHOLE BODY	3.0×10^{-2}	25 @ 2HR	10CFR 100
30 DAY** LOW POP ZONE THYROID	1.7	300 @ 30DAYS	10CFR 100
30 DAY** LOW POP ZONE WHOLE BODY	3.05×10^{-4}	25 @ 30DAYS	10CFR 100
30 DAY** CONTROL ROOM THYROID	.426	30 @ 30DAYS	10CFR 50 APP. A - 60C19
30 DAY** CONTROL ROOM WHOLE BODY	$\frac{8.0 \times 10^{-5}}{3.2 \times 10^{-4}}$ Rev. 2	5 @ 30DAYS	10CFR 50 APP. A - 60C19
30 DAY** CONTROL ROOM SKIN	2.53×10^{-5}	30 @ 30DAYS	10CFR 50 APP. A - 60C19

NOTES:


* ACTUAL EXPOSURE WAS FOR 16 HOURS,
10CFR 100 REQUIRES DOSE EVALUATION AT 2HRS ONLY, HOWEVER, EVEN 16 HOUR DOSE IS BELOW LIMITS.

** ACTUAL EXPOSURE WAS FOR 16 HOURS, NO
FURTHER DOSE ACCRUED FOR 16 HOURS TO 30 DAYS
10CFR 100 and 10CFR 50 REQUIRE DOSE EVALUATION AT 30 DAYS

Dept. _____
Date _____ 19____
Designed by _____
Approved by _____

PENNSYLVANIA POWER & LIGHT COMPANY
CALCULATION SHEET
PROJECT _____


ER No. _____
Snt. No. 11 of _____



Dept. _____ PENNSYLVANIA POWER & LIGHT COMPANY ER No. _____
Date _____ 19 _____ CALCULATION SHEET
Designed by _____ PROJECT _____ Sht. No. 2 of _____
Approved by _____

IV. REFERENCES

1. SSES - FSAR, Chapter 15, Accident Analyses
2. SSES Chemistry Manual, Chapter 2.3.3.5
3. SSES Unit 1/Unit 2 Technical Specifications Section 3/4.4.5
4. TACT-III Evaluation of SOOR-1-88-042, System Engineering Calculation SE-1-NA-005 December, 1988.
5. Meteorology and Atomic Energy - 1968, D.H. Slade, USAEC/Division of Technical Information, 1968.
6. ASME STEAM TABLES - 1983



Dept. _____ PENNSYLVANIA POWER & LIGHT COMPANY
 CALCULATION SHEET

ER No. _____

Date _____ 19 _____

Designed by _____

PROJECT _____

Sht. No. 13 of _____

Approved by _____

Appendix A

Parameter Values Extracted from source
 = FSAR Chapter 15

Parameter	Value	Reference (FSAR)
\dot{V}/Q , SB 0-16 HRS*	$2.5 \times 10^{-4} \frac{\text{sec}}{\text{m}^3}$	Table 15B-3
\dot{V}/Q , IPE 0-3 HRS	$2.13 \times 10^{-5} \frac{\text{sec}}{\text{m}^3}$	Table 15B-3
\dot{V}/Q , IPE 3-24 HRS	$2.3 \times 10^{-5} \frac{\text{sec}}{\text{m}^3}$	Table 15B-3
\dot{V}/Q , CR 0-8 HRS	$3.32 \times 10^{-4} \frac{\text{sec}}{\text{m}^3}$	Table 15B-1
\dot{V}/Q , CR 8-24 HRS	$1.96 \times 10^{-4} \frac{\text{sec}}{\text{m}^3}$	Table 15B-1
Thyroid Dose Conv. Factor I-131	$1.49 \times 10^6 \frac{\text{Rem}}{\text{Curie}}$	Table 15B-2
β Dose Conversion Factor	$3.02 \times 10^{-2} \frac{\text{Rem/sec}}{\text{Ci/m}^3}$	Table 15B-4
BR, Breathing Rate, Conservatively used in ALL time periods.	$3.47 \times 10^{-4} \frac{\text{m}^3}{\text{sec}}$	Table 15B-3
IPF, Iodine Protection Factor	85.46	Reference 4
\overline{E}_I , Average Energy of I-131 per disintegration	$.374 \frac{\text{MeV}}{\text{dis.}}$	Table 15B-2

* This value assumed conservatively to extend to 16 hrs.

22
1A

2

1

2

2

2

2

2

2

2

2

2

2

2

2



Dept. _____ PENNSYLVANIA POWER & LIGHT COMPANY ER No. _____
 Date _____ 19 _____ CALCULATION SHEET
 Designed by _____ PROJECT _____ Sht. No. 12
 Approved by _____

Appendix B Numerical Calculations

1) Determine Source Term in Ci/hr for 25 GPM Leak.

- Assume Reactor Water at 548°F and 1028 psia -

$$\therefore \rho_{RW} = 46.08 \frac{\text{lbm}}{\text{ft}^3} = .74 \frac{\text{gm}}{\text{ml}} \quad (\text{Steam Tables-Ref 6})$$

- Assume 4.0 $\mu\text{Ci/gm}$ DE-I-131 Source Concentration

$$\text{Ci/hr of I-131} = \dot{Q}_I$$

$$\dot{Q}_I = 25 \text{ GPM} \times 3785.3 \frac{\text{ml}}{\text{gallon}} \times .74 \frac{\text{gm}}{\text{ml}} \times 4.0 \frac{\mu\text{Ci}}{\text{gm}} \\ \times \frac{1 \text{ Ci}}{10^6 \mu\text{Ci}} \times \frac{60 \text{ min}}{\text{hr}}$$

$$\boxed{\dot{Q}_I = 16.8 \text{ Ci/hr}}$$

2) Calculate Thyroid Dose For Site Boundary

$$\dot{Q} \times \Delta t \times \frac{1}{2} \times \beta \times \text{TDCF}$$

$$D_{\text{Th-16}}^{\text{SB}} = 16.8 \frac{\text{Ci}}{\text{hr}} \times 16 \text{ hr} \times 9.6 \times 10^{-4} \frac{\text{sec}}{\text{m}^2} \times 3.47 \times 10^{-9} \frac{\text{m}^3}{\text{sec}} \\ \times 1.48 \times 10^6 \frac{\text{Rem}}{\text{Ci}}$$

$$\boxed{D_{\text{Th-16}}^{\text{SB}} = 132.5 \text{ Rem @ 16 hrs}}$$

$$\therefore D_{\text{Th-2}}^{\text{SB}} = 132.5 \times \frac{2 \text{ hr}}{16 \text{ hr}} = 16.6 \text{ Rem @ 2 hrs}$$

Dept. _____ PENNSYLVANIA POWER & LIGHT COMPANY ER No. _____
 Date _____ 19 _____ CALCULATION SHEET
 Designed by _____ PROJECT _____ Sht. No. 15 of _____
 Approved by _____

3) Calculate Thyroid Dose for Low Population Zone

$$\dot{Q} \times \Delta t \times \frac{V}{Q} \times BR \times TDF$$

$$D_{0-8}^{LPZ} = 16.9 \frac{Ci}{hr} \times 8hr \times 2.18 \times 10^5 \frac{sec}{m^3} \times 3.47 \times 10^{-4} \frac{m^3}{sec} \times 1.43 \times 10^6 \frac{Rem}{Ci}$$

$$= 1.5 \text{ Rem}$$

$$D_{8-16}^{LPZ} = 16.9 \frac{Ci}{hr} \times 8hr \times 2.92 \times 10^5 \frac{sec}{m^3} \times 3.47 \times 10^{-4} \frac{m^3}{sec} \times 1.43 \times 10^6 \frac{Rem}{Ci}$$

$$= .2 \text{ Rem}$$

$$D_{0-16}^{LPZ} = D_{0-8}^{LPZ} + D_{8-16}^{LPZ} = 1.5 \text{ Rem} + .2 \text{ Rem} = 1.7 \text{ Rem}$$

4) Calculate Whole Body Dose for Site Boundary

$$.25 \times \dot{Q} \times \Delta t \times \frac{V}{Q} \times \bar{E}_I$$

$$D_{80-16}^{SB} = .25 \times 16.9 \frac{Ci}{hr} \times 16hr \times 9.6 \times 10^{-4} \frac{sec}{m^3} \times .374 \frac{MeV}{dis}$$

$$D_{80-16}^{SB} = .024 \text{ Rem @ 16hrs}$$

$$\therefore D_{80-2}^{SB} = .024 \text{ Rem} \times \frac{2hr}{16hr} = .0030 \text{ Rem @ 2hrs}$$

Dept. _____ PENNSYLVANIA POWER & LIGHT COMPANY ER No. _____
 Date _____ 19 _____ CALCULATION SHEET
 Designed by _____ PROJECT _____ Sht. No. 16 of _____
 Approved by _____

5) Calculate Whole Body Dose for Low Population Zone

$$D_{0-8}^{LPZ} = .25 \times \dot{Q} \times \Delta t \times \frac{1}{2} \times \bar{E}_I$$

$$= .25 \times 16.8 \frac{Ci}{hr} \times 8hr \times 2.18 \times 10^{-5} \frac{sec}{m^3} \times .374 \frac{mCi}{dis}$$


$$= 2.7 \times 10^{-4} \text{ Rem}$$

$$D_{8-16}^{LPZ} = .25 \times 16.8 \frac{Ci}{hr} \times 8hr \times 2.82 \times 10^{-6} \frac{sec}{hr} \times .374 \frac{mCi}{dis}$$

$$= 3.5 \times 10^{-5} \text{ Rem}$$

$$D_{0-16}^{LPZ} = D_{0-8}^{LPZ} + D_{8-16}^{LPZ} = 2.7 \times 10^{-4} \text{ Rem} + 3.5 \times 10^{-5} \text{ Rem}$$

$$D_{0-16}^{LPZ} = 3.05 \times 10^{-4} \text{ Rem}$$



Dept. _____ PENNSYLVANIA POWER & LIGHT COMPANY ER No. _____
 Date _____ 19_____ CALCULATION SHEET
 Designed by _____ PROJECT _____ Sht. No. 17 of _____
 Approved by _____

6) Calculate Thyroid Dose for Control Room

$$D_{\text{Thyroid 0-8}}^{\text{CR}} = Q \times \Delta t \times \frac{1}{3} \times \text{BR} \times \text{Conversion Factors}$$

$$= 16.8 \text{ Ci/hr} \times 8 \text{ hr} \times 3.32 \times 10^{-4} \frac{\text{Sec}}{\text{m}^3} \times 3.47 \times 10^{-4} \frac{\text{m}^3}{\text{Sec}} \times 1.48 \times 10^6 \frac{\text{Bq}}{\text{Ci}} \times \frac{1}{85.46}$$

$$D_{\text{Thyroid 0-8}}^{\text{CR}} = .268 \text{ Rem}$$

$$D_{\text{Thyroid 8-16}}^{\text{CR}} = 16.8 \text{ Ci/hr} \times 8 \text{ hr} \times 1.96 \times 10^{-9} \frac{\text{Sec}}{\text{m}^3} \times 3.47 \times 10^{-4} \frac{\text{m}^3}{\text{Sec}} \times 1.48 \times 10^6 \frac{\text{Bq}}{\text{Ci}} \times \frac{1}{85.46}$$

$$D_{\text{Thyroid 8-16}}^{\text{CR}} = .158 \text{ Rem}$$

$$D_{\text{Thyroid 0-16}}^{\text{CR}} = D_{\text{Thyroid 0-8}}^{\text{CR}} + D_{\text{Thyroid 8-16}}^{\text{CR}} = .268 \text{ Rem} + .158 \text{ Rem} =$$

$$D_{\text{Thyroid 0-16}}^{\text{CR}} = .426 \text{ Rem}$$

7) Calculate Whole Body Dose for Control Room

$$D_{\text{0-8}}^{\text{CR}} = 16.8 \frac{\text{Ci}}{\text{hr}} \times 8 \text{ hr} \times 3.32 \times 10^{-4} \frac{\text{Sec}}{\text{m}^3} \times .374 \frac{\text{MeV}}{\text{Dis}} \times \frac{1}{85.46} \times .25 \times .25$$

(Rev. 2)

$$D_{\text{0-8}}^{\text{CR}} = \frac{5.0 \times 10^{-5} \text{ Rem}}{2.0 \times 10^{-4} \text{ Rem}} \quad \left. \begin{array}{l} \text{Rev. 2} \\ \text{Rev. 2} \end{array} \right\}$$

$$D_{\text{8-16}}^{\text{CR}} = 16.8 \frac{\text{Ci}}{\text{hr}} \times 8 \text{ hr} \times 1.96 \times 10^{-4} \frac{\text{Sec}}{\text{m}^3} \times .374 \frac{\text{MeV}}{\text{Dis}} \times \frac{1}{85.46} \times .25 \times .25$$

(Rev. 2)

$$D_{\text{8-16}}^{\text{CR}} = \frac{3.0 \times 10^{-5} \text{ Rem}}{1.2 \times 10^{-4} \text{ Rem}} \quad \left. \begin{array}{l} \text{Rev. 2} \\ \text{Rev. 2} \end{array} \right\}$$

Dept. _____ PENNSYLVANIA POWER & LIGHT COMPANY ER No. _____
 Date _____ 19 _____ CALCULATION SHEET
 Designed by _____ PROJECT _____ Sht. No 13 of _____
 Approved by _____

$$D_{80-16}^{CR} = D_{80-3}^{CR} + D_{83-16}^{CR} = \frac{5.0 \times 10^{-5} + 3.0 \times 10^{-5}}{2.0 \times 10^{-4} + 1.2 \times 10^{-4}} = \frac{8.0 \times 10^{-5} \text{ Rem}}{3.2 \times 10^{-1} \text{ Rem}} \text{ Rem}$$

8) Calculate Skin Dose for Control Room

$$\dot{Q} \times \Delta t \times \frac{C}{2} \times \text{PF} \times \frac{1}{\text{IPF}}$$


$$D_{810-8}^{CR} = 16.8 \frac{\text{Ci}}{\text{hr}} \times 8 \text{ hr} \times 3.32 \times 10^{-4} \frac{\text{Sec}}{\text{hr}} \times 3.02 \times 10^{-2} \frac{\text{Rem/Sec}}{\text{Ci/m}^3} \times \frac{1}{85.46}$$

$$D_{810-8}^{CR} = 1.6 \times 10^{-5} \text{ Rem}$$

$$D_{818-16}^{CR} = 16.8 \frac{\text{Ci}}{\text{hr}} \times 8 \text{ hr} \times 1.96 \times 10^{-4} \frac{\text{Sec}}{\text{hr}} \times 3.02 \times 10^{-2} \frac{\text{Rem/Sec}}{\text{Ci/m}^3} \times \frac{1}{85.76}$$

$$D_{818-16}^{CR} = 9.3 \times 10^{-6} \text{ Rem}$$

$$D_{810-16}^{CR} = D_{810-8}^{CR} + D_{818-16}^{CR} = 1.6 \times 10^{-5} \text{ Rem} + 9.3 \times 10^{-6} \text{ Rem} = 2.53 \times 10^{-5} \text{ Rem}$$



Dept. _____

PENNSYLVANIA POWER & LIGHT COMPANY
 CALCULATION SHEET

ER No.

Date _____ 19__

Designed by ..

PROJECT

Sheet No. 19


Approved by ..

Appendix C

Extension of Calculation to a Leak of
 50 gpm for a 48 hr. Period.

I. INTRODUCTION

The purpose of this Appendix is to extend the methodology of the dose calculation to an increased leakage flow and leak duration. The leakage is increased to 50 gpm of reactor grade water for a duration of 48 hrs. This situation is considered to provide a conservative bounds for future requirements for analysis of this type. The \times/Q s for the low population zone and control room must be extended to the 48 hr leak period duration. The site boundary \times/Q will remain the same because the required evaluation time is at 2 hrs.



Dept. _____

PENNSYLVANIA POWER & LIGHT COMPANY
CALCULATION SHEET

ER No. _____

Date _____ 19____

Designed by _____

PROJECT _____

Sht. No. 20

Approved by _____

For the Site Population Zone (LPZ), X/Q , the value from Table IS.0-3 for the 24-96 hr time period is used. That is:

$$X/Q, LPZ (24-96 \text{ hrs}) = \boxed{1.43 \times 10^{-6} \frac{\text{Sec}}{\text{m}^3}}$$

For the Control Room X/Q , the value from Table ISB-1 for the 1-4 day time period is used. That is

$$X/Q, CR (1-4 \text{ day} / 24-96 \text{ hr}) = \boxed{7.64 \times 10^{-5} \frac{\text{Sec}}{\text{m}^3}}$$

The above X/Q 's are required to extend the calculation to the 48hr leak period. Note that a conservative breathing rate of $3.47 \times 10^{-4} \text{ m}^3/\text{sec}$ is used for all time periods in this calculation for additional conservatism. All dose values are rounded up for conservatism.

Dept. _____

PENNSYLVANIA POWER & LIGHT COMPANY
CALCULATION SHEET

ER No _____

Date _____ 19 _____

Designed by _____

PROJECT _____

Site No. 21

Approved by _____

II. Numerical Calculations

- 1) Determine Source Term: from Appendix B-1), substituting 50 GPM for 25 GPM gives

$$\dot{Q}_I = 50 \text{ GPM} \times 3785.3 \frac{\text{ml}}{\text{gallon}} \times .74 \frac{\text{gm}}{\text{ml}} \times 4.0 \frac{\mu\text{Ci}}{\text{gm}} \times \frac{1 \text{ Ci}}{10^6 \mu\text{Ci}} \times \frac{60 \text{ min}}{\text{hr}}$$

$$\dot{Q}_I = 33.6 \frac{\text{Ci}}{\text{hr}}$$

- 2) Calculate 2 HR Site Boundary Thyroid Dose -

$$D_{Th(0-2)}^{SB} = \dot{Q}_I \times \Delta t \times \frac{x}{Q} \times \beta \times \text{TDCF}$$

$$= 33.6 \frac{\text{Ci}}{\text{hr}} \times 2 \text{ hr} \times 9.6 \times 10^{-4} \frac{\text{sec}}{\text{m}^3} \times 3.47 \times 10^{-4} \frac{\text{m}^3}{\text{sec}} \times 1.48 \times 10^6 \frac{\text{Rem}}{\text{Ci}}$$

$$D_{Th(0-2)}^{SB} = 33.2 \text{ Rem @ 2 hrs}$$



Vertical text or markings along the left edge of the page, possibly bleed-through from the reverse side.

Dept. _____ PENNSYLVANIA POWER & LIGHT COMPANY ER No. ...
 Date ... 19... CALCULATION SHEET
 Designed by _____ PROJECT ... Sh. No. 22
 Approved by _____

3) Calculate Thyroid Dose for Low Population Zone

$$D_{TH}^{LPZ} = \dot{Q} \times \Delta t \times \frac{1}{Q} \times BR \times TDCF$$

$$D_{TH}^{LPZ}(0-8) = 33.6 \frac{Ci}{hr} \times 8hr \times 2.18 \times 10^{-5} \frac{sec}{m^3} \times 3.47 \times 10^{-4} \frac{m^3}{sec} \times 1.48 \times 10^5 \frac{Rem}{Ci}$$

$$= 3.1 \text{ Rem}$$

$$D_{TH}^{LPZ}(8-24) = 33.6 \frac{Ci}{hr} \times 16hr \times 2.82 \times 10^{-6} \frac{sec}{m^3} \times 3.47 \times 10^{-4} \frac{m^3}{sec} \times 1.48 \times 10^6 \frac{Rem}{Ci}$$

$$= .8 \text{ Rem}$$

$$D_{TH}^{LPZ}(24-43) = 33.6 \frac{Ci}{hr} \times 24hr \times 1.43 \times 10^{-6} \frac{sec}{m^3} \times 3.47 \times 10^{-4} \frac{m^3}{sec} \times 1.48 \times 10^6 \frac{Rem}{Ci}$$

$$= .6 \text{ Rem}$$

$$D_{TH}^{LPZ}(0-43) = D_{TH}^{LPZ}(0-8) + D_{TH}^{LPZ}(8-24) + D_{TH}^{LPZ}(24-43) = 3.1 \text{ Rem} + .8 \text{ Rem} + .6 \text{ Rem} = 4.5 \text{ Rem}$$

4) Calculate Whole Body Dose for Site Boundary

$$D_y^{SB}(0-2) = .25 \times \dot{Q} \times \Delta t \times \frac{1}{Q} \times \bar{E}_I$$

$$D_y^{SB}(0-2) = .25 \times 33.6 \frac{Ci}{hr} \times 2hr \times 9.6 \times 10^{-4} \frac{sec}{m^3} \times .374 \frac{MeV}{dis}$$

$$D_y^{SB}(0-2) = 6.1 \times 10^{-3} \text{ Rem @ 2hrs}$$

Dept. _____ PENNSYLVANIA POWER & LIGHT COMPANY ER No. _____
 Date ... 19 _____ CALCULATION SHEET
 Designed by _____ PROJECT _____ Sht. No 23
 Approved by _____

5) Calculate Whole Body Dose for Low Population Zone

$$D_y^{LPZ}(0-8) = .25 \times \dot{Q} \times \Delta t \times \frac{1}{Q} \times \bar{E}_I$$

$$= .25 \times 33.6 \frac{Ci}{hr} \times 8hr \times 2.18 \times 10^{-5} \frac{sec}{m^3} \times .374 \frac{MeV}{dis}$$

$$= 5.5 \times 10^{-4} \text{ Rem}$$

$$D_y^{LPZ}(8-24) = .25 \times 33.6 \frac{Ci}{hr} \times 16hr \times 2.82 \times 10^{-6} \frac{sec}{m^3} \times .374 \frac{MeV}{dis}$$

$$= 1.5 \times 10^{-4} \text{ Rem}$$

$$D_y^{LPZ}(24-48) = .25 \times 33.6 \frac{Ci}{hr} \times 24hr \times 1.43 \times 10^{-6} \frac{sec}{m^3} \times .374 \frac{MeV}{dis}$$

$$= 1.1 \times 10^{-4} \text{ Rem}$$

$$D_y^{LPZ}(0-48) = D_y^{LPZ}(0-8) + D_y^{LPZ}(8-24) + D_y^{LPZ}(24-48) = 5.5 \times 10^{-4} \text{ Rem} + 1.5 \times 10^{-4} \text{ Rem} + 1.1 \times 10^{-4} \text{ Rem}$$

$$D_y^{LPZ}(0-48) = 8.1 \times 10^{-4} \text{ Rem}$$

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100



Dept. _____ PENNSYLVANIA POWER & LIGHT COMPANY ER No. _____
 Date _____ 19 _____ CALCULATION SHEET
 Designed by _____ PROJECT _____ Ser. No. 24
 Approved by _____

6) Calculate Thyroid Dose for Control Room

$$D_{TH}^{CR}(0-8) = Q \times \Delta t \times \frac{1}{Q} \times BR \times TDCF \times \frac{1}{IPF}$$

$$D_{TH}^{CR}(0-8) = 33.6 \frac{Ci}{hr} \times 8hr \times 3.32 \times 10^{-4} \frac{Sec}{m^3} \times 3.47 \times 10^{-4} \frac{m^3}{SPC} \times 1.43 \times 10^6 \frac{Rem}{Ci} \times \frac{1}{85.46}$$

$$= .54 Rem$$

$$D_{TH}^{CR}(8-24) = 33.6 \frac{Ci}{hr} \times 16hr \times 1.96 \times 10^{-4} \frac{Sec}{m^3} \times 3.47 \times 10^{-4} \frac{m^3}{Sec} \times 1.43 \times 10^6 \frac{Rem}{Ci} \times \frac{1}{85.46}$$

$$= .64 Rem$$

$$D_{TH}^{CR}(24-48) = 33.6 \frac{Ci}{hr} \times 24hr \times 7.64 \times 10^{-5} \frac{Sec}{m^3} \times 3.47 \times 10^{-4} \frac{m^3}{Sec} \times 1.43 \times 10^6 \frac{Rem}{Ci} \times \frac{1}{85.46}$$

$$= .38 Rem$$

$$D_{TH}^{CR}(0-48) = D_{TH}^{CR}(0-8) + D_{TH}^{CR}(8-24) + D_{TH}^{CR}(24-48) = .54 Rem + .64 Rem + .38 Rem$$

$$D_{TH}^{CR}(0-48) = 1.6 Rem$$

7) Calculate Whole Body Dose for Control Room

$$D_y^{CR}(0-8) = Q \times \Delta t \times \frac{1}{Q} \times \bar{E} \times \frac{1}{IPF}$$

$$D_y^{CR}(0-8) = 33.6 \frac{Ci}{hr} \times 8hr \times 3.32 \times 10^{-4} \frac{Sec}{m^3} \times .374 \frac{MeV}{dis} \times \frac{1}{85.46} \times .25$$

$$= 1.0 \times 10^{-4} Rem \quad \text{Rev. 2}$$

$$= \cancel{4.0 \times 10^{-4} Rem} \quad \text{Rev. 2}$$

$$D_y^{CR}(8-24) = 33.6 \frac{Ci}{hr} \times 16hr \times 1.96 \times 10^{-4} \frac{Sec}{m^3} \times .374 \frac{MeV}{dis} \times \frac{1}{85.46} \times .25$$

$$= 1.175 \times 10^{-4} Rem \quad \text{Rev. 2}$$

$$= \cancel{4.7 \times 10^{-4} Rem}$$

Dept. _____

PENNSYLVANIA POWER & LIGHT COMPANY
 CALCULATION SHEET

ER No. _____

Date _____ 19 _____

Designed by _____

PROJECT _____

Srs. No: 25

Approved by _____

$$D_y^{CR}(24-48) = 33.6 \frac{Ci}{hr} \times 24hr \times 7.64 \times 10^{-5} \frac{sec}{m^3} \times .374 \frac{mV}{A's} \times \frac{1}{85.46} \times 2.25$$

$$= 6.75 \times 10^{-5} \text{ Rem} \quad \text{Rev. 2}$$

$$= 2.7 \times 10^{-4} \text{ Rem}$$

$$D_y^{CR}(0-48) = D_y^{CR}(0-8) + D_y^{CR}(8-24) + D_y^{CR}(24-48) = 1.0 \times 10^{-4} + 1.175 \times 10^{-4} + 6.75 \times 10^{-5}$$

$$= 4.0 \times 10^{-4} \text{ Rem} + 4.7 \times 10^{-4} \text{ Rem} + 2.7 \times 10^{-4} \text{ Rem}$$

$$D_y^{CR}(0-48) = \frac{2.850 \times 10^{-4} \text{ Rem}}{1.2 \times 10^{-4} \text{ Rem}}$$

8) Calculate Skin Dose for Control Room

$$D_{PI}^{CR}(0-8) = 33.6 \frac{Ci}{hr} \times 8hr \times 3.32 \times 10^{-4} \frac{sec}{m^3} \times 3.02 \times 10^{-2} \frac{Rem/sec}{Ci/m^3} \times \frac{1}{85.46}$$

$$= 3.2 \times 10^{-5} \text{ Rem}$$

$$D_{PI}^{CR}(8-24) = 33.6 \frac{Ci}{hr} \times 16hr \times 1.96 \times 10^{-4} \frac{sec}{m^3} \times 3.02 \times 10^{-2} \frac{Rem/sec}{Ci/m^3} \times \frac{1}{85.46}$$

$$= 3.8 \times 10^{-5} \text{ Rem}$$

$$D_{PI}^{CR}(24-48) = 33.6 \frac{Ci}{hr} \times 24hr \times 7.64 \times 10^{-5} \frac{sec}{m^3} \times 3.02 \times 10^{-2} \frac{Rem/sec}{Ci/m^3} \times \frac{1}{85.46}$$

$$= 2.2 \times 10^{-5} \text{ Rem}$$

$$D_{PI}^{CR}(0-48) = D_{PI}^{CR}(0-8) + D_{PI}^{CR}(8-24) + D_{PI}^{CR}(24-48) = 3.2 \times 10^{-5} \text{ Rem} + 3.8 \times 10^{-5} \text{ Rem} + 2.2 \times 10^{-5} \text{ Rem}$$

$$D_{PI}^{CR}(0-48) = 9.2 \times 10^{-5} \text{ Rem}$$




TABLE C1 - COMPARISON OF CALCULATED DOSES FOR 50 GPM LEAK FOR 48 HR TIME PERIOD TO 10 CFR DOSE LIMITS

<u>DOSE CATEGORY</u>	<u>CALCULATED DOSE (REM)</u>	<u>DOSE LIMIT (REM)</u>	<u>REGULATION</u>
2 HR* SITE BOUNDARY THYROID	33.2	300 @ 2HR	10 CFR 100
2 HR* SITE BOUNDARY WHOLE BODY	6.1×10^{-3}	25 @ 2HR	10 CFR 100
30 DAY** LOW POPULATION ZONE THYROID	4.5	300 @ 30 DAYS	10 CFR 100
30 DAY** LOW POPULATION ZONE WHOLE BODY	8.1×10^{-4}	25 @ 30 DAYS	10 CFR 100
30 DAY** CONTROL ROOM THYROID	1.6	30 @ 30 DAYS	10 CFR 50 APP. A - GDC 17
30 DAY** CONTROL ROOM WHOLE BODY	$\frac{2.850 \times 10^{-4}}{1.2 \times 10^{-3}}$ Rev. 2	5 @ 30 DAYS	10 CFR 50 APP. A - GDC 19
30 DAY** CONTROL ROOM SKIN	9.2×10^{-5}	75 ^{***} @ 30 DAYS	10 CFR 50 APP. A - GDC 19

* ALTHOUGH ACTUAL EXPOSURE PERIOD IS 48 HRS, REG. REQUIRES DOSE CALC @ 2HR FOR SITE BUDY.

** ACTUAL EXPOSURE ENDED AFTER 48 HRS, WITH NO FURTHER DOSE ACCUMULATED OUT TO 30 DAYS

*** SKIN DOSE LIMIT IS INCREASED TO 75 REM BECAUSE PPL HAS COMMITTED TO PROTECTIVE CLOTHING REQMT IN EP-IP-033.

Dept. _____
Date _____ 19_____
Designed by _____
Approved by _____

PENNSYLVANIA POWER & LIGHT COMPANY
CALCULATION SHEET
PROJECT _____

ER NO. _____
Snr: 10.26

Dept. _____ PENNSYLVANIA POWER & LIGHT COMPANY ER No. _____
Date .. 19 _____ CALCULATION SHEET
Designed by _____ PROJECT _____ Sht. No. 27
Approved by _____

III RESULTS.

The results of the calculations are displayed
in TABLE C1.

IV CONCLUSIONS

The results show that even for a leak
rate of 50 GPM for a duration of 48 hrs,
NO 10 CFR 100 or 10 CFR 50 dose limits
are exceeded even with the extreme
conservatism considered in this analysis.

