

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9112170429 DOC. DATE: 91/12/11 NOTARIZED: NO. DOCKET #
 FACIL: 50-388 Susquehanna Steam Electric Station, Unit 2, Pennsylvania 05000388
 AUTH. NAME AUTHOR AFFILIATION
 KEISER, H.W. Pennsylvania Power & Light Co.
 RECIP. NAME RECIPIENT AFFILIATION
 MARTIN, T.T. Region 1 (Post 820201)

SUBJECT: Lists snubber sample plan for fifth refueling & insp outage, per 910114 ltr. Advises that util will test 10% of each type of snubber in accordance w/Spec 4.7.4.e.1 rather than utilizing Spec 4.7.4.e.3 for certain types.

DISTRIBUTION CODE: IE01D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 2
 TITLE: General (50 Dkt)-Insp Rept/Notice of Violation Response

NOTES: LPDR 1 cy Transcripts. 05000388

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID CODE/NAME		LTR	ENCL		ID CODE/NAME		LTR	ENCL
	PD1-2 PD		1	1		RALEIGH, J.		1	1
INTERNAL:	ACRS		2	2		AEOD		1	1
	AEOD/DEIIB		1	1		AEOD/DSP/TPAB		1	1
	DEDRO		1	1		NRR HARBUCK, C.		1	1
	NRR MORISSEAU, D		1	1		NRR/DLPQ/LHFBPT		1	1
	NRR/DLPQ/LPEB10		1	1		NRR/DOEA/OEAB		1	1
	NRR/DREP/PEPB9H		1	1		NRR/DST/DIR 8E2		1	1
	NRR/PMAS/ILRB12		1	1		NUDOCS-ABSTRACT		1	1
	OE DIR		1	1		OGC/HDS2		1	1
	<u>REG FILES</u> 02		1	1		RGN1 FILE 01		1	1
EXTERNAL:	EG&G/BRYCE, J.H.		1	1		NRC PDR		1	1
	NSIC		1	1					

NOTES: 2 2


NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK, ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR 26 ENCL 260

MP/WH

R
I
D
S
/
A
D
D
S
/
A
D
D
S



Pennsylvania Power & Light Company

Two North Ninth Street • Allentown, PA 18101-1179 • 215/774-5151

DEC 11 1991

Harold W. Keiser
Senior Vice President-Nuclear
215/774-4194

Mr. Thomas T. Martin
Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

**SUSQUEHANNA STEAM ELECTRIC STATION
SNUBBER SAMPLE PLAN - UNIT 2 FIFTH
REFUELING AND INSPECTION OUTAGE
PLA-3692 FILES A17-2/R41-2**

Docket No. 50-388

Reference: PLA-3481, H.W. Keiser to T.T. Martin, dated January 14, 1991

Dear Mr. Martin:

Via the referenced letter, PP&L notified the NRC of the snubber sample plan for the Susquehanna SES Unit 2 fourth refueling and inspection outage, as required by Technical Specification 4.7.4e. This specification also requires us to notify you prior to the beginning of any subsequent outage if the sample plan has changed since the last test period. This transmittal fulfills that requirement.

The sample plan for the SSES Unit 2 fifth refueling and inspection outage will be changed from the plan used during the fourth refueling and inspection outage. PP&L has chosen to test 10% of each type of snubber in accordance with Specification 4.7.4.e.1 rather than utilizing Specification 4.7.4.e.3 for certain types.

Therefore, the sample plan for the SSES Unit 2 fifth refueling and inspection outage will be as follows:

TYPE	SAMPLE PLAN
1. PSA - 1/4 and 1/2	Specification 4.7.4.e.1.
2. PSA - 1, 3, and 10	Specification 4.7.4.e.1.
3. PSA - 35	Specification 4.7.4.e.1.
4. PSA - 100	Specification 4.7.4.e.1.
5. Compensating Struts	Specification 4.7.4.e.1.

91111/0427 215/774-4194
EDV ASGUS 0703 2300
B

TE01
1/0



Any questions on this transmittal should be directed to Mr. A.K. Maron at (215) 774-6536.

Very truly yours,

A handwritten signature in cursive script, appearing to read "H.W. Keiser".

H.W. Keiser

Attachment

cc: NRC Document Control Desk (original)
Mr. J. J. Raleigh, NRC Project Manager
Mr. G. S. Barber, NRC Sr. Resident Inspector