## SUSQUEHANNA STEAM ELECTRIC STATION SE TABLE 1 SUMMARY OF RELIEF REQUESTS

	SOMMAN OF RELIEF REQUESTS				
Relief Request Number	SE Sect.	Section:X1:Requirements	Equipment Identification	Proposed:Alternative Method of Testing	Recommended NRC:Action
PRR-52	H/A	IWP-3210, allowable ranges of inservice test quantities .	Various pumps in the RHR, Core Spray, ESW, RHRSW, HPCI, and SBLC Systems	1. The values of pump flow and pressure, corrected for the effects of instrument accuracy shall be compared to the allowable ranges for the corresponding test quantities, from Table IWP-3100-2, for determination of acceptability.  2. Instrument accuracies for use in these corrections shall be determined, as needed, by calibration of the flow and/or pressure instruments utilized for the pump test.  3. Actual accuracies for use in these corrections shall conform to the acceptable instrument accuracies established for flow instruments and for pressure instruments by Table IWP-4110-1.	Preapproved GL 89-04, Relief not evaluated in SE.
PRR-54	H/A	IWP-4310, bearing temperature measurement	Various pumps in the RHR, Core Spray, ESW, and RHRSW Systems	None .	Preapproved GL 89-04, Relief not evaluated in SE.
PRR-55	N/A	IWP-4120, required range of test instruments	Various pumps in the RHR, Core Spray and HPCI Systems	Utilize permanent plant pump suction pressure instruments for ISI pump test suction pressure measurements in RHR, Core Spray, and HPCI Systems.	Preapproved GL 89-04, Relief not evaluated in SE.
PRR-56		N/A	N/A	N/A	Request Withdrawn
PRR-63	2.5	IWP-3100, inservice test procedure requirement for pump speed to be adjusted to the reference speed.	1P204 and 1P209 (Unit 1) 2P204 and 2P209 (Unit 2) Combination pumps located in the HPCI . System	When pump test speed differs from the reference speed by a measurable amount (10 RPM, or greater), the corrective action analysis, permitted by paragraph IWP-3230(c) may include a corrective calculation.	Relief Denied.

. . The state of the s • • F. 



## UNITED STATES NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555

June 16, 1992

Docket Nos. 50-387 and 50-388

Mr. Harold W. Keiser
Senior Vice President-Nuclear
Pennsylvania Power and Light
Company
2 North Ninth Street
Allentown, Pennsylvania 18101

Dear Mr. Keiser:

SUBJECT: SUPPLEMENTAL SAFETY EVALUATION (SSE) ON THE STATION BLACKOUT RULE

FOR SUSQUEHANNA STEAM ELECTRIC STATION, UNITS 1 AND 2 (TAC NOS.

M68613 AND M68614)


The Station Blackout (SBO) Rule requires licensees to submit information as defined in 10 CFR 50.63 and provide a plant and schedule for conformance to the SBO Rule. The Pennsylvania Power and Light Company's (the licensee) responses to the SBO Rule were provided by letters from H. W. Keiser dated April 17, 1989, April 17, 1990, and February 27, 1991, to the U.S. Nuclear Regulatory Commission. This was followed by the licensee's written response dated August 1, 1991, to questions during the June 14, 1991, telephone conference.

By letter dated January 14, 1992, the staff transmitted a Safety Evaluation (SE) on the above submittals that found the licensee's proposed method of coping with an SBO to be incomplete. The licensee responded to this SE by letter from H. W. Keiser, dated March 13, 1992, and its supplements dated April 14, 1992 and May 13, 1992.

The staff has reviewed the licensee's responses to the staff's January 14, 1992 SE pertaining to the SBO Rule and finds the licensee's response to be acceptable except that until Generic Issue (GI) B-56 is resolved, the licensee committed, during a telephone conversation on June 12, 1992, to an emergency diesel generator reliability program which as a minimum contains the five elements of Regulatory Guide 1.155, Section 1.2. Enclosed is the staff's SSE. Therefore, no further submittals are required.

It is the staff's position that the licensee must be in full compliance with the SBO Rule within 2 years after receipt of this SSE in accordance with 10 CFR 50.63(c)(4). Therefore, this requirement should be implemented to ensure complete compliance with the SBO rule as indicated in the staff's SE and SSE. The licensee should maintain all documentation in support of its SBO submittals in its files for possible future NRC audit.

THE FILE CENTER COPY AA3



This SSE documents the NRC's final regulatory assessment of the licensee's proposed conformance to the SBO Rule and closes TAC Nos. M68613 and M68614.

If there are any questions please contact me on (301) 504-1447.

Sincerely,

/S/

George F. Maxwell, Acting Project Manager Project Directorate I-2 Division of Reactor Projects - I/II Office of Nuclear Reactor Regulation

Enclosure:

Supplemental Safety Evaluation

cc w/enclosure: See next page

## **DISTRIBUTION:**


Docket File
NRC & Local PDRs
PDI-2 Reading
SVarga
JCalvo
CMiller
MO'Brien(2)
JRaleigh
GMaxwell
OGC
AToalston
PTam

ACRS(10) EWenzinger, RGN-I JWhite, RGN-I

\*Previously Concurred

OFFICE	PDJ 22 A	PDI-2/PM()	SELB*	PDI-2/PD
NAME	MO'BRIEN	JRALWIGH:t1c	ATOALSTON	CMICLERU
DATE	6/16/92	6/16/92	06/16/92	6 /16/92

OFFICIAL RECORD COPY FILENAME: A:\SU68613.SER



Sincerely,

George F. Maxwell, Acting Project Manager

Project Directorate I-2

Division of Reactor Projects - I/II Office of Nuclear Reactor Regulation

Enclosure: Supplemental Safety Evaluation

cc w/enclosure: See next page Mr. Harold W. Keiser Pennsylvania Power & Light Company

Susquehanna Steam Electric Station, Units 1 & 2

cc:

Jay Silberg, Esq. Shaw, Pittman, Potts & Trowbridge 2300 N Street N.W. Washington, D.C. 20037

Bryan A. Snapp, Esq. Assistant Corporate Counsel Pennsylvania Power & Light Company 2 North Ninth Street Allentown, Pennsylvania 18101

Mr. J. M. Kenny Licensing Group Supervisor Pennsylvania Power & Light Company 2 North Ninth Street Allentown, Pennsylvania 18101

Mr. Scott Barber Senior Resident Inspector U. S. Nuclear Regulatory Commission P.O. Box 35 Berwick, Pennsylvania 18603-0035

Mr. Thomas M. Gerusky, Director Bureau of Radiation Protection Resources Commonwealth of Pennsylvania P. O. Box 2063 Harrisburg, Pennsylvania 17120

Mr. Jesse C. Tilton, III Allegheny Elec. Cooperative, Inc. 212 Locust Street P.O. Box 1266 Harrisburg, Pennsylvania 17108-1266 Regional Administrator, Region I U.S. Nuclear Regulatory Commission 475 Allendale Road King of Prussia, Pennsylvania 19406

Mr. Harold G. Stanley Superintendent of Plant Susquehanna Steam Electric Station Pennsylvania Power and Light Company 2 North Ninth Street Allentown, Pennsylvania 18101

Mr. Herbert D. Woodeshick Special Office of the President Pennsylvania Power and Light Company 1009 Fowles Avenue Berwick, Pennsylvania 18603

Mr. Robert G. Byram
Vice President-Nuclear Operations
Pennsylvania Power and Light Company
2 North Ninth Street
Allentown, Pennsylvania 18101