

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9207280016 DOC. DATE: 92/07/21 NOTARIZED: NO DOCKET #
 FACIL: 50-388 Susquehanna Steam Electric Station, Unit 2, Pennsylvania 05000388
 AUTH. NAME AUTHOR AFFILIATION
 KEISER, H.W. Pennsylvania Power & Light Co.
 RECIP. NAME RECIPIENT AFFILIATION
 MILLER, C.L. Project Directorate I-2

SUBJECT: Clarifies proposed Amend 105 to License NPF-22, transmitted via 920630 ltr, changing TS to support ensuing Cycle 6 reload, per discussions w/NRC. Encl TS Figure 3.2.1-1 revised to include note re average bundle exposure for 9x9 fuel.

DISTRIBUTION CODE: IE26D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 17
 TITLE: Startup Report/Refueling Report. (per Tech Specs)

NOTES: LPDR 1 cy Transcripts. ; MAXWELL, G 05000388

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID CODE/NAME		LTR	ENCL		ID CODE/NAME		LTR	ENCL
	PD1-2 LA		1	0		PD1-2 PD		1	1
	RALEIGH, J.		2	2					
INTERNAL:	ACRS		5	5		AEOD/DSP/TPAB		1	1
	NRR CHATTERTON		1	1		NUDOCS-ABSTRACT		1	1
	REG FILE 02		1	1		RGN1 FILE 01		1	1
EXTERNAL:	NRC PDR		1	1		NSIC		1	1
NOTES:			2	2					

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK, ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR 18 ENCL 17

AAJ



Pennsylvania Power & Light Company

Two North Ninth Street • Allentown, PA 18101-1179 • 215/774-5151

Harold W. Keiser
Senior Vice President-Nuclear
215/774-4194

JUL 21 1992

Director of Nuclear Reactor Regulation
Attention: Mr. C.L. Miller, Project Director
Project Directorate I-2
Division of Reactor Projects
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

**SUSQUEHANNA STEAM ELECTRIC STATION
PROPOSED AMENDMENT 105 TO LICENSE
NO. NPF-22: UNIT 2 CYCLE 6 RELOAD
PLA-3810 FILES A7-8C/A17-2/R41-2**

Docket No. 50-388

*Reference: PLA-3787, dated 6/30/92, Proposed Amendment 105 to License No. NPF-22: Unit 2
Cycle 6 Reload.*

Dear Mr. Miller:

The purpose of this letter is to provide a clarification to the proposed change to the Susquehanna SES Unit 2 Technical Specifications in support of the ensuing cycle 6 reload. Based on a discussion with Mr. L. Kopp of the NRC staff (SRXB), Figure 3.2.1-1 has been revised to include a note clarifying that the average bundle exposure for all 9x9 fuel, except the XN-1 fuel, is limited to 40,000 MWD/MT.

Questions regarding this revised response should be directed to Mr. A.K. Maron at (215) 774-7852.

Very truly yours,

H. W. Keiser

cc: NRC Document Control Desk (original)
NRC Region I
Mr. G. S. Barber, NRC Sr. Resident Inspector - SSES
Mr. G. F. Maxwell, Acting NRC Project Manager - Rockville
Mr. L. I. Kopp, NRR/SRXB - Rockville

9207280016 920721
PDR ADDCK 05000388
P PDR