

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM
 REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9210060336 DOC. DATE: 92/10/01 NOTARIZED: NO DOCKET #
 FACIL: 50-387 Susquehanna Steam Electric Station, Unit 1, Pennsylvania 05000387
 50-388 Susquehanna Steam Electric Station, Unit 2, Pennsylvania 05000388
 AUTH. NAME AUTHOR AFFILIATION
 KEISER, H.W. Pennsylvania Power & Light Co.
 RECIP. NAME RECIPIENT AFFILIATION
 MARTIN, T.T. Region 1 (Post 820201)

SUBJECT: Submits final response to GL 89-13, "Svc Water Sys Problems Affecting Safety-Related Equipment." Installation of corrosion rate probes in emergency svc water/RHR svc water piping at selected locations completed. R
I
D

DISTRIBUTION CODE: A065D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 2
 TITLE: Generic Ltr 89-13 - Svc Water Sys Problems Affecting Safety-Related S

NOTES: Maxwell, G 05000387
 Maxwell, G 05000388

	RECIPIENT ID CODE/NAME	COPIES LTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTR ENCL	
	RALEIGH, J.	1			
INTERNAL:	CHU, A NRR/PD1-3	1	NRR/DET/SELB	1	
	NRR/DRIS	1	NRR/DST/SPLB	1	
	NRR/RSIB	1	<u>REG FILE</u>	1	
EXTERNAL:	NRC PDR	1	NSIC	1	
NOTES:		1			

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK. ROOM P1-37 (EXT. 504-2065) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR 10 ENCL ~~10~~⁰

MAY

THE UNIVERSITY OF CHICAGO

1954



Pennsylvania Power & Light Company

Two North Ninth Street • Allentown, PA 18101-1179 • 215/774-5151

Harold W. Keiser
Senior Vice President-Nuclear
215/774-4194

OCT 0 1 1992

Mr. Thomas T. Martin
Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

**SUSQUEHANNA STEAM ELECTRIC STATION
FINAL RESPONSE TO GENERIC LETTER 89-13
PLA-3845**

Docket Nos. 50-387
and 50-388

FILE R41-2

- Reference:*
1. Letter, PLA-3349, H.W. Keiser to W.T. Russell, "Response to Generic Letter 89-13", dated February 23, 1990.
 2. Letter, PLA-3377, H.W. Keiser to T.T. Martin, "Supplemental Response to Generic Letter 89-13", dated April 27, 1990.
 3. Letter, PLA-3489, H.W. Keiser to T.T. Martin, "12/90 Confirmatory Response to Generic Letter 89-13", dated December 14, 1990.
 4. Letter, PLA-3585, "H.W. Keiser to T.T. Martin, "6/91 Confirmatory Response to Generic Letter 89-13 Piping Inspection Program", dated June 4, 1991.
 5. Letter, PLA-3645, H.W. Keiser to T.T. Martin, "Delayed Implementation of Generic Letter 89-13 Commitment to Install Corrosion Rate Monitors", dated September 9, 1991.
 6. Letter, PLA-3776, "H.W. Keiser to T.T. Martin, "5/92 Confirmatory Response to Generic Letter 89-13," dated June 11, 1992.

Dear Mr. Martin:

This letter serves as our final response to Generic Letter 89-13, "Service Water System Problems Affecting Safety-Related Equipment". PP&L committed to have several testing and installation activities complete by the end of the Unit 1 sixth refueling and inspection outage, which ended in mid-May 1992 for Unit 1 and by the end of the Unit 2 fifth refueling and inspection outage currently scheduled to end in late November 1992 for Unit 2. In response to the Generic Letter requirement for a submittal within 30 days confirming that each of the activities were completed, please be advised of the following status for Recommended Action III of the Generic Letter:

050030

9210060336	921001
PDR	ADOCK 05000387
P	PDR

AD65
1/0

Mr. T.T. Martin
FILE R41-2 PLA-3845

ITEM: PP&L will install corrosion rate monitoring probes in the emergency service water/residual heat removal service water piping at selected locations to provide instantaneous measurement of corrosion rates and their response to changes in water purity or other environmental conditions.

STATUS: Complete for Unit 1 and Unit 2.

This last action completes the implementation of all our commitments made in regard to Generic Letter 89-13 as documented in the references cited above.

Please direct any questions regarding this submittal to Mr. J.B. Wesner at (215) 774-7911.

Very truly yours,



H. W. Keiser

cc: NRC Document Control Desk (original)
NRC Region I
Mr. G. S. Barber - NRC Sr. Resident Inspector, SSES
Mr. J. J. Raleigh - NRC Project Manager, OWFN