

COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL RESOURCES

P.O. Box 2063  
Harrisburg, PA 17120

August 27, 1992

Radiation Protection

(717) 787-2163

Mr. Richard W. Cooper, Director  
Division of Radiation Safety and  
Safeguards  
U.S. Nuclear Regulatory Commission  
Region I  
475 Allendale Road  
King of Prussia, PA 19406

Gentlemen:

Subject: Pennsylvania LLRW Shipment Inspection  
Report Nos. 50-387/PA-92-01; 50-388/PA-92-01

On August 12, 1992, our engineer Mr. David E. Ney, performed an inspection of LLRW liner no. 92-29 at the Susquehanna Steam Electric Station. A copy of the inspection report no. 50-387/PA-92-01; 50-388/PA-92-01 is enclosed with this letter. This report is being forwarded to you for docketing, distribution, and any other action you may deem necessary. This inspection was conducted under the provisions of a Memorandum of Understanding between the Commonwealth of Pennsylvania and the Nuclear Regulatory Commission (NRC). A copy of this letter and our inspection report is being forwarded to the Pennsylvania Power and Light Company for their information.

Within the scope of this inspection, no violations or deviations were noted. However, a concern was identified pertaining to the calculated contact dose of the radwaste liner and the measured contact dose which did not fall within the established acceptance criteria.

Your cooperation with our staff and the Commonwealth of Pennsylvania is appreciated.

Sincerely,

*William P. Dornsife*  
William P. Dornsife, Director  
Bureau of Radiation Protection

Enclosure

cc: Pennsylvania Power and Light Company

9210190005 920927  
PDR ADDOCK 05000387  
G PDR

Recycled Paper

