

ACCELERATED DOCUMENT DISTRIBUTION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9303020481 DOC. DATE: 93/02/22 NOTARIZED: NO DOCKET #
 FACIL: 50-387 Susquehanna Steam Electric Station, Unit 1, Pennsylvania 05000387
 50-388 Susquehanna Steam Electric Station, Unit 2, Pennsylvania 05000388
 AUTH. NAME AUTHOR AFFILIATION
 KEISER, H.W. Pennsylvania Power & Light Co.
 RECIP. NAME RECIPIENT AFFILIATION
 MILLER, C.L. Project Directorate I-2

SUBJECT: Amends 880810 response to GL 88-01. Listed TS changes will be submitted following NRC approval of BWR Owners Group proposed allowed outage time. Util opposed requirement to decrease unidentified leakage limit.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 2
 TITLE: OR Submittal: General Distribution

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTR	ENCL	RECIPIENT ID CODE/NAME	COPIES LTR	ENCL
	PDI-2 LA	1	1	PDI-2 PD	1	1
	CLARK, R	2	2			
INTERNAL:	ACRS	6	6	NRR/DE/EELB	1	1
	NRR/DORS/OTSB	1	1	NRR/DRCH/HICB	1	1
	NRR/DSSA/SRXB	1	1	NUDOCS-ABSTRACT	1	1
	OC/LFMB	1	0	OGC/HDS2	1	0
	<u>REG FILE</u> 01	1	1			
EXTERNAL:	NRC PDR	1	1	NSIC	1	1

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM P1-37 (EXT. 504-2065) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR 20 ENCL 18 ⁰

MAF

R
I
D
S
/
A
D
D
S
/
A
D
D
S



Pennsylvania Power & Light Company

Two North Ninth Street • Allentown, PA 18101-1179 • 215/774-5151

Harold W. Keiser
Senior Vice President-Nuclear
215/774-4194

FEB 22 1993

Director of Nuclear Reactor Regulation
Attention: Mr. C.L. Miller, Project Director
Project Directorate I-2
Division of Reactor Projects
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

SUSQUEHANNA STEAM ELECTRIC STATION
AMENDED RESPONSE TO GENERIC LETTER 88-01
PLA-3917 **FILE R41-2**

Docket Nos. 50-387
& 50-388

Reference: PLA-3060, H. W. Keiser to USNRC, "Response to Generic Letter 88-01", dated August 10, 1988.

Dear Mr. Miller:

The purpose of this letter is to amend Pennsylvania Power and Light (PP&L) Company's response to the required actions of Generic Letter 88-01. PP&L has opposed the requirement to decrease the unidentified leakage limit based on the current limit being adequate and has followed the NRC suggestion to bring this issue to the BWR Owners' Group attention for generic consideration. That effort has resulted in no reduction in the allowable unidentified leakage limit and an investigation into extending the allowable time prior to initiating a plant shutdown. PP&L has been actively participating in these activities and is now agreeing to amend the applicable Technical Specifications (TS). However, in an effort to minimize resource impact, these TS changes will be submitted following NRC approval of the BWROG proposed allowed outage time.

At that time, PP&L will amend the following TS sections:

LCO 3.4.3.2.e. 2 gpm increase in UNIDENTIFIED LEAKAGE will be expanded to be within any 24-hour period.

ACTION 3.4.3.2.e. "With any reactor ... within 4-hour period ..." time period will be increased to reflect the allowed outage time approved by the NRC based on the BWROG proposal.

SR 4.0.5. section f will be added to identify that the Inservice Inspection Program will be performed in accordance with the Staff position in GL 88-01 on schedule, methods and personnel, and sample expansion.

020107

9303020481 930222
PDR ADDCK 05000387
P PDR

A001
1/0



12

1981

1981

This information is being provided to assist in the closure of this long standing activity. Questions regarding this amended response should be directed to Mr. A. K. Maron at (215) 774-7852.

Very truly yours,



H. W. Keiser

cc: NRC Document Control Desk (original)
NRC Region I
Mr. G. S. Barber, NRC Sr. Resident Inspector
Mr. R. J. Clark, NRC Sr. Project Manager



Handwritten marks and scribbles in the top right corner.

Faint, illegible handwritten marks on the left side.

A single line of extremely faint, illegible text centered horizontally.

Faint handwritten marks at the bottom right.