

# ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

## REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION-NBR: 9401060019      DOC.DATE: 93/12/22      NOTARIZED: NO      DOCKET #  
 FACIL: 50-388 Susquehanna Steam Electric Station, Unit 2, Pennsylv      05000388  
 AUTH.NAME      AUTHOR AFFILIATION  
 BYRAM, R.G.      Pennsylvania Power & Light Co.  
 RECIP.NAME      RECIPIENT AFFILIATION  
 MILLER, C.L.      Project Directorate I-2

SUBJECT: informs that valve, HV-25703, repaired & successfully leak rate tested during forced outage of Unit 2. Util 930914 requested for amend to TS no longer needed & hereby withdrawn.

DISTRIBUTION CODE: A001D      COPIES RECEIVED: LTR 1 ENCL 0      SIZE: 1/4  
 TITLE: OR Submittal: General Distribution

NOTES:

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID CODE/NAME		LTR	ENCL		ID CODE/NAME		LTR	ENCL
	PD1-2 LA		1	1		PD1-2 PD		1	1
	CLARK, R		2	2					
INTERNAL:	ACRS		6	6		NRR/DE/EELB		1	1
	NRR/DORS/OTSB		1	1		NRR/DRCH/HICB		1	1
	NRR/DRPW		1	1		NRR/DSSA/SPLB		1	1
	NRR/DSSA/SRXB		1	1		NUDOCS-ABSTRACT		1	1
	OC/LEDCEB		1	0		OGC/HDS2		1	0
	<del>REG-FILE</del> 01		1	1					
EXTERNAL:	NRC PDR		1	1		NSIC		1	1

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK, ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR 22 ENCL 20 <sup>D</sup>

AA4

R  
I  
D  
S  
/  
A  
D  
S  
  
R  
I  
D  
S  
/  
A  
D  
D  
S



**Pennsylvania Power & Light Company**

Two North Ninth Street • Allentown, PA 18101-1179 • 215/774-5151

Robert G. Byram  
Senior Vice President-Nuclear  
215/774-7502

DEC 22 1993

Director of Nuclear Reactor Regulation  
Attention: Mr. C. L. Miller, Project Director  
Project Directorate I-2  
Division of Reactor Projects  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

**SUSQUEHANNA STEAM ELECTRIC STATION  
WITHDRAWAL OF PROPOSED AMENDMENT  
NO. 115 TO LICENSE NO. NPF-22  
PLA-4066 • FILES A17-2/R41-2**

Docket No. 50-388

*Reference: PLA-4022, R.G. Byram to C.L. Miller, "Proposed Amendment No. 115 to License No. NPF-22: Emergency Request Related to Inoperable Purge Valve," dated September 14, 1993.*

Dear Mr. Miller:

Via the referenced letter, PP&L proposed changes to the Susquehanna SES Unit 2 Technical Specifications in order to support continued operation with an inoperable containment purge valve. That valve, HV-25703, has been repaired and successfully leak rate tested during the ongoing forced outage of Unit 2.


Therefore, the referenced request is no longer needed, and PP&L hereby withdraws it from further consideration. Any questions on this request should be directed to Mr. R.R. Sgarro at (215) 774-7914.

Very truly yours,

R. G. Byram

- cc: NRC Document Control Desk (original)
- NRC Region I
- Mr. G. S. Barber, NRC Sr. Resident Inspector - SSES
- Mr. R. J. Clark, NRC Sr. Project Manager - Rockville
- Mr. W. P. Dornsife, Pa DER

9401060019 931222  
PDR ADOCK 05000388  
P PDR



*Acc 1/0*