

PRIORITY 1
(ACCELERATED RIDS PROCESSING)

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9407150123 DOC. DATE: 94/07/11 NOTARIZED: NO DOCKET #
 FACIL: 50-387 Susquehanna Steam Electric Station, Unit 1, Pennsylv 05000387
 50-388 Susquehanna Steam Electric Station, Unit 2, Pennsylv 05000388
 AUTH. NAME AUTHOR AFFILIATION
 BYRAM, R.G. Pennsylvania Power & Light Co.
 RECIPIENT NAME RECIPIENT AFFILIATION
 MILLER, C.L. Project Directorate I-2

SUBJECT: Provides update to Generic Ltr 89-10 completion plan.
 Attachments B, C & D (originally provided in 940429 ltr)
 revised to include RCIC valve being tested after 940628 &
 RWCU return isolation valves being reclassified.

DISTRIBUTION CODE: A064D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 14
 TITLE: Response to Generic Ltr 89-10, "Safety-Related MOV Testing & Surveill

NOTES:

| | RECIPIENT ID CODE/NAME | COPIES LTTR ENCL | RECIPIENT ID CODE/NAME | COPIES LTTR ENCL |
|-----------|---------------------------|---------------------|---------------------------|---------------------|
| | PD1-2 PD | 1 1 | POSLUSNY, C. | 1 1 |
| INTERNAL: | ACRS | 1 1 | AEOD/DSP/ROAB | 1 1 |
| | AEOD/DSP/TPAB | 1 1 | NRR/DE/EMEB | 1 1 |
| | NRR/DRIL/RPEB | 1 1 | NRR/DRPW/OGCB | 1 1 |
| | NRR/PD111-3 | 1 1 | REG FILE 01 | 1 1 |
| | RES/DSIR | 1 1 | RES/DSIR/EIB/B | 1 1 |
| EXTERNAL: | NRC PDR | 1 1 | NSIC | 1 1 |

NOTE TO ALL "RIDS" RECIPIENTS:


PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL
 DESK, ROOM P1-37 (EXT. 504-2083) TO ELIMINATE YOUR NAME FROM
 DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 14 ENCL 14

P
R
I
O
R
I
T
Y

1

D
O
C
U
M
E
N
T





Pennsylvania Power & Light Company

Two North Ninth Street • Allentown, PA 18101-1179 • 610/774-5151

Robert G. Byram
Senior Vice President—Nuclear
610/774-7502
Fax: 610/774-5019

JUL 11 1994

Director of Nuclear Reactor Regulation
Attn: Mr. C. L. Miller, Project Director
Project Directorate I-2
Division of Reactor Projects
U.S. Nuclear Regulatory Commission
Washington, DC 20555

**SUSQUEHANNA STEAM ELECTRIC STATION
UPDATE TO THE GENERIC LETTER 89-10
COMPLETION PLAN
PLA-4163**

FILE R41-2

Docket Nos. 50-387
and 50-388

*Reference: Letter PLA-4124, 'Revision to Generic Letter 89-10 Completion Plan,' dated April 29, 1994,
from R.G. Byram (PP&L) to C.L. Miller (NRC)*

Dear Mr. Miller:

The purpose of this letter is to provide the staff with an update to our Generic Letter 89-10 completion plan. We have determined that the dynamic testing for the RCIC pump minimum flow bypass valve (HV149F019) on Unit 1 will not be completed by June 28, 1994, along with revisions to our valve groupings.

The RCIC pump minimum flow bypass valve is normally closed and will open under a low flow condition, and reclose when flow is greater than the minimum flow setpoint. The safety function is to open to provide minimum flow to the RCIC pump, to close to ensure that sufficient RCIC flow is sent to the reactor pressure vessel, and to provide containment isolation.

This valve and its counterpart on Unit 2 were statically tested during their respective refueling outages. As these are rising-rotating valves, both thrust and torque data were taken to fully characterize the valve response. The difficulty in obtaining and analyzing test data in the static condition requires further refinement of the techniques prior to attempting to perform a dynamic test. The rising-rotating design coupled with being a globe valve presents additional challenges. Since this is a local leak rate tested valve on a safety system that can only be tested with the unit at 100% power while in an LCO, it is required that the evolution be well planned and executed to

7 400
9407150123 940711
PDR ADOCK 05000387
P PDR

AD64



1991 1 10

minimize out of service time and not jeopardize the operation of the unit. Because of the complexity of this test, other scheduled dynamic testing (10 dynamic tests) and Unit 2 in a power uprate ascension program, the test has been rescheduled to a work window prior to the end of the 4th quarter of 1994. The static test results have indicated an acceptable margin to indicate the valve is operable under all defined design basis condition. Deferral of this testing also defers the similarity analysis for the Unit 2 valve.

In reviewing our program, we determined that the RWCU return isolation valves should have been classified as valves having zero differential pressure and not classified as non-testable valves. This reclassification does not change the number of dynamic tests to be performed.

The above changes have been reflected in the following revised table which was originally provided in the above referenced letter.

| GROUP | OPERABILITY ASSESSMENT | TOTAL | AFTER 6/28/94 |
|--|------------------------|-------|------------------|
| In-Situ Dynamic Tests w/Diags. | Test | 37 | 10 (Notes 3 & 5) |
| w/o Diags. | Test | 8 | 4 (Notes 3 & 5) |
| Diff. Press. = 0 | Note 1 | 20 | |
| Excessive Margins | Note 1 | 12 | |
| Globes - Flow under Seat and Open Only Safety Function | Note 1 | 2 | |
| Similarity to In-Situ Tested Valve | Similarity Analysis | 7 | 1 (Note 5) |
| NON-TESTABLES | Note 2 | 84 | 84 (Notes 4 & 5) |
| TOTAL | | 170 | |
| Note 1: Static test sufficient to determine operability. Note 2: Non-Testables rely on either EPRI tests and EPRI methodology or engineering analysis to assess operability. Note 3: Physical description contained in Attachment B. Note 4: Physical description contained in Attachment C. Note 5: Safety function description provided in Attachment D. | | | |


Attachments B, C, and D (Originally provided in PLA-4124) have been revised to include the RCIC valve being tested after June 28, 1994, and the RWCU return isolation valves being reclassified as valves having zero differential flow.

The extended length of the Unit 2 Sixth Refueling Outage has delayed the planned post outage dynamic tests until late June. Although the dynamic tests will be completed prior to or close to June 28, 1994, the associated closure packages (i.e., functionality assessments) for valves tested in June will not be completed until 7/31/94.



If you have any questions or comments, please contact Mr. C.T. Coddington at (610) 774-7915.

Very truly yours,



R. G. Byram

Attachments

cc: ~~NRC Document Control Desk (original)~~
NRC Region I
Mr. G. S. Barber, NRC Sr. Resident Inspector - SSES
Mr. C. Poslusny, Jr., NRC Sr. Project Manager - Rockville

1000

ATTACHMENT B**RISING STEM VALVES SET-UP OR HAVE STATIC RETEST AFTER 6/94**

| VALVE TAG # | SYSTEM | TYPE | SIZE | SAFETY FUNCTION | RISK PRIORITY | MAXIMUM DP (PSID)* | MAXIMUM FLOW (GPM)* |
|-------------|--------|------|------|-----------------|---------------|--------------------|---------------------|
| HV-151F007A | RHR | GT | 6 | O/C | 3 | 498 | 2000 |
| HV-151F009 | RHR | GT | 20 | C | 3 | 126 | 24721 |
| HV-151F023 | RHR | GB | 6 | C | 3 | 404 | 500 |

RISING STEM VALVES WITH DYNAMIC TEST AFTER 6/94

| VALVE TAG # | SYSTEM | TYPE | SIZE | SAFETY FUNCTION | RISK PRIORITY | MAXIMUM DP (PSID)* | MAXIMUM FLOW (GPM)* |
|-------------|--------|------|------|-----------------|---------------|--------------------|---------------------|
| HV-149F007 | RCIC | GT | 4 | C | 3 | 1175 | 87900 |
| HV-149F008 | RCIC | GT | 4 | C | 3 | 1175 | 87900 |
| HV-149F019 | RCIC | R/R | 2 | O/C | 3 | 1335 | 75 |
| HV-152F005A | CS | GT | 12 | O/C | 3 | 371 | 7900 |
| HV-155F001 | HPCI | GT | 10 | O | 1 | 1187 | 220000** |
| HV-155F002 | HPCI | GT | 10 | C | 1 | 1175 | 672000** |
| HV-155F003 | HPCI | GT | 10 | C | 1 | 1175 | 672000** |
| HV-212F073A | RHRSW | GT | 6 | O | 2 | 165 | 5000 |
| HV-212F073B | RHRSW | GT | 6 | O | 2 | 165 | 5000 |
| HV-249F007 | RCIC | GT | 4 | C | 3 | 1175 | 87900 |
| HV-249F008 | RCIC | GT | 4 | C | 3 | 1175 | 87900 |
| HV-255F002 | HPCI | GT | 10 | C | 1 | 1175 | 672000** |
| HV-255F003 | HPCI | GT | 10 | C | 1 | 1175 | 672000** |
| HV-255F012 | HPCI | GT | 4 | O/C | 1 | 1474 | 500 |

RISK PRIORITY SCHEME

| PRIORITY | DEFINITION |
|----------|---|
| 1 | Causes the loss of a safety function |
| 2 | Causes loss of 1 of 2 systems used for a safety function. |
| 3 | Not 1 or 2, but within Generic Letter 89-10 scope. |


* Worst Case

** lbs/hr steam flow



ATTACHMENT C

| NON-TESTABLE VALVES | | | | | | | |
|---------------------|--------|------------|------------|-----------------|---------------|--------------------|---------------------|
| VALVE TAG NUMBE | SYSTEM | VALVE TYPE | VALVE SIZE | SAFETY FUNCTION | RISK PRIORITY | MAXIMUM DP (PSIG)* | MAXIMUM FLOW (GPM)* |
| HV 112F075A | RHRSW | GT | 6 | O | 2 | 33.3 | 0 |
| HV 112F075B | RHRSW | GT | 6 | O | 2 | 33.3 | 0 |
| HV 11313 | RBCCW | GT | 4 | C | 3 | 91 | 128 |
| HV 11314 | RBCCW | GT | 4 | C | 3 | 91 | 128 |
| HV 11345 | RBCCW | GT | 4 | C | 3 | 91 | 128 |
| HV 11346 | RBCCW | GT | 4 | C | 3 | 91 | 128 |
| HV 12603 | CIG | GB | 2 | C | 3 | 60 | 40 |
| HV 143F031A | Recirc | GT | 28 | C | 2 | 200 | 19500 |
| HV 143F031B | Recirc | GT | 28 | C | 2 | 200 | 19500 |
| HV 143F032A | Recirc | GT | 4 | C | 3 | 1066 | 591 |
| HV 143F032B | Recirc | GT | 4 | C | 3 | 1066 | 591 |
| HV 144F001 | RWCU | GT | 6 | C | 3 | 1083 | 436 |
| HV 144F004 | RWCU | GT | 6 | C | 3 | 1083 | 436 |
| HV 149F010 | RCIC | GT | 6 | O/C | 3 | 29 | 0 |
| HV 149F013 | RCIC | GT | 6 | O/C | 3 | 1220 | 600 |
| HV 149F031 | RCIC | GT | 6 | O/C | 3 | 36 | 600 |
| HV 149F059 | RCIC | GT | 10 | C | 3 | 16 | 0 |
| HV 149F060 | RCIC | GB | 2 | C | 3 | 16 | 0 |
| HV 151F004A | RHR | GT | 24 | O/C | 3 | 41 | 100 |
| HV 151F004B | RHR | GT | 24 | O/C | 3 | 41 | 100 |
| HV 151F004C | RHR | GT | 24 | O/C | 3 | 41 | 100 |
| HV 151F004D | RHR | GT | 24 | O/C | 3 | 41 | 100 |
| HV 151F008 | RHR | GT | 20 | C | 3 | 1070 | 24721 |
| HV 151F009 | RHR | GT | 20 | C | 3 | 126 | 24721 |
| HV 151F015A | RHR | GT | 24 | O/C | 2 | 359 | 21300 |
| HV 151F015B | RHR | GT | 24 | O/C | 2 | 359 | 21300 |
| HV 151F016A | RHR | GB | 12 | O/C | 2 | 316 | 10000 |
| HV 151F016B | RHR | GB | 12 | O/C | 2 | 316 | 10000 |
| HV 151F017A | RHR | DG | 20 | O/C | 2 | 478 | 21300 |
| HV 151F017B | RHR | DG | 20 | O/C | 2 | 478 | 21300 |
| HV 151F021A | RHR | GT | 12 | O/C | 2 | 305 | 9500 |
| HV 151F021B | RHR | GT | 12 | O/C | 2 | 305 | 9500 |
| HV 151F027A | RHR | GB | 6 | O/C | 3 | 340 | 750 |
| HV 151F027B | RHR | GB | 6 | O/C | 3 | 340 | 750 |
| HV 152F001A | CS | GT | 16 | C | 3 | 23 | 100 |
| HV 152F001B | CS | GT | 16 | C | 3 | 23 | 100 |
| HV 155F004 | HPCI | GT | 16 | O/C | 3 | 33 | 5000 |
| HV 155F006 | HPCI | GT | 14 | O/C | 1 | 1223 | 5000 |
| HV 155F042 | HPCI | GT | 16 | O/C | 3 | 41 | 5000 |
| HV 155F066 | HPCI | GT | 20 | C | 1 | 16 | 0 |



ATTACHMENT C (continued)

| VALVE TAG NUMBER | SYSTEM | VALVE TYPE | VALVE SIZE | SAFETY FUNCTION | RISK PRIORITY | MAXIMUM DP (PSIG)* | MAXIMUM FLOW (GPM)* |
|------------------|--------|------------|------------|-----------------|---------------|--------------------|---------------------|
| HV 15766 | SPCU | GT | 6 | C | 3 | 50 | 295 |
| HV 15768 | SPCU | GT | 6 | C | 3 | 50 | 295 |
| HV 212F075A | RHRSW | GT | 6 | O | 2 | 33.3 | 0 |
| HV 212F075B | RHRSW | GT | 6 | O | 2 | 33.3 | 0 |
| HV 21313 | RBCCW | GT | 4 | C | 3 | 91 | 128 |
| HV 21314 | RBCCW | GT | 4 | C | 3 | 91 | 128 |
| HV 21345 | RBCCW | GT | 4 | C | 3 | 91 | 128 |
| HV 21346 | RBCCW | GT | 4 | C | 3 | 91 | 128 |
| HV 22603 | CIG | GB | 2 | C | 3 | 60 | 40 |
| HV 243F031A | Recirc | GT | 28 | C | 2 | 200 | 19500 |
| HV 243F031B | Recirc | GT | 28 | C | 2 | 200 | 19500 |
| HV 243F032A | Recirc | GT | 4 | C | 3 | 1066 | 591 |
| HV 243F032B | Recirc | GT | 4 | C | 3 | 1066 | 591 |
| HV 244F001 | RWCU | GT | 6 | C | 3 | 1083 | 436 |
| HV 244F004 | RWCU | GT | 6 | C | 3 | 1083 | 436 |
| HV 249F010 | RCIC | GT | 6 | O/C | 3 | 29 | 0 |
| HV 249F013 | RCIC | GT | 6 | O/C | 3 | 1220 | 600 |
| HV 249F031 | RCIC | GT | 6 | O/C | 3 | 36 | 600 |
| HV 249F059 | RCIC | GT | 10 | C | 3 | 16 | 0 |
| HV 249F060 | RCIC | GB | 2 | C | 3 | 16 | 0 |
| HV 251F004A | RHR | GT | 24 | O/C | 3 | 41 | 100 |
| HV 251F004B | RHR | GT | 24 | O/C | 3 | 41 | 100 |
| HV 251F004C | RHR | GT | 24 | O/C | 3 | 41 | 100 |
| HV 251F004D | RHR | GT | 24 | O/C | 3 | 41 | 100 |
| HV 251F008 | RHR | GT | 20 | C | 3 | 1070 | 24721 |
| HV 251F009 | RHR | GT | 20 | C | 3 | 126 | 24721 |
| HV 251F015A | RHR | GT | 24 | O/C | 2 | 359 | 21300 |
| HV 251F015B | RHR | GT | 24 | O/C | 2 | 359 | 21300 |
| HV 251F016A | RHR | GB | 12 | O/C | 2 | 316 | 10000 |
| HV 251F016B | RHR | GB | 12 | O/C | 2 | 316 | 10000 |
| HV 251F017A | RHR | DG | 20 | O/C | 2 | 478 | 21300 |
| HV 251F017B | RHR | DG | 20 | O/C | 2 | 478 | 21300 |
| HV 251F021A | RHR | GT | 12 | O/C | 2 | 305 | 9500 |
| HV 251F021B | RHR | GT | 12 | O/C | 2 | 305 | 9500 |
| HV 251F027A | RHR | GB | 6 | O/C | 3 | 340 | 750 |
| HV 251F027B | RHR | GB | 6 | O/C | 3 | 340 | 750 |
| HV 252F001A | CS | GT | 16 | C | 3 | 23 | 100 |
| HV 252F001B | CS | GT | 16 | C | 3 | 23 | 100 |
| HV 255F004 | HPCI | GT | 16 | O/C | 3 | 33 | 5000 |
| HV 255F006 | HPCI | GT | 14 | O/C | 1 | 1223 | 5000 |
| HV 255F042 | HPCI | GT | 16 | O/C | 3 | 41 | 5000 |
| HV 255F066 | HPCI | GT | 20 | C | 1 | 16 | 0 |
| HV 25766 | SPCU | GT | 6 | C | 3 | 50 | 295 |
| HV 25768 | SPCU | GT | 6 | C | 3 | 50 | 295 |

* Worst case



ATTACHMENT DSAFETY FUNCTION DESCRIPTIONS

HV-212F073A
HV-212F073B

These valves are the RHR/RHRSW cross-tie valves. These valves are normally closed and their safety function is to open to provide a flowpath from the RHRSW system to the RPV or containment, via the RHR system, for RPV/containment flooding or suppression pool make-up.

HV-112F075A
HV-112F075B
HV-212F075A
HV-212F075B

These valves are the RHR/RHRSW cross-tie valves. These valves are normally closed and their safety function is to open to provide a flowpath from the RHRSW system to the RPV or containment, via the RHR system, for RPV/containment flooding or suppression pool make-up.

HV-11313
HV-11314
HV-11345
HV-11346
HV-21313
HV-21314
HV-21345
HV-21346

These valves are containment isolation valves for the RBCCW to the reactor recirculation pump seal and motor oil coolers. These valves' safety function is to close for containment isolation on a high drywell pressure or low reactor level 1 signal.

HV-12603
HV-22603

These valves are the Containment Instrument Gas compressor suction inboard containment isolation valves. These valves are normally open to provide a suction path for the containment instrument gas compressors. The valves' safety function is to close on a containment isolation signal.

HV-143F031A
 HV-143F031B
 HV-243F031A
 HV-243F031B

These valves are the reactor recirculation pump discharge valves. These valves are normally open to provide a discharge path for the recirculation system. The safety function of these valves is to close on a LOCA plus low reactor pressure signal, to assure the proper alignment for LPCI injection.

HV-143F032A
 HV-143F032B
 HV-243F032A
 HV-243F032B

These valves are the reactor recirculation pump discharge bypass valves. These valves are normally open and provide a discharge path for the recirculation system during pump start-up. The safety function of these valves is to close on a LOCA plus low reactor pressure signal, to assure the proper alignment for LPCI injection.

HV-144F001
 HV-244F001

These valves are the RWCU inboard containment isolation valves. These valves are normally open and their safety function is to close on a reactor low level signal or on indication of a RWCU system break from the steam leak detection system.

HV-144F004
 HV-244F004

These valves are the RWCU outboard containment isolation valves. These valves are normally open and their safety function is to close on a reactor low level signal, on indication of a RWCU system break from the steam leak detection system, on initiation of Standby Liquid Control system, and on RWCU nonregenerative heat exchanger high outlet temperature.

HV-149F007
 HV-149F008
 HV-249F007
 HV-249F008

These valves are the RCIC steam supply line to the RCIC turbine containment isolation valves. These valves are normally open for RCIC operation and their safety function is to close for containment isolation when RCIC is not operating.

HV-149F010
HV-249F010

These valves are the RCIC suction valves from the condensate storage tank and are normally open. These valves' safety function is to close on suction transfer from the CST to the suppression pool.

HV-149F013
HV-249F013

These valves are the RCIC injection shutoff containment isolation valves. These valves are normally closed and their safety function is to open on RCIC initiation, and to close for containment isolation when RCIC is not operating.

HV-149F019
HV-249F019

These valves are the RCIC minimum flow bypass valves. These valves are normally closed. The safety function is to open to provide minimum flow to the RCIC pump, to close to ensure that sufficient RCIC flow is sent to the reactor pressure vessel, and to provide containment isolation.

HV-149F031
HV-249F031

These valves are the RCIC suppression pool suction containment isolation valves. These valves are normally closed and will open on low level conditions in the CST. The valves' safety function is to open on automatic RCIC suction transfer from CST to suppression pool, and to remote manually close for containment isolation.

HV-149F059
HV-249F059

These valves are the containment isolation valves on the RCIC turbine exhaust to the suppression pool. These valves are normally open and their safety function is to remote manually close if required to provide long term containment isolation.

HV-149F060
HV-249F060

These valves are the RCIC barometric condenser vacuum pump discharge to the suppression pool containment isolation valves. These valves are normally open and their safety function is to perform a manual containment isolation function.

HV-151F004A
HV-151F004B
HV-151F004C
HV-151F004D
HV-251F004A
HV-251F004B
HV-251F004C
HV-251F004D

These valves are the RHR suppression pool suction manual containment isolation valves. These valves are normally open to provide a suction path for LPCI and their safety function is to remote manually close to provide long term containment isolation.

HV-151F007A

This valve is the RHR pump minimum flow bypass valve. This valve is normally closed and its safety function is to open to prevent damage to the pumps during low flow condition and to close when sufficient flow exists to assure maximum LPCI flow to the vessel.

HV-151F008
HV-251F008

These valves are the shutdown cooling supply outboard containment isolation valves. These valves are normally closed and are opened for shutdown cooling mode of RHR. The safety function of these valves is to close on a shutdown cooling isolation signal.

HV-151F009
HV-251F009

These valves are the shutdown cooling supply inboard containment isolation valves. These valves are normally closed and are opened for shutdown cooling mode of RHR. The safety function of these valves is to close on a shutdown cooling isolation signal.



HV-151F015A
 HV-151F015B
 HV-251F015A
 HV-251F015B

These valves are the RHR injection inboard containment isolation valves. These valves are normally closed and their safety function is to open on LPCI initiation during LOCA, and to close on low level 3 when in shutdown cooling.

HV-151F016A
 HV-151F016B
 HV-251F016A
 HV-251F016B

These valves are the drywell spray header outboard containment isolation valves. These valves are normally closed. The safety function of these valves is to open for containment spray and to close for containment isolation.

HV-151F017A
 HV-151F017B
 HV-251F017A
 HV-251F017B

These valves are the RHR outboard injection control valves. These valves are normally open and their safety function is to open and close as required to control injection flow during LPCI and containment cooling modes of RHR.

HV-151F021A
 HV-151F021B
 HV-251F021A
 HV-251F021B

These valves are the drywell spray header inboard containment isolation valves. These valves are normally closed. The safety function of these valves is to open for containment spray and to subsequently close for containment isolation.

HV-151F023

This valve is the RHR head spray outboard containment isolation valve. This valve is normally closed and its safety function is to close, if open, on a reactor low level 3, RHR isolation, High Drywell pressure, or reactor pressure greater than allowable for shutdown cooling.

HV-151F027A
 HV-151F027B
 HV-251F027A
 HV-251F027B

These valves are the suppression chamber spray header inboard containment isolation valves. These valves are normally closed. The safety function of these valves is to open for suppression chamber spray.

HV-152F001A
HV-152F001B
HV-252F001A
HV-252F001B

These valves are the Core Spray suppression pool suction manual containment isolation valves. These valves are normally open to provide a suction path for core spray injection and their safety function is to remote manually close to provide long term containment isolation.

HV-152F005A

This valve is the Core Spray injection inboard containment isolation valve. This valve is normally closed and its safety function is to open on Core Spray initiation and low reactor pressure, and to close to provide containment isolation.

HV-155F001

This valve is the HPCI injection valve. This valve is normally open, and the safety function of this valve is to open on a HPCI injection signal.

HV-155F002
HV-255F002

This valve is the HPCI steam supply line inboard containment isolation valve. This valve is normally open, and the safety function of this valve is to close on a HPCI isolation signal.

HV-155F003
HV-255F003

This valve is the HPCI steam supply line outboard containment isolation valve. This valve is normally open, and the safety function of this valve is to close on a HPCI isolation signal.

HV-155F004
HV-255F004

These valves are the HPCI suction valves from the condensate storage tank and are normally open. These valves' safety function is to automatically close on suction transfer from the CST to the suppression pool.



HV-155F006
HV-255F006

These valves are the HPCI injection shutoff containment isolation valves. These valves are normally closed and their safety function is to open on HPCI initiation, and to close for containment isolation when HPCI is not operating.

HV-255F012

This valve is the HPCI minimum flow bypass valve. This valve is normally closed and will open when HPCI is operating with inadequate flow, and will reclose when adequate HPCI flow is developed. The valves safety function is to open to provide minimum flow to the HPCI pump, and to close to ensure sufficient HPCI flow is sent to the RPV and to also provide containment isolation.

HV-155F042
HV-255F042

These valves are the HPCI suppression pool suction containment isolation valves. These valves are normally closed and will open on low level conditions in the CST or high water level in the suppression pool. The valves' safety function is to open on automatic HPCI suction transfer from CST to suppression pool, and to remote manually close for containment isolation or realignment of HPCI suction to the CST.

HV-155F066
HV-255F066

These valves are the containment isolation valves on the HPCI turbine exhaust to the suppression pool. These valves are normally open and their safety function is to remote manually close if required to provide long term containment isolation.

HV-15766
HV-25766

These valves are the suppression pool cleanup system inboard containment isolation valves. These valves are normally closed and their safety function is to close, if open, on a LOCA signal.

HV-15768
HV-25768

These valves are the suppression pool cleanup system outboard containment isolation valves. These valves are normally closed and their safety function is to close, if open, on a LOCA signal.