

PRIORITY 2

NUDOCS OFFSITE FACILITY
REGULATOR INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9408240039 DOC. DATE: 94/08/15 NOTARIZED: NO DOCKET #
FACIL: 50-387 Susquehanna Steam Electric Station, Unit 1, Pennsylv 05000387
50-388 Susquehanna Steam Electric Station, Unit 2, Pennsylv 05000388
AUTH. NAME AUTHOR AFFILIATION
MODES, M.C. Region 1 (Post 820201)
RECIP. NAME RECIPIENT AFFILIATION
BYRAM, R.G. Pennsylvania Power & Light Co.

SUBJECT: Discusses util request that present requirement of biennial reviews of nuclear plant procedures be reduced & provide certain criteria involving reviews as listed.

DISTRIBUTION CODE: IE43D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 2
TITLE: 50.54.a.3 & 50.55.f.3 Change to SAR QA Program

NOTES: 05000387

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	POSLUSNY, C	1 1		
INTERNAL:	ACRS	6 0	DRS/RGN1	1 1
	DRS/RGN2	1 1	DRS/RGN3	1 1
	DRS/RGN4	1 1	NRR/PMAS/IRCB-E	1 1
	OC/LFDCB	1 0	<u>REG FILE</u> 02	1 1
	RGN1 FILE 01	1 1		
EXTERNAL:	NRC PDR	1 1		
NOTES:		1 1		

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK, ROOM P1-37 (EXT. 504-2083) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 17 ENCL 10

P
R
I
O
R
I
T
Y

2

D
O
C
U
M
E
N
T

DES

Docket Nos. 50-387
50-388

AUG 15 1994

Mr. Robert G. Byram
Senior Vice President - Nuclear
Pennsylvania Power & Light Company
2 North Ninth Street
Allentown, Pennsylvania 18101

Dear Mr. Byram:

SUBJECT: SUSQUEHANNA STEAM ELECTRIC STATION REQUEST FOR
FSAR/QUALITY ASSURANCE APPROVAL

Reference: (a) Letter from R. G. Byram, PP&L, dated July 14, 1994
(b) NRC Memorandum "Biennial Procedure Review and Plant
Procedure Programs," dated December 21, 1992

In Reference (a), Pennsylvania Power & Light Company requested that the present requirement of biennial (every two years) reviews of nuclear plant procedures be reduced, provided certain criteria involving reviews as listed in Reference (b) are followed. These are:

1. All affected procedures shall be reviewed after unusual events;
2. Plant procedures shall be based on total designs;
3. Industry events shall be reviewed;
4. Significant operating occurrence reports, nonconformance reports, and engineering deficiency reports shall be reviewed;
5. Review of existing procedures shall be performed by comparing TS changes with TS amendments;
6. Emergency operating procedures shall be reviewed every two years;
7. QA should review (on a sampling basis) those procedures that are used more frequently than every two years;
8. Routine procedures not used for two years should be removed;
9. Emergency Operating Procedure, Off Normal Procedure, Emergency Preparedness Procedures, and any event-driven procedure shall be reviewed every two years; and
10. Procedures associated with regulatory requirements including Commonwealth of Pennsylvania shall be reviewed every two years.

230032

9408240039 940815
PDR ADOCK 05000387
P PDR

1E 4/3 111

Mr. Robert G. Byram

2

AUG 15 1994

The reviewed procedural review program is approved without comment. Please refer to NRC Region I Tracking No. QA 94-19 in all correspondence.

Sincerely,

Original Signed By:

Michael C. Modes, Chief
Materials Section
Division of Reactor Safety

cc w/encl:

H. G. Stanley, Vice President - Nuclear Operations
J. M. Kenny, Nuclear Licensing
G. T. Jones, Vice President - Nuclear Engineering
M. M. Urioste, Nuclear Services Manager
J. M. Finnegan, Supervisor, Nuclear Compliance
H. D. Woodeshick, Special Office of the President
J. C. Tilton, III, Allegheny Electric Cooperative, Inc.
Public Document Room (PDR)
Local Public Document Room (LPDR)
Nuclear Safety Information Center (NSIC)
K. Abraham, PAO (2)
NRC Resident Inspector
Commonwealth of Pennsylvania

bcc w/encl:

Region I Docket Room (with concurrences)
E. Wenzinger, DRP
K. Gallagher, DRP
W. Dean, OEDO
C. Poslusny, Project Manager, NRR
M. Thadani, PDI-2, NDD
M. Shannon, ILPB
V. Curley, DRS
DRS File (2)
RI:DRS RI:DRS
Kaplan Modes
fjk
08/15/94 08/15/94

OFFICIAL RECORD COPY
A:SUSQA94.19