

**PRIORITY 1**  
(ACCELERATED RIDS PROCESSING)

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9409270316      DOC. DATE: 94/09/21      NOTARIZED: NO      DOCKET #  
 FACIL: 50-387 Susquehanna Steam Electric Station, Unit 1, Pennsylvania      05000387  
 AUTH. NAME      AUTHOR AFFILIATION  
 STANLEY, H.G.      Pennsylvania Power & Light Co.  
 RECIPIENT AFFILIATION  
 RECIP. NAME      Document Control Branch (Document Control Desk)

SUBJECT: Forwards LER 94-014-00, superceding rept attached to 940919 ltr, PLAS-613 due to errors in info block on page 1. Rept being made because condition prohibited by TS existed when continuous fire watches not established within one h.

DISTRIBUTION CODE: IE22T      COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 1+4  
 TITLE: 50.73/50.9 Licensee Event Report (LER), Incident Rpt, etc.

NOTES:

05000387

	RECIPIENT ID CODE/NAME	COPIES LTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTR ENCL
	PD1-2 PD	1 1	POSLUSNY, C	1 1
INTERNAL:	ACRS	1 1	AEOD/ROAB/DSP	2 2
	AEOD/SPD/RRAB	1 1	<u>FILE CENTER 02</u>	1 1
	NRR/DE/EELB	1 1	NRR/DE/EMEB	1 1
	NRR/DORS/OEAB	1 1	NRR/DRCH/HHFB	1 1
	NRR/DRCH/HICB	1 1	NRR/DRCH/HOLB	1 1
	NRR/DRSS/PRPB	2 2	NRR/DSSA/SPLB	1 1
	NRR/DSSA/SRXB	1 1	NRR/PMAS/IRCB-E	1 1
	RES/DSIR/EIB	1 1	RGN1 FILE 01	1 1
EXTERNAL:	EG&G BRYCE, J.H	2 2	L ST LOBBY WARD	1 1
	NOAC MURPHY, G.A	1 1	NOAC POORE, W.	1 1
	NRC PDR	1 1	NUDOCS FULL TXT	1 1
NOTES:		1 1		

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK, ROOM P1-37 (EXT. 504-2083) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

FULL TEXT CONVERSION REQUIRED  
 TOTAL NUMBER OF COPIES REQUIRED: LTR 28 ENCL 28

P  
R  
I  
O  
R  
I  
T  
Y  
  
D  
O  
C  
U  
M  
E  
N  
T



**Pennsylvania Power & Light Company**

Two North Ninth Street • Allentown, PA 18101 • 215 / 770-5151

September 21, 1994

U.S. Nuclear Regulatory Commission  
Document Control Desk  
Washington, DC 20555

SUSQUEHANNA STEAM ELECTRIC STATION  
LICENSEE EVENT REPORT 94-014-00  
FILE R41-2  
PLAS - 614

Docket No. 50-387  
License No. NPF-14

This letter and attached Licensee Event Report 94-014-00 supercedes our letter, PLAS-613 dated September 19, 1994. The report attached to PLAS-613 contained errors in the information blocks on page 1 which occurred during word processing. Please disregard the report which was attached to PLAS-613.

This report is being made pursuant to 10CFR50.73(a)(2)(i)(B), in that a condition prohibited by Technical Specifications existed when continuous fire watches were not established within one hour to meet action statements due to inoperable fire suppression and detection equipment.

  
H.G. Stanley  
VP - Nuclear Operations

HL/mjm

cc: Mr. T. T. Martin  
Regional Administrator, Region I  
U.S. Nuclear Regulatory Commission  
475 Allendale Road  
King of Prussia, PA 19406

Ms. Maitri Banerjee  
Sr. Resident Inspector  
U.S. Nuclear Regulatory Commission  
P.O. Box 35  
Berwick, PA 18603-0035

9409270316 940921  
PDR ADDCK 05000387  
S PDR

*Handwritten initials/signature*

