

PRIORITY 1

(ACCELERATED RIDS PROCESSING)

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS).

ACCESSION NBR: 9508040028 DOC. DATE: 95/08/01 NOTARIZED: NO DOCKET #
 FACIL: 50-387 Susquehanna Steam Electric Station, Unit 1, Pennsylv 05000387
 50-388 Susquehanna Steam Electric Station, Unit 2, Pennsylv 05000388
 AUTH. NAME AUTHOR AFFILIATION
 BYRAM, R.G. Pennsylvania Power, & Light Co.
 RECIPIENT NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Documents telcons between JB Wesner & C Poslusny of 950720
 & 950725 re. inadvertent omission of addl revised page from
 each SSES Unit 1 & 2 TS.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 2+2
 TITLE: OR Submittal: General Distribution

NOTES: 05000387

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID CODE/NAME		LTTR	ENCL		ID CODE/NAME		LTTR	ENCL
	PD1-2 LA		1	1		PD1-2 PD		1	1
	POSLUSNY, C		1	1					
INTERNAL:	ACRS		6	6	<u>FILE CENTER</u> 01			1	1
	NRR/DE/EMCB		1	1	NRR/DRCH/HICB			1	1
	NRR/DSSA/SPLB		1	1	NRR/DSSA/SRXB			1	1
	NUDOCS-ABSTRACT		1	1	OGC/HDS2			1	0
EXTERNAL:	NOAC		1	1	NRC PDR			1	1
NOTES:			1	1					

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL
 DESK, ROOM OWEN 5D8 (415-2083) TO ELIMINATE YOUR NAME FROM
 DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 19 ENCL 18



Pennsylvania Power & Light Company

Two North Ninth Street • Allentown, PA 18101-1179 • 610/774-5151

Robert G. Byram
Senior Vice President-Nuclear
610/774-7502
Fax: 610/774-5019

AUG 01 1995

U.S. Nuclear Regulatory Commission
Attn.: Document Control Desk
Mail Stop P1 - 137
Washington, D.C. 20555

**SUSQUEHANNA STEAM ELECTRIC STATION
PROPOSED CORRECTION TO AMENDMENT ON
CHLORINE DETECTION REQUIREMENTS
PLA-4345 FILE R41-2**

Docket Nos. 50-387
and 50-388

- References:
- 1) PLA-4212 from Mr. R. G. Byram to USNRC, "Proposed Amendment No. 174 to License NPF-14 And Proposed Amendment No. 128 To License NPF-22: Deletion Of Chlorine Detection Requirements And Associated Bases From Technical Specifications," dated October 28, 1995.
 - 2) PLA-4305 from Mr. R. G. Byram to USNRC, "Request For Additional Information On SSES Technical Specification Change Deleting Chlorine Detection System Requirements And Bases," dated April 18, 1995.
 - 3) USNRC to Mr. R. G. Byram, "Amendment No. 147 To Facility Operating License NPF-14, Amendment No. 117 To Facility Operating License NPF-22, And Safety Evaluation," dated June 19, 1995.

This letter documents the telephone conversations between our Mr. J. B. Wesner and NRC's Mr. C. Poslusny of July 20, 1995 and July 25, 1995 regarding the inadvertent omission of an additional revised page from each of the Susquehanna Steam Electric Station (SSES) Unit 1 and Unit 2 Technical Specifications in support of our original proposal in the above referenced PLAs. The omission of these pages is due to an administrative oversight. As discussed with Mr. Poslusny, the deletions noted on these pages are bounded by the 'Safety Assessment' and 'No Significant Hazards Considerations' provided in PLA-4212, as well as the additional information regarding probability of hazardous off-site chlorine release provided in PLA-4305.

The deletion of the surveillance requirement on the attached pages results from the elimination of the chlorine detection system LCO and surveillance requirements from Technical Specifications 3.3.7.8 and 4.3.7.8, respectively. Without a functioning chlorine detection system in place, there is no purpose for a 'Outside air intake chlorine - high' isolation mode actuation test as required by Technical Specification 4.7.2 d 2 on the attached pages. Therefore, the attached deletions are

9508040028 950801
PDR ADDCK 05000387
PDR
U 10001


A001
11



administrative in nature only and are bounded by the NRC Safety Evaluation issued with reference 3) above.

Please call Mr. J. B. Wesner if you have any questions.

Very truly yours,



R. G. Byram

Attachments

copy: NRC Region I
Ms. M. Banerjee, NRC Sr. Resident Inspector - SSES
Mr. C. Poslusny, Jr., NRC Sr. Project Manager - Rockville
Mr. W. P. Dornsife, Pa. DER



37

21

22

23

24

25

26

27

28

29

30

31

32