

PRIORITY 2

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9508220045 DOC. DATE: 95/08/16 NOTARIZED: NO DOCKET #
 FACIL: 50-387 Susquehanna Steam Electric Station, Unit 1, Pennsylvania 05000387
 50-388 Susquehanna Steam Electric Station, Unit 2, Pennsylvania 05000388
 AUTH. NAME AUTHOR AFFILIATION
 KELLY, E.M. Region 1 (Post 820201)
 RECIP. NAME RECIPIENT AFFILIATION
 BYRAM, R.G. Pennsylvania Power & Light Co.

SUBJECT: Forwards insp repts 50-387/95-13 & 50-388/95-13 on 950530-0609. No violations noted.

DISTRIBUTION CODE: IE01D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 3+18
 TITLE: General (50 Dkt)-Insp Rept/Notice of Violation Response

NOTES: 05000387

RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
PD1-2 PD	1 1	POSLUSNY, C	1 1
INTERNAL: ACRS	2 2	AEOD/DEIB	1 1
AEOD/SPD/RAB	1 1	AEOD/TTC	1 1
DEDRO	1 1	<u>FILE CENTER</u>	1 1
NRR/DISP/PIPB	1 1	NRR/DORS/OEAB	1 1
NRR/DRCH/HHFB	1 1	NUDOCS-ABSTRACT	1 1
OE DIR	1 1	OGC/HDS2	1 1
RGN1 FILE 01	1 1		
EXTERNAL: LITCO BRYCE, J H	1 1	NOAC	1 1
NRC PDR	1 1		

NOTES: 1 1

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK, ROOM P1-37 (EXT. 504-2083) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 20 ENCL 20

P
R
I
O
R
I
T
Y
2
D
O
C
U
M
E
N
T

August 16, 1995

Mr. Robert G. Byram
Senior Vice President - Nuclear
Pennsylvania Power and Light Company
2 North Ninth Street
Allentown, Pennsylvania 18101

SUBJECT: SUSQUEHANNA ENGINEERING INSPECTION 95-13

Dear Mr. Byram:

This letter transmits the results of an inspection performed between May 30 - June 9, 1995, by Mr. D. Dempsey and others of this office at the Susquehanna Steam Electric Station and at your Allentown corporate offices. The inspection was focused on issues important to public health and safety, and consisted of independent evaluations of your inservice test, engineering, and core reload analysis programs. The preliminary inspection findings were discussed with Mr. G. Jones and other members of your staff on June 9, 1995.

We found that your inservice test and core safety analysis programs were well documented and implemented. The new condition report program involved senior management early in the corrective action process and fostered effective communication between the corporate engineering staff and the site. Your resolution of potentially significant safety issues involving liquid containment bypass leakage and unplanned post-accident control rod withdrawal was noteworthy. Oversight of contracted engineering services was accomplished effectively and confirmed by a high quality QA audit. The Engineering Review Committee was an excellent self-assessment initiative which reinforced high performance standards throughout the engineering organization.

No reply to this letter is necessary, and your cooperation with us during this inspection is appreciated.

Sincerely,

Eugene M. Kelly, Chief
Systems Section
Division of Reactor Safety

Docket Nos. 50-387; 50-388

Enclosure: Inspection Report Nos. 50-387/95-13 and 50-388/95-13

210017
9508220045 950816
PDR ADOCK 05000387
Q PDR

1001

Mr. Robert G. Byram

2

cc w/encl:

H. G. Stanley, Vice President - Nuclear Operations

J. M. Kenny, Nuclear Licensing

G. T. Jones, Vice President - Nuclear Engineering

M. M. Urioste, Nuclear Services Manager, General Electric

C. D. Lopes, Manager - Nuclear Security

W. Burchill, Manager, Assessment Services

H. D. Woodeshick, Special Office of the President

R. Wehry, Nuclear Licensing

J. C. Tilton, III, Allegheny Electric Cooperative, Inc.

Nuclear Safety Information Center (NSIC)

Commonwealth of Pennsylvania

Mr. Robert G. Byram

3

Distribution w/encl:
Region I Docket Room (with concurrences)
J. Wiggins, DRS
E. Kelly, DRS
K. Gallagher, DRP
D. Screnci, PAO (2)
NRC Resident Inspector
PUBLIC
DRS Files (2)

Distribution w/encl: (Via E-Mail)
W. Dean, OEDO
C. Poslusny, Project Manager, NRR
J. Stolz, PDI-2, NRR
Inspection Program Branch, NRR (IPAS)

DOCUMENT NAME: A: SU951313.INS

To receive a copy of this document, indicate in the box: "C" = Copy without attachment/enclosure "E" = Copy with attachment/enclosure "N" = No copy

OFFICE	RI/DRS	RI/DRS	RI/DRP	RI/DRS	RI/NER/DRPW
NAME	DMoy	DDempsey	CAnderson	EKelly	DDempsey & S.Bloom
DATE	08/15/95	08/15/95	08/15/95	08/16/95	08/15/95

OFFICIAL RECORD COPY