

PRIORITY 1

(ACCELERATED RIDS PROCESSING)

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9508220069 DOC.DATE: 95/08/18 NOTARIZED: NO DOCKET # 05000388
 FACIL: 50-388 Susquehanna Steam Electric Station, Unit 2, Pennsylvania
 AUTH.NAME AUTHOR AFFILIATION
 BYRAM, R.G. Pennsylvania Power & Light Co.
 RECIPIENT AFFILIATION
 RECIP.NAME Document Control Branch (Document Control Desk)

SUBJECT: Responds to NRC question on leak testing of blank flanges being installed to replace three pressure relief valves in RHR sys.

DISTRIBUTION CODE: A017D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 1
 TITLE: OR Submittal: Append J Containment Leak Rate Testing

NOTES:

	RECIPIENT		COPIES		
	ID CODE/NAME	LTR	ENCL		
	PD1-2 LA	1	0		
	POSLUSNY, C	1	1		
INTERNAL:	ACRS	6	6		
	NRR/DE/ECGB	1	1		
	OGC/HDS2	1	1		
EXTERNAL:	NOAC	1	1		
	PD1-2 PD	1	1		
	<u>FILE CENTER</u> 01	1	1		
	NRR/DSSA/SCSB	1	1		
	RES/DE/SEB	1	1		
	NRC PDR	1	1		

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK, ROOM OWFN 5D8 (415-2083) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR 16 ENCL 15



Pennsylvania Power & Light Company

Two North Ninth Street • Allentown, PA 18101-1179 • 610/774-5151

Robert G. Byram
Senior Vice President-Nuclear
610/774-7502
Fax: 610/774-5019

AUG 18 1995

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Mail Station P1-137
Washington, DC 20555

SUSQUEHANNA STEAM ELECTRIC STATION
REQUEST FOR ADDITIONAL INFORMATION
ON PROPOSED AMENDMENT NO. 142 TO
LICENSE NPF-22: DELETION OF RHR
RELIEF VALVES

PLA-4357


FILE R41-2

Docket No. 50-388

The purpose of this letter is to respond to the NRC staff's question on the leak testing of the blank flanges that are being installed to replace three pressure relief valves in the RHR system. A post-modification local leak rate test (LLRT) will be performed on the blank flanges that are part of the primary containment boundary. In addition these blank flanges will continue to be local leak rate tested in accordance with 10 CFR 50 Appendix J requirements.

If you have any questions, please contact C. T. Coddington at (610) 774-7531.

Very truly yours,



R. G. Byram

cc: NRC Region I

Ms. M. Banerjee, NRC Sr. Resident Inspector
Mr. C. Poslusny, NRC Sr. Project Manager
Mr. W. P. Dornsife, PA DEP

9508220069 950818
PDR ADDOCK 05000388
PDR

AD17/10

2001 6 23

2001 6 23