

**PRIORITY 1**  
ACCELERATED RIDS PROCESSING

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9512070016    DOC. DATE: 95/12/01    NOTARIZED: NO    DOCKET #  
 FACIL: 50-387 Susquehanna Steam Electric Station, Unit 1, Pennsylvania    05000387  
 AUTH. NAME    AUTHORITY AFFILIATION  
 BYRAM, R.G.    Pennsylvania Power & Light Co.  
 RECIP. NAME    RECIPIENT AFFILIATION  
                  Document Control Branch (Document Control Desk)

SUBJECT: Provides closure to one open item from Unit 1 Power Uprate Test Program Startup Rept.

DISTRIBUTION CODE: A001D    COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 1  
 TITLE: OR Submittal: General Distribution

NOTES: 05000387

	RECIPIENT ID CODE/NAME	COPIES LTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTR ENCL
	PD1-2 LA	1	PD1-2 PD	1
	POSLUSNY, C	1		
INTERNAL:	ACRS	6	<u>FILE CENTER</u> 01	1
	NRR/DE/EMCB	1	NRR/DRCH/HICB	1
	NRR/DSSA/SPLB	1	NRR/DSSA/SRXB	1
	NUDOCS-ABSTRACT	1	OGC/HDS2	1
EXTERNAL:	NOAC	1	NRC PDR	1
NOTES:		1		

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK, ROOM P1-37 (EXT. 504-2083) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR 19 ENCL 18

P  
R  
I  
O  
R  
I  
T  
Y  
  
1  
  
D  
O  
C  
U  
M  
E  
N  
T



**Pennsylvania Power & Light Company**

Two North Ninth Street • Allentown, PA 18101-1179 • 610/774-5151

Robert G. Byram  
Senior Vice President-Nuclear  
610/774-7502  
Fax: 610/774-5019

DEC 01 1995

U.S. Nuclear Regulatory Commission  
Attn.: Document Control Desk  
Mail Station P1-137  
Washington, DC 20555

**SUSQUEHANNA STEAM ELECTRIC STATION  
UNIT 1 POWER UPRATE TEST PROGRAM  
PLA-4390**


**FILES A17-2/R41-2**

**Docket No. 50-387/NPF-14**

This letter provides closure to the one open item from the Unit 1 Power Uprate Test Program Startup Report transmitted via PLA-4366 dated September 27, 1995. Section 3.3.3 of the report states that analysis of the results from plant procedure RE-1TP-024, "Jet Pump/Recirculation Loop Baseline Data Acquisition" was ongoing. This analysis has now been completed and the test results confirm the Technical Specification limits for single loop operation. Closure of this item concludes the Unit 1 Power Uprate Test Program.

Should you have any questions regarding this submittal, they should be directed to Mr. W.W. Williams at (610) 774-7742.

Very truly yours,

  
R. G. Byram  
Attachment

copy: Regional Administrator - Region I  
Ms. M. Banerjee, NRC Sr. Resident Inspector  
Mr. C. Poslusny, Jr., NRC Sr. Project Manager

070009

9512070016 951201  
PDR ADOCK 05000387.  
P. PDR

Adol  
1/0

