

# CATEGORY 1

## REGULATOR INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9601170375 DOC. DATE: 96/01/09 NOTARIZED: NO DOCKET #  
 FACIL: 50-387 Susquehanna Steam Electric Station, Unit 1, Pennsylv 05000387  
 50-388 Susquehanna Steam Electric Station, Unit 2, Pennsylv 05000388  
 AUTH. NAME AUTHOR AFFILIATION  
 BYRAM, R.G. Pennsylvania Power & Light Co.  
 RECIP. NAME RECIPIENT AFFILIATION  
 Document Control Branch (Document Control Desk)

SUBJECT: Forwards relief requests 1RR-24 & 2RR-21 in response to NRC questions re Units 1 & 2.

DISTRIBUTION CODE: A047D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 12  
 TITLE: OR Submittal: Inservice/Testing/Relief from ASME Code - GL-89-04

NOTES: 05000387

|           | RECIPIENT                 |  | COPIES |      |  | RECIPIENT    |  | COPIES |      |
|-----------|---------------------------|--|--------|------|--|--------------|--|--------|------|
|           | ID CODE/NAME              |  | LTR    | ENCL |  | ID CODE/NAME |  | LTR    | ENCL |
|           | PD1-2 LA                  |  | 1      | 1    |  | PD1-2 PD     |  | 1      | 1    |
|           | POSLUSNY, C               |  | 1      | 1    |  |              |  |        |      |
| INTERNAL: | ACRS                      |  | 6      | 0    |  | AEOD/SPD/RAB |  | 1      | 1    |
|           | <del>FILE CENTER</del> 01 |  | 1      | 1    |  | NRR/DE/ECGB  |  | 1      | 1    |
|           | NRR/DE/EMCB               |  | 1      | 1    |  | NRR/DE/EMEB  |  | 1      | 1    |
|           | NUDOCS-ABSTRACT           |  | 1      | 1    |  | OGC/HDS2     |  | 1      | 0    |
|           | RES/DET/EMMEB             |  | 1      | 1    |  | RES/DSIR/EIB |  | 1      | 1    |
| EXTERNAL: | LITCO ANDERSON            |  | 1      | 1    |  | NOAC         |  | 1      | 1    |
|           | NRC PDR                   |  | 1      | 1    |  |              |  |        |      |
| NOTES:    |                           |  | 1      | 1    |  |              |  |        |      |

NOTE TO ALL "RIDS" RECIPIENTS:  
 PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,  
 ROOM OWFN 5D-5 (EXT. 415-2083) TO ELIMINATE YOUR NAME FROM  
 DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR 22 ENCL 15

C  
A  
T  
E  
G  
O  
R  
Y  
1  
D  
O  
C  
U  
M  
E  
N  
T





**Pennsylvania Power & Light Company**

Two North Ninth Street • Allentown, PA 18101-1179 • 610/774-5151

Robert G. Byram  
Senior Vice President-Nuclear  
610/774-7502  
Fax: 610/774-5019

JAN 09 1996

U.S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Mail Station P1-137  
Washington, DC 20555

SUSQUEHANNA STEAM ELECTRIC STATION  
FIRST 10-YEAR INSERVICE INSPECTION INTERVAL  
PROGRAM RELIEF REQUESTS 1RR-24 AND 2RR-21:  
AUGMENTED RPV SHELL WELD EXAMINATIONS  
PLA-4398 FILES R41-2, R15-10

Docket Nos. 50-387  
and 50-388

During a recent telephone call, the NRC staff requested additional information on our augmented examination of the reactor vessel in order to close out the First 10-Year ISI Program Interval. The attached Relief requests 1RR-24 and 2RR-21 are in response to the NRC questions regarding SSES Units 1 and 2 compliance with the requirements of 10CFR50.55a(g)(6)(ii)(A), augmented examination of reactor vessel, for the First 10-Year Inservice Inspection Interval. These relief requests replace Relief Request RR-10 which was generated for the Second 10-Year Inservice Inspection Interval Program to address previous questions on this issue. Relief Request RR-10 will be removed from the Second 10-Year ISI Interval program upon NRC acceptance of Relief Requests 1RR-24 and 2RR-21.

In addition, the following clarifications are provided to assist with close out of the First 10-Year Inservice Inspection Interval Program:

- Relief Request 1RR-18 is withdrawn. The subject Class 2 Examination Category C-F piping weld only required a surface examination. Surface examination of the weld was successfully completed, and relief is not required. This weld is, however, included in Relief Request 1RR-19 for relief from complete volumetric examination in accordance with augmented program requirements.

180006

9601170375 960109  
PDR ADOCK 05000387  
P PDR

ADK  
11




1900

- Relief Request 1RR-19 lists two welds - VRRB311-FW-A20 and VRRB311-1-A - twice. This is an editorial error; the welds need only be listed once. Attached is a revision to Relief Request 1RR-19 which corrects this error.

If you have any questions, please contact Mr. C. T. Coddington at (610) 774-7531.


Very truly yours,



R. G. Byram

Attachments

copy: NRC Region I  
Ms. M. Banerjee, NRC Sr. Resident Inspector  
Mr. C. Poslusny, NRC Sr. Project Manager



**RELIEF REQUEST 1RR-24****I. RELIEF REQUEST APPLICABILITY**

- A. Unit: 1
- B. Code Examination Category: B-A, Pressure Retaining Welds in Reactor Vessel
- C. Code Item Number(s): B1.10, B1.11, B1.12
- D. Reference: 10CFR50.55(a)(g)(6)(ii)(A) -  
Augmented examination of reactor vessel

**II. IDENTIFICATION OF COMPONENTS**

SSES Units 1 and 2 reactor vessel pressure retaining welds identified in Table 1RR-24-1 are the subject of this relief request.

**TABLE 1RR-24-1**

| Component Identification | Description/Item Number          | Limiting Condition   | Examination Coverage (%) |
|--------------------------|----------------------------------|--|--------------------------|
| AD                       | Shell circumferential weld/B1.11 | Permanent RPV mirror insulation support steel precludes complete examination | 85.6                     |
| BK                       | Shell longitudinal weld/B1.12    | Permanent RPV mirror insulation support steel precludes complete examination | 81.1                     |
| BM                       | Shell longitudinal weld/B1.12    | Permanent RPV mirror insulation support steel precludes complete examination | 81.1                     |

**III. CODE/REGULATORY REQUIREMENTS FROM WHICH RELIEF IS REQUESTED**

10CFR50.55(a)(g)(6)(ii)(A)(2) requires volumetric examination of essentially 100% of the weld length of all circumferential and longitudinal shell welds in accordance with the examination requirements of Examination Category B-A, Item B1.10 of Table WB-2500-1 of the 1989 Edition of ASME Section XI. Relief is requested from complete examination of the affected welds (AD, BK, and BM) due to a plant design obstruction caused by permanent RPV mirror insulation support steel.





## RELIEF REQUEST 1RR-24

### IV. BASIS FOR RELIEF

Examination of the affected welds will be performed to the maximum extent practical using both automated and manual ultrasonic techniques from the RPV OD surface. This is the most practical examination approach for all Susquehanna reactor pressure vessel welds while still maintaining an acceptable level of quality and safety.

The three RPV welds (AD, BK, and BM) with coverage less than 90% are located on the fourth RPV shell course (approximately 171" above the top of the beltline region). The examination restriction is caused by permanent RPV mirror insulation support steel. Plant design changes to effect greater examination coverage represent extreme hardship without a compensating return in increased plant safety.

The obstruction allows examination of only 16.25 inches (each) of longitudinal welds BK and BM from both sides. The unexamined volume of welds BK and BM accounts for only 0.56% of the total RPV shell weld length. There is no unexamined volume for circumferential weld AD. The obstructed portion of weld AD can be examined from the other (unobstructed) side of the weld.

Since all portions of the three obstructed welds are above the top of active fuel, the volume of weld that has been completely examined is representative of the weld volume not examined. With 96% overall RPV shell weld examination coverage, the inability to completely examine a very small percentage of the total RPV weld length does not present an increased risk to public health and safety.

To date, the RPV shell welds have been examined twice and no service related flaw indications have been detected. Non-relevant fabrication flaw indications were recorded during both preservice baseline examinations (PSI) and the first interval inservice examinations (ISI). The location and size of these indications has not changed between the PSI and the ISI examinations. The results from both examinations certify that RPV shell weld integrity continues to provide for acceptable levels of plant quality and safety.

Overall ultrasonic examination coverage has increased significantly between the preservice examination and the inservice examinations. Improvements in manipulators and ultrasonic transducer design have resulted in increased coverage with the automated examination equipment. Performance of manual "pick-up" examinations further enhances coverage. These examination improvements have resulted in an increase in the quality of the examination and increased assurance of plant safety.

Alternative examination techniques for the subject welds were evaluated, and it was determined that no additional examination coverage is obtainable. Ultrasonic examination coverage of the three subject welds from the RPV ID surface was also evaluated. Coverage from the ID has been estimated to be approximately 80-85%, and offers no significant increase in coverage. Ultrasonic examinations from the RPV ID surface significantly impact refuel floor activities and resources with no commensurate increase in examination coverage or plant safety.

**RELIEF REQUEST 1RR-24**


Performance of RPV shell weld ultrasonic examinations from the RPV ID is not a prudent approach for Susquehanna. Actual RPV shell weld examination coverage from the RPV OD surface is 96% (based on total shell weld length). Whereas, overall ultrasonic examination coverage from the RPV ID has been estimated to be, at best, only 80 - 85%. Performance of supplemental external examinations would be necessary to maximize overall ID examination coverage to even match that achieved by the total OD examinations.

Implementing an examination plan which combines both OD and ID examinations provides no commensurate increase in quality and/or plant safety. The combined examination approach would result in examination coverage which is essentially equivalent to the current OD examination coverage; however, the combined examination approach will require additional resources and result in increased radiation dose. The increase in radiation dose is from performance of expanded supplemental manual OD examinations required to obtain ID coverage equivalent to a complete OD examination.

**V. ALTERNATE PROVISIONS**

Examinations of the affected welds will be performed to the maximum extent practical using automated ultrasonic examination techniques from the RPV OD surface.

In addition, the reactor pressure vessel pressure retaining welds are subject to VT-2 visual examination during system pressure testing in accordance with the requirements of Examination Category B-P.



## RELIEF REQUEST 2RR-21

I. RELIEF REQUEST APPLICABILITY

- A. Unit: 2
- B. Code Examination Category: B-A, Pressure Retaining Welds in Reactor Vessel
- C. Code Item Number(s): B1.10, B1.11, B1.12
- D. Reference: 10CFR50.55(a)(g)(6)(ii)(A) -  
Augmented examination of reactor vessel

II. IDENTIFICATION OF COMPONENTS

SSES Units 1 and 2 reactor vessel pressure retaining welds identified in Table 2RR-21-1 are the subject of this relief request.

TABLE 2RR-21-1

| Component Identification | Description/Item Number          | Limiting Condition   | Examination Coverage (%) |
|--------------------------|----------------------------------|--|--------------------------|
| AD                       | Shell circumferential weld/B1.11 | Permanent RPV mirror insulation support steel precludes complete examination | 85.6                     |
| BK                       | Shell longitudinal weld/B1.12    | Permanent RPV mirror insulation support steel precludes complete examination | 81.1                     |
| BM                       | Shell longitudinal weld/B1.12    | Permanent RPV mirror insulation support steel precludes complete examination | 81.1                     |

III. CODE/REGULATORY REQUIREMENTS FROM WHICH RELIEF IS REQUESTED

10CFR50.55(a)(g)(6)(ii)(A)(2) requires volumetric examination of essentially 100% of the weld length of all circumferential and longitudinal shell welds in accordance with the examination requirements of Examination Category B-A, Item B1.10 of Table IWB-2500-1 of the 1989 Edition of ASME Section XI. Relief is requested from complete examination of the affected welds (AD, BK, and BM) due to a plant design obstruction caused by permanent RPV mirror insulation support steel.

**RELIEF REQUEST 2RR-21****IV. BASIS FOR RELIEF**

Examination of the affected welds will be performed to the maximum extent practical using both automated and manual ultrasonic techniques from the RPV OD surface. This is the most practical examination approach for all Susquehanna reactor pressure vessel welds while still maintaining an acceptable level of quality and safety.

The three RPV welds (AD, BK, and BM) with coverage less than 90% are located on the fourth RPV shell course (approximately 171" above the top of the bellline region). The examination restriction is caused by permanent RPV mirror insulation support steel. Plant design changes to effect greater examination coverage represent extreme hardship without a compensating return in increased plant safety.

The obstruction allows examination of only 16.25 inches (each) of longitudinal welds BK and BM from both sides. The unexamined volume of welds BK and BM accounts for only 0.56% of the total RPV shell weld length. There is no unexamined volume for circumferential weld AD. The obstructed portion of weld AD can be examined from the other (unobstructed) side of the weld.

Since all portions of the three obstructed welds are above the top of active fuel, the volume of weld that has been completely examined is representative of the weld volume not examined. With 96% overall RPV shell weld examination coverage, the inability to completely examine a very small percentage of the total RPV weld length does not present an increased risk to public health and safety.

To date, the RPV shell welds have been examined twice and no service related flaw indications have been detected. Non-relevant fabrication flaw indications were recorded during both preservice baseline examinations (PSI) and the first interval inservice examinations (ISI). The location and size of these indications has not changed between the PSI and the ISI examinations. The results from both examinations certify that RPV shell weld integrity continues to provide for acceptable levels of plant quality and safety.

Overall ultrasonic examination coverage has increased significantly between the preservice examination and the inservice examinations. Improvements in manipulators and ultrasonic transducer design have resulted in increased coverage with the automated examination equipment. Performance of manual "pick-up" examinations further enhances coverage. These examination improvements have resulted in an increase in the quality of the examination and increased assurance of plant safety.

Alternative examination techniques for the subject welds were evaluated, and it was determined that no additional examination coverage is obtainable. Ultrasonic examination coverage of the three subject welds from the RPV ID surface was also evaluated. Coverage from the ID has been estimated to be approximately 80-85%, and offers no significant increase in coverage. Ultrasonic examinations from the RPV ID surface significantly impact refuel floor activities and resources with no commensurate increase in examination coverage or plant safety.

**RELIEF REQUEST 2RR-21**

Performance of RPV shell weld ultrasonic examinations from the RPV ID is not a prudent approach for Susquehanna. Actual RPV shell weld examination coverage from the RPV OD surface is 96% (based on total shell weld length). Whereas, overall ultrasonic examination coverage from the RPV ID has been estimated to be, at best, only 80 - 85%. Performance of supplemental external examinations would be necessary to maximize overall ID examination coverage to even match that achieved by the total OD examinations.

Implementing an examination plan which combines both OD and ID examinations provides no commensurate increase in quality and/or plant safety. The combined examination approach would result in examination coverage which is essentially equivalent to the current OD examination coverage; however, the combined examination approach will require additional resources and result in increased radiation dose. The increase in radiation dose is from performance of expanded supplemental manual OD examinations required to obtain ID coverage equivalent to a complete OD examination.

**V. ALTERNATE PROVISIONS**

Examinations of the affected welds will be performed to the maximum extent practical using automated ultrasonic examination techniques from the RPV OD surface.

In addition, the reactor pressure vessel pressure retaining welds are subject to VT-2 visual examination during system pressure testing in accordance with the requirements of Examination Category B-P.

RELIEF REQUEST NO. 1RR-18

I. IDENTIFICATION OF COMPONENTS AND IMPRACTICAL CODE REQUIREMENTS

Relief Request 1RR-18 is no longer needed and has been withdrawn.



1. The first part of the document is a list of names and addresses, which are arranged in a columnar format. The names are written in a cursive script, and the addresses are written in a more formal, printed style. The list is organized into two columns, with the names on the left and the addresses on the right. The names are: [Illegible names]

2. The second part of the document is a list of names and addresses, which are arranged in a columnar format. The names are written in a cursive script, and the addresses are written in a more formal, printed style. The list is organized into two columns, with the names on the left and the addresses on the right. The names are: [Illegible names]

3. The third part of the document is a list of names and addresses, which are arranged in a columnar format. The names are written in a cursive script, and the addresses are written in a more formal, printed style. The list is organized into two columns, with the names on the left and the addresses on the right. The names are: [Illegible names]

4. The fourth part of the document is a list of names and addresses, which are arranged in a columnar format. The names are written in a cursive script, and the addresses are written in a more formal, printed style. The list is organized into two columns, with the names on the left and the addresses on the right. The names are: [Illegible names]



This page intentionally left blank.

TABLE IRR-19-1

| Component Identification | Configuration/System      | Exam Source           | Exam Type | Limiting Condition   | Estimate of Exam Coverage | Basis for relief  | Alternate Provisions |
|--------------------------|---------------------------|-----------------------|-----------|--|---------------------------|---|----------------------|
| DLA1011-FW-1             | Pipe-valve/<br>Feedwater  | FSAR Section<br>6.6.8 | Vol       | Limited access due to<br>pipe whip restraint   | 87%<br>Complete           | Examination performed<br>to maximum extent<br>practical.        | NONE                 |
| DBA1012-FW-6             | Pipe-flued<br>head/RWCU   | FSAR Section<br>6.6.8 | Vol       | Hanger removal<br>required to facilitate<br>exam. Area survey<br>indicates 18R field.<br>Estimate 801 mhrs in<br>area to complete<br>inspection. | 0%                        | Excessive radiological<br>environment prohibits<br>examination. | NONE                 |
| N4B-IR                   | Nozzle inner<br>radius    | NUREG 0619            | Vol       | Biological shield wall<br>restricts access to<br>exam equipment.   | 84.7%                     | Examination completed to<br>maximum extent<br>practical.        | NONE                 |
| N4B-BORE                 | Nozzle bore/<br>Feedwater |                       |           |  | 84.9%                     |   | NONE                 |
| N4D-IR                   | Nozzle inner<br>radius    | NUREG 0619            | Vol       | Thermocouple pads<br>restrict access to<br>examination<br>equipment.   | 82.6%                     | Examination completed to<br>maximum extent<br>practical.        | NONE                 |
| N4D-BORE                 | Nozzle bore/<br>Feedwater |                       |           |  | 85%                       |   | NONE                 |
| DBB1071-1-B              | Elbow-Pipe/RHR            | NUREG 0313            | Vol       | Permanent pipe<br>support saddle restricts<br>complete scan  | 84%                       | Examination completed to<br>the maximum extent<br>practical.    | NONE                 |
| DCB1021-FW-2             | Valve-Flued<br>Head/RHR   | NUREG 0313            | Vol       | Component<br>configuration   | 50%                       | Examination completed to<br>the maximum extent<br>practical.    | NONE                 |
| DCB1021-FW-4             | Flued Head-<br>Elbow/RHR  | NUREG<br>0313         | Vol       | Welded pipe clamp  | 89.4%                     | Examination completed to<br>the maximum extent<br>practical.    | NONE                 |



11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34  
35  
36  
37  
38  
39  
40  
41  
42  
43  
44  
45  
46  
47  
48  
49  
50  
51  
52  
53  
54  
55  
56  
57  
58  
59  
60  
61  
62  
63  
64  
65  
66  
67  
68  
69  
70  
71  
72  
73  
74  
75  
76  
77  
78  
79  
80  
81  
82  
83  
84  
85  
86  
87  
88  
89  
90  
91  
92  
93  
94  
95  
96  
97  
98  
99  
100

[Faint, illegible text or markings, possibly bleed-through from the reverse side of the page.]

TABLE 1RR-19-1

| Component Identification | Configuration/System                | Exam Source | Exam Type | Limiting Condition                  | Estimate of Exam Coverage | Basis for relief                                       | Alternate Provisions |
|--------------------------|-------------------------------------|-------------|-----------|-------------------------------------|---------------------------|--|----------------------|
| VRRB311-FW-A20           | Weldolet-Pipe/Reactor Recirculation | NUREG 0313  | Vol       | Component (Weldolet) Configuration  | 50%*                      | Examination performed to the maximum extent practical. | NONE                 |
| VRRB311-1-A              | Pipe-Weldolet/Reactor Recirculation | NUREG 0313  | Vol       | Component (Weldolet) Configuration  | 50%*                      | Examination performed to the maximum extent practical. | NONE                 |
| VRRB311-2-B              | Pipe-Weldolet/Reactor Recirculation | NUREG 0313  | Vol       | Component (Weldolet) Configuration  | 50%*                      | Examination performed to the maximum extent practical. | NONE                 |
| VRRB312-FW-B20           | Weldolet-Pipe/Reactor Recirculation | NUREG 0313  | Vol       | Component (Weldolet) Configuration  | 50%*                      | Examination performed to the maximum extent practical. | NONE                 |
| VRRB312-10-B             | Pipe-Weldolet/Reactor Recirculation | NUREG 0313  | Vol       | Component (Weldolet) Configuration  | 50%*                      | Examination performed to the maximum extent practical. | NONE                 |
| VRRB312-12-A             | Pipe-Weldolet/Reactor Recirculation | NUREG 0313  | Vol       | Component (Weldolet) Configuration  | 50%*                      | Examination performed to the maximum extent practical. | NONE                 |
| VRRB312-3-A              | Pipe-Weldolet/Reactor Recirculation | NUREG 0313  | Vol       | Component (Weldolet) Configuration  | 50%*                      | Examination performed to the maximum extent practical. | NONE                 |
| VRRB312-3-B              | Pipe-Weldolet/Reactor Recirculation | NUREG 0313  | Vol       | Component (Weldolet) Configuration  | 50%                       | Examination performed to the maximum extent practical. | NONE                 |
| DBB1181-1-A              | Pipe-Sweepolet/Feedwater            | FSAR 6.6.8  | Vol       | Component (Sweepolet) Configuration | 50%                       | Examination performed to the maximum extent practical. | NONE                 |

\*Axial scan 100%; Circumferential scan 0%.



2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30

9

0

0

7

1

11

12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30

RECEIVED  
MAY 11 1964  
U.S. DEPARTMENT OF THE INTERIOR  
BUREAU OF LAND MANAGEMENT  
DENVER, COLORADO

8

0