

TABLE 3.3.2-2 ISOLATION ACTUATION INSTRUMENTATION SETPOINTS		
TRIP FUNCTION	TRIP SETPOINT	ALLOWABLE VALUE
1. PRIMARY CONTAINMENT ISOLATION		
<ul style="list-style-type: none"> a. Reactor Vessel Water Level <ul style="list-style-type: none"> 1) Low, Level 3 2) Low Low, Level 2 3) Low Low Low, Level 1 b. Drywell Pressure - High c. Manual Initiation d. SGTS Exhaust Radiation - High e. Main Steam Line Radiation - High 	<ul style="list-style-type: none"> ≥ 13.0 inches * ≥ -38.0 inches * ≥ -129 inches * ≤ 1.72 psig NA ≤ 23.0 mR/hr ≤ 7.0 x full power background 	<ul style="list-style-type: none"> ≥ 11.5 inches ≥ -45.0 inches ≥ -136 inches ≤ 1.88 psig NA ≤ 31.0 mR/hr ≤ 8.4 x full power background
2. SECONDARY CONTAINMENT ISOLATION		
<ul style="list-style-type: none"> a. Reactor Vessel Water Level-Low Low, Level 2 b. Drywell Pressure - High c. Refuel Floor High Exhaust Duct Radiation - High d. Railroad Access Shaft Exhaust Duct Radiation - High e. Refuel Floor Wall Exhaust Duct Radiation - High f. Manual Initiation 	<ul style="list-style-type: none"> ≥ -38.0 inches * ≤ 1.72 psig ≤ 2.5 mR/hr 18 ≤ 2.5 mR/hr 5 ≤ 2.5 mR/hr 21 NA 	<ul style="list-style-type: none"> ≥ -45.0 inches ≤ 1.88 psig ≤ 4.0 mR/hr 25 ≤ 4.0 mR/hr 7 ≤ 4.0 mR/hr 28 NA
3. MAIN STEAM LINE ISOLATION		
<ul style="list-style-type: none"> a. Reactor Vessel Water Level - Low Low Low, Level 1 b. Main Steam Line Radiation - High c. Main Steam Line Pressure - Low d. Main Steam Line Flow - High 	<ul style="list-style-type: none"> ≥ -129 inches * ≤ 7.0 x full power background ≥ 861 psig ≤ 113 psid ** 	<ul style="list-style-type: none"> ≥ -136 inches ≤ 8.4 x full power background >841 psig <121 psid **




TABLE 3.3.2-2		
ISOLATION ACTUATION INSTRUMENTATION SETPOINTS		
TRIP FUNCTION	TRIP SETPOINT	ALLOWABLE VALUE
1. PRIMARY CONTAINMENT ISOLATION		
a. Reactor Vessel Water Level 1) Low, Level 3 2) Low Low, Level 2 3) Low Low Low, Level 1 b. Drywell Pressure - High c. Manual Initiation d. SGTS Exhaust Radiation - High e. Main Steam Line Radiation - High	≥ 13.0 inches ≥ -38.0 inches ≥ -129 inches ≤ 1.72 psig NA ≤ 23.0 mR/hr $\leq 7.0 \times$ full power background	≥ 11.5 inches ≥ -45.0 inches ≥ -138 inches ≤ 1.88 psig NA ≤ 31.0 mR/hr $\leq 8.4 \times$ full power background
2. SECONDARY CONTAINMENT ISOLATION		
a. Reactor Vessel Water Level - Low Low, Level 2 b. Drywell Pressure - High c. Refuel Floor High Exhaust Duct Radiation - High d. Railroad Access Shaft Exhaust Duct Radiation - High e. Refuel Floor Wall Exhaust Duct Radiation - High f. Manual Initiation	≥ -38.0 inches ≤ 1.72 psig ≤ 2.5 mR/hr 18 ≤ 2.5 mR/hr 5 ≤ 2.5 mR/hr 21 NA	≥ -45.0 inches ≤ 1.88 psig ≤ 4.0 mR/hr 25 ≤ 4.0 mR/hr 7 ≤ 4.0 mR/hr 28 NA
3. MAIN STEAM LINE ISOLATION		
a. Reactor Vessel Water Level - Low Low Low, Level 1 b. Main Steam Line Radiation - High c. Main Steam Line Pressure - Low d. Main Steam Line Flow - High	≥ -129 inches $\leq 7.0 \times$ full power background ≥ 881 psig ≤ 113 psid	≥ -138 inches $\leq 8.4 \times$ full power background ≥ 841 psig ≤ 121 psid

