

# CATEGORY 1

## REGULATOR INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION # ABR: 9705060052      DOC. DATE: 97/04/29      NOTARIZED: NO      DOCKET #  
 FACIL: 50-387 Susquehanna Steam Electric Station, Unit 1, Pennsylva      05000387  
 50-388 Susquehanna Steam Electric Station, Unit 2, Pennsylva      05000388  
 AUTH. NAME      AUTHOR AFFILIATION  
 BYRAM, R.G.      Pennsylvania Power & Light Co.  
 RECIP. NAME      RECIPIENT AFFILIATION  
                          Document Control Branch (Document Control Desk)

SUBJECT: Provides update on status of implementing GL-95-07.180-day response will be revised when mods to valves designed.

DISTRIBUTION CODE: A056D      COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 2  
 TITLE: Generic Ltr 95-07 - Pressure Locking & Thermal Binding of Safety Rela


NOTES: 05000387

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID CODE/NAME	NRR/DRPE/EATON POSLUSNY, C	LTR	ENCL		ID CODE/NAME	LTR	ENCL	
INTERNAL: <u>FILE CENTER</u> 01			1	1				1	1
EXTERNAL: NOAC			1	1				1	1
EXTERNAL: NUDOCS ABSTRACT			1	1				1	1
NOTES:			1	1					

C  
A  
T  
E  
G  
O  
R  
Y  
1  
D  
O  
C  
U  
M  
E  
N  
T

NOTE TO ALL "RIDS" RECIPIENTS:  
 PLEASE HELP US TO REDUCE WASTE. TO HAVE YOUR NAME OR ORGANIZATION REMOVED FROM DISTRIBUTION LISTS OR REDUCE THE NUMBER OF COPIES RECEIVED BY YOU OR YOUR ORGANIZATION, CONTACT THE DOCUMENT CONTROL DESK (DCD) ON EXTENSION 415-2083

TOTAL NUMBER OF COPIES REQUIRED: LTR 9 ENCL 6





**Pennsylvania Power & Light Company**

Two North Ninth Street • Allentown, PA 18101-1179 • 610/774-5151

Robert G. Byram  
Senior Vice President  
Generation and Chief Nuclear Officer  
610/774-7502  
Fax: 610/774-5019

APR 29 1997

U.S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Mail Station P1-137  
Washington, DC 20555

**SUSQUEHANNA STEAM ELECTRIC STATION  
UPDATE ON THE STATUS OF  
GENERIC LETTER 95-07 IMPLEMENTATION  
PLA-4616**

Docket Nos. 50-387  
and 50-388

**FILE R41-2**

- References:
- 1) Letter (PLA-4418) from R. G. Byram (PP&L) to NRC Document Control Desk titled, "180-Day Response to Generic Letter 95-07, 'Pressure Locking and Thermal Binding of Safety-Related Power-Operated Gate Valves,'" dated February 14, 1996.
  - 2) Letter (PLA-4479) from R. G. Byram (PP&L) to NRC Document Control Desk titled, "Response to RAI Dated 6/10/96 on Generic Letter 95-07," dated July 11, 1996.
  - 3) Letter (PLA-4515) from R. G. Byram (PP&L) to NRC Document Control Desk titled, "Revision to PP&L's 180-Day Response to Generic Letter 95-07, 'Pressure Locking and Thermal Binding of Safety-Related Power-Operated Gate Valves,'" dated November 7, 1996.

This letter provides an update on the status of implementing Generic Letter 95-07. In Reference 3 above, Pennsylvania Power & Light Company stated that the Residual Heat Removal (RHR) Suppression Pool Return Isolation Valves (HV-1(2)51-F028A/B) in each unit were susceptible to system transient pressure locking. As stated in the reference, the actions to correct the pressure locking for these valves were procedural changes predicated on the successful completion of analyses to verify that the piping loads induced by a revised operating sequence are acceptable. The results of the analyses of the piping have shown that the piping loads induced by the proposed sequence are higher than initially expected. Therefore, a modification to the RHR Suppression Pool Return Isolation Valves is required. These modifications will be completed in the Unit 1 10th Refueling and Inspection Outage (Spring of 1998) and the Unit 2 9th Refueling and Inspection Outage (Spring of 1999). The evaluation of the operability of these valves as stated in Reference 3 is not changed by the need to provide a modification to these valves.

050127  
9705060052 970429  
PDR ADOCK 05000387  
PDR




A056 1/0

Also in Reference 3, PP&L stated that the High Pressure Coolant Injection (HPCI) Suppression Pool Suction Valves (HV-1(2)55-F042) were not susceptible to thermally induced pressure locking or thermal binding. Upon reanalysis of the performance of these valves due to proposed modifications to the valve control logic, it was determined that these valves are susceptible to thermally induced pressure locking if the barometric condenser fails. Based upon an evaluation, there are no operability issues with these valves. Modifications of these valves will be completed in the Unit 1 10th Refueling and Inspection Outage (Spring of 1998) and the Unit 2 9th Refueling and Inspection Outage (Spring of 1999).

Our 180-Day Response to Generic Letter 95-07 will be revised when the modifications to the valves are designed.

If you have any questions, please contact Mr. C. T. Coddington at (717) 542-3294.

Very truly yours,



R. G. Byram

copy: NRC Region I  
Mr. K. Jenison, NRC Sr. Resident Inspector  
Mr. C. Poslusny, NRC Sr. Project Manager



100

100

100