

CONTAINMENT SYSTEMSSURVEILLANCE REQUIREMENTS (Continued)**DRAFT** - Proposed
Amendment
to be Submitted
Separately

- b. At least once per 18 months or (1) after any structural maintenance on the HEPA filter or charcoal adsorber housings, or (2) following painting, fire or chemical release in any ventilation zone communicating with the subsystem by:
1. Verifying that the subsystem satisfies the in-place penetration and bypass leakage testing acceptance criteria of less than 0.05% and uses the test procedures of Regulatory Positions C.5.a, C.5.c and C.5.d of Regulatory Guide 1.52, Revision 2, March 1978, and the system flow rate is 10,100 cfm \pm 10%.
 2. Verifying within 31 days after removal that a laboratory analysis of a representative carbon sample obtained in accordance with Regulatory Position C.6.b of Regulatory Guide 1.52, Revision 2, March 1978, meets the laboratory testing criteria of Regulatory Position C.6.a of Regulatory Guide 1.52, Revision 2, March 1978, for a methyl iodide penetration of less than 0.175%; and
 3. Verifying a subsystem flow rate of 10,100 cfm \pm 10% during system operation when tested in accordance with ANSI N510-1975.
- c. After every 720 hours of charcoal adsorber operation by verifying within 31 days after removal that a laboratory analysis of a representative carbon sample obtained in accordance with Regulatory Position C.6.b of Regulatory Guide 1.52, Revision 2, March 1978, meets the laboratory testing criteria of Regulatory Position C.6.a of Regulatory Guide 1.52, Revision 2, March 1978, for a methyl iodide penetration of less than 0.175%.
- d. At least once per 18 months by:
1. Verifying that the pressure drop across the combined HEPA filters and charcoal adsorber banks is less than 13 inches Water Gauge while operating the filter train at a flow rate of 10,100 cfm \pm 10%.
 2. Verifying that the filter train starts and associated dampers open on each of the following test signals:
 - a. Manual initiation from the control room, and
 - b. Simulated automatic initiation signal.
 3. Verifying that the filter cooling bypass and outside air dampers open and the fan start on filter cooling initiation.
 4. Verifying that the temperature differential across each heating coil is \geq 17°F when tested in accordance with ANSI N510-1975.

except that
* the test is performed at 30°C and 95% relative humidity in accordance with ASTM D3803-79 Method A.

SUSQUEHANNA - UNIT 1

3/4 6-35

Amendment No. 82

PLA-1640, Attachment
Page 2 of 4**DRAFT**Proposed
Amendment
to be Submitted
SeparatelyPLANT SYSTEMSSURVEILLANCE REQUIREMENTS (Continued)


1. Verifying that the subsystem satisfies the in-place penetration and bypass leakage testing acceptance criteria of less than 0.05% and uses the test procedures of Regulatory Positions C.5.a, C.5.c and C.5.d of Regulatory Guide 1.52, Revision 2, March 1978, and the system flow rate is 5810 cfm \pm 10%.
 2. Verifying within 31-days after removal that a laboratory analysis of a representative carbon sample obtained in accordance with Regulatory Position C.6.b of Regulatory Guide 1.52, Revision 2, March 1978, meets the laboratory testing criteria of Regulatory Position C.6.a of Regulatory Guide 1.52, Revision 2, March 1978, for a methyl iodide penetration of less than 0.175%; and
 3. Verifying a subsystem flow rate of 5810 cfm \pm 10% during subsystem operation when tested in accordance with ANSI N510-1975.
- c. After every 720 hours of charcoal adsorber operation by verifying within 31 days after removal that a laboratory analysis of a representative carbon sample obtained in accordance with Regulatory Position C.6.b of Regulatory Guide 1.52, Revision 2, March 1978, meets the laboratory testing criteria of Regulatory Position C.6.a of Regulatory Guide 1.52, Revision 2, March 1978, for a methyl iodide penetration of less than 0.175%.
- d. At least once per 18 months by:
1. Verifying that the pressure drop across the combined prefilter, upstream and downstream HEPA filters and charcoal adsorber banks is less than 9.1 inches Water Gauge while operating the subsystem at a flow rate of 5810 cfm \pm 10%.
 2. Verifying that on the below isolation mode actuation test signal, the subsystem automatically switches to the isolation mode of operation and the isolation dampers close within 8 seconds:
 - a) Outside air intake chlorine - high.
 3. Verifying that on each of the below pressurization mode actuation test signals, the subsystem automatically switches to the pressurization mode of operation and the control structure is maintained at a positive pressure of 1/8 inch W.G. relative to the outside atmosphere during subsystem operation at a flow rate less than or equal to 5810 cfm:
 - a) Reactor Building isolation, and
 - b) Outside air intake radiation - high.
 4. Verifying that the heaters dissipate 30 \pm 3.0 Kw when tested in accordance with ANSI N510-1975.
- Except that the test is performed at 30°C and 95% relative humidity in accordance with ASTM D3803-79 Method A.*

DRAFTProposed
Amendment to
be submitted
separatelyCONTAINMENT SYSTEMSSURVEILLANCE REQUIREMENTS (Continued)

- b. At least once per 18 months or (1) after any structural maintenance on the HEPA filter or charcoal adsorber housings, or (2) following painting, fire or chemical release in any ventilation zone communicating with the subsystem by:
1. Verifying that the subsystem satisfies the in-place penetration and bypass leakage testing acceptance criteria of less than 0.05% and uses the test procedures of Regulatory Positions C.5.a, C.5.c and C.5.d of Regulatory Guide 1.52, Revision 2, March 1978, and the system flow rate is 10,100 cfm \pm 10%.
 2. Verifying within 31 days after removal that a laboratory analysis of a representative carbon sample obtained in accordance with Regulatory Position C.6.b of Regulatory Guide 1.52, Revision 2, March 1978, meets the laboratory testing criteria of Regulatory Position C.6.a of Regulatory Guide 1.52, Revision 2, March 1978, for a methyl iodide penetration of less than 0.175%; and
 3. Verifying a subsystem flow rate of 10,100 cfm \pm 10% during system operation when tested in accordance with ANSI N510-1975.
- c. After every 720 hours of charcoal adsorber operation by verifying within 31 days after removal that a laboratory analysis of a representative carbon sample obtained in accordance with Regulatory Position C.6.b of Regulatory Guide 1.52, Revision 2, March 1978, meets the laboratory testing criteria of Regulatory Position C.6.a* of Regulatory Guide 1.52, Revision 2, March 1978, for a methyl iodide penetration of less than 0.175%.
- d. At least once per 18 months by:
1. Verifying that the pressure drop across the combined HEPA filters and charcoal adsorber banks is less than 13 inches Water Gauge while operating the filter train at a flow rate of 10,100 cfm \pm 10%.
 2. Verifying that the filter train starts and associated dampers open on each of the following test signals:
 - a. Manual initiation from the control room, and
 - b. Simulated automatic initiation signal.
 3. Verifying that the filter cooling bypass and outside air dampers open and the fan start on filter cooling initiation.
 4. Verifying that the temperature differential across each heating coil is \geq 17°F when tested in accordance with ANSI N510-1975.

Except that

* The test is performed at 30°C and 95% relative humidity in accordance with ASTM D3803-79 Method A.



PLA-4640, Attachment
Page 4 of 4

DRAFT

Proposed Amendment
to be Submitted
Separately

PLANT SYSTEMS

SURVEILLANCE REQUIREMENTS (Continued)

1. Verifying that the subsystem satisfies the in-place penetration and bypass leakage testing acceptance criteria of less than 0.05% and uses the test procedures of Regulatory Positions C.5.a, C.5.c, and C.5.d of Regulatory Guide 1.52, Revision 2, March 1978, and the system flow rate is 5810 cfm ± 10%.
 2. Verifying within 31 days after removal that a laboratory analysis of a representative carbon sample obtained in accordance with Regulatory Position C.6.b of Regulatory Guide 1.52, Revision 2, March 1978, meets the laboratory testing criteria of Regulatory Position C.6.a of Regulatory Guide 1.52, Revision 2, March 1978, for a methyl iodide penetration of less than 0.175%; and
 3. Verifying a subsystem flow rate of 5810 cfm ± 10% during subsystem operation when tested in accordance with ANSI N510-1975.
- c. After every 720 hours of charcoal adsorber operation by verifying within 31 days after removal that a laboratory analysis of a representative carbon sample obtained in accordance with Regulatory Position C.6.b of Regulatory Guide 1.52, Revision 2, March 1978, meets the laboratory testing criteria of Regulatory Position C.6.a of Regulatory Guide 1.52, Revision 2, March 1978, for a methyl iodide penetration of less than ~~0.75%~~ **0.175%**.
- d. At least once per 18 months by:
1. Verifying that the pressure drop across the combined prefilter, upstream and downstream HEPA filters and charcoal adsorber banks is less than 9.1 inches Water Gauge while operating the subsystem at a flow rate of 5810 cfm ± 10%.
 2. Verifying that on the below isolation mode actuation test signal, the subsystem automatically switches to the isolation mode of operation and the isolation dampers close within 8 seconds:
 - a) Outside air intake chlorine - high.
 3. Verifying that on each of the below pressurization mode actuation test signals, the subsystem automatically switches to the pressurization mode of operation and the control structure is maintained at a positive pressure of 1/8 inch W.G. relative to the outside atmosphere during subsystem operation at a flow rate less than or equal to 5810 cfm:
 - a) Reactor Building isolation, and
 - b) Outside air intake-radiation - high.

Except that 4. Verifying that the heaters dissipate 30 ± 3.0 Kw when tested in accordance with ANSI N510-1975.
 * The test is performed at 30°C and 95% relative humidity in accordance with ASTM D3803-79 Method A.

