

CATEGORY 1

REGULATOR INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION/NBR: 9707290217 DOC. DATE: 97/07/21 NOTARIZED: NO DOCKET #
FACIL: 50-387 Susquehanna Steam Electric Station, Unit 1, Pennsylvania 05000387
AUTH. NAME AUTHOR AFFILIATION
KUCZYNSKI, G.J. Pennsylvania Power & Light Co.
RECIPIENT NAME RECIPIENT AFFILIATION
Document Control Branch (Document Control Desk)

SUBJECT: Forwards LER 97-013-00, per 10CFR50.73(a)(2)(B) re condition prohibited by TSS. Enforcement discretion was requested by PPL & granted by NRC to allow continued power operation of both plants.

DISTRIBUTION CODE: IE22T COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 1+4
TITLE: 50.73/50.9 Licensee Event Report (LER), Incident Rpt, etc.

NOTES:

05000387

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD1-2 PD	1 1	POSLUSNY, C	1 1
INTERNAL:	ACRS	1 1	AEOD/SPD/RAB	2 2
	AEOD/SPD/RRAB	1 1	<u>FILE CENTER</u>	1 1
	NRR/DE/ECGB	1 1	NRR/DE/EELB	1 1
	NRR/DE/EMEB	1 1	NRR/DRCH/HHFB	1 1
	NRR/DRCH/HICB	1 1	NRR/DRCH/HOLB	1 1
	NRR/DRCH/HQMB	1 1	NRR/DRPM/PECB	1 1
	NRR/DSSA/SPLB	1 1	NRR/DSSA/SRXB	1 1
	RES/DET/EIB	1 1	RGN1 FILE 01	1 1
EXTERNAL:	L ST LOBBY WARD	1 1	LITCO BRYCE, J. H	1 1
	NOAC POORE, W.	1 1	NOAC QUEENER, DS	1 1
	NRC PDR	1 1	NUDOCS FULL TXT	1 1
NOTES:		1 1		

NOTE TO ALL "RIDS" RECIPIENTS:
PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
ROOM OWFN 5D-5(EXT. 415-2083) TO ELIMINATE YOUR NAME FROM
DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

FULL TEXT CONVERSION REQUIRED
TOTAL NUMBER OF COPIES REQUIRED: LTR 26 ENCL 26

C
A
T
E
G
O
R
Y
1
D
O
C
U
M
E
N
T



12/1/74



Pennsylvania Power & Light Company

Two North Ninth Street • Allentown, PA 18101-1179 • 610/774-5151

JUL 21 1997

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Mail Station P1-137
Washington, DC 20555

SUSQUEHANNA STEAM ELECTRIC STATION
LICENSEE EVENT REPORT 50-387/97-013-00
PLAS-715 FILE R41-2

Docket No. 50-387
License No. NPF-14

Attached is Licensee Event Report 50-387/97-013-00. This report is being made pursuant to 10CFR50.73(a)(2)(i)(B) in that Susquehanna SES Unit 1 and Unit 2 were in a condition prohibited by the Technical Specifications when it was discovered that the requirements for periodic surveillance testing laboratory analysis of activated carbon samples in purchase documents differed from those specified in the Technical Specifications. Enforcement discretion was requested by Pennsylvania Power & Light Company and granted by the NRC to allow continued power operation of both units. A request for a Technical Specification Amendment has been submitted.

G. J. Kuczynski
General Manager - Susquehanna SES

Attachment

cc: Mr. H. J. Miller
Regional Administrator
U. S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

cc: Mr. K. Jenison
Sr. Resident Inspector
U. S. Nuclear Regulatory Commission
P. O. Box 35
Berwick, PA 18603-0035

IE221

9707290217 970721
PDR ADDCK 05000387
S PDR

090000

