

# CATEGORY 1

## REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9711210137 DOC. DATE: 97/11/17 NOTARIZED: NO  
FACIL: 50-388 Susquehanna Steam Electric Station, Unit 2, Pennsylvania  
AUTH. NAME AUTHOR AFFILIATION  
KUCZYNSKI, G.J. Pennsylvania Power & Light Co.  
RECIP. NAME RECIPIENT AFFILIATION  
Document Control Branch (Document Control Desk)

SUBJECT: Forwards LER 97-007-00 re TS 3.0.3 entry voluntarily made,  
per guidance of NUREG-1022. Operability testing completed in  
timely manner, rod block monitor restored to operable status  
& LCO cleared.

DISTRIBUTION CODE: IE22T COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 1 +  
TITLE: 50.73/50.9 Licensee Event Report (LER), Incident Rpt, etc.

### NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD1-2 PD	1 1	POSLUSNY, C	1 1
INTERNAL:	ACRS	1 1	AEOD/SPD/RAB	2 2
	AEOD/SPD/RRAB	1 1	<u>FILE CENTER</u>	1 1
	NRR/DE/ECGB	1 1	NRR/DE/EELB	1 1
	NRR/DE/EMEB	1 1	NRR/DRCH/HHFB	1 1
	NRR/DRCH/HICB	1 1	NRR/DRCH/HOLB	1 1
	NRR/DRCH/HQMB	1 1	NRR/DRPM/PECB	1 1
	NRR/DSSA/SPLB	1 1	NRR/DSSA/SRXB	1 1
	RES/DET/EIB	1 1	RGN1 FILE 01	1 1
EXTERNAL:	L ST LOBBY WARD	1 1	LITCO BRYCE, J H	1 1
	NOAC POORE, W.	1 1	NOAC QUEENER, DS	1 1
	NRC PDR	1 1	NUDOCS FULL TXT	1 1

NOTE TO ALL "RIDS" RECIPIENTS:  
PLEASE HELP US TO REDUCE WASTE. TO HAVE YOUR NAME OR ORGANIZATION REMOVED FROM DISTRIBUTION  
OR REDUCE THE NUMBER OF COPIES RECEIVED BY YOU OR YOUR ORGANIZATION, CONTACT THE DOCUMENT  
DESK (DCD) ON EXTENSION 415-2083

FULL TEXT CONVERSION REQUIRED  
TOTAL NUMBER OF COPIES REQUIRED: LTTR 25 ENCL 25

George J. Kuczynski  
General Manager-Susquehanna

PP&L Resources, Inc.  
Two North Ninth Street  
Allentown, PA 18101-1179

Susquehanna Steam Electric Station  
P.O. Box 467, Berwick, PA 18603  
Tel. 717.542.3120 Fax 717.542.1949




November 17, 1997

U.S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Mail Station P1-137  
Washington, DC 20555

SUSQUEHANNA STEAM ELECTRIC STATION  
LICENSEE EVENT REPORT 50-388/97-007-00  
PLA - 4804 FILE R41-2

Docket No. 50-388  
License No. NPF-22

Attached is Licensee Event Report 50-388/97-007-00. This event is being reported pursuant to the guidance of NUREG 1022, per 10CFR50.73(a)(2)(i)(B), for an entry into Technical Specification 3.0.3. The Technical Specification 3.0.3 entry was made voluntarily to allow completion of operability testing of one channel of the Rod Block Monitor. The operability testing was completed in a timely manner, the Rod Block Monitor was restored to operable status, and the Limiting Condition for Operation was cleared.

  
G. J. Kuczynski  
General Manager - Susquehanna SFS

Attachment

cc: Mr. H. J. Miller  
Regional Administrator  
U. S. Nuclear Regulatory Commission  
475 Allendale Road  
King of Prussia, PA 19406

cc: Mr. Kenneth M. Jenison  
Sr. Resident Inspector  
U. S. Nuclear Regulatory Commission  
P.O. Box 35  
Berwick, PA 18603-0035

9711210137 971117  
PDR ADOCK 05000388  
S PDR

