

# CATEGORY 1

## REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9802170064      DOC. DATE: 98/02/09      NOTARIZED: NO      DOCKET #  
 FACIL: 50-387 Susquehanna Steam Electric Station, Unit 1, Pennsylvania      05000387  
 AUTH. NAME      AUTHOR AFFILIATION  
 KUCZYNSKI, G.J.      Pennsylvania Power & Light Co.  
 RECIPIENT NAME      RECIPIENT AFFILIATION  
                                  Document Control Branch (Document Control Desk)

SUBJECT: Forwards LER 98-001-00, describing event in which Unit 1 reactor building discharge vent gaseous effluent monitor was declared inoperable per TS 3.3.7.11.

DISTRIBUTION CODE: IE22T      COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 1+3  
 TITLE: 50.73/50.9 Licensee Event Report (LER), Incident Rpt, etc.

NOTES: 05000387

	RECIPIENT ID CODE/NAME	COPIES	LTR	ENCL	RECIPIENT ID CODE/NAME	COPIES	LTR	ENCL
	PD1-2 PD	1	1		NERSES, V	1	1	
INTERNAL:	ACRS	1	1		AEOD/SPD/RAB	2	2	
	AEOD/SPD/RRAB	1	1		<del>FILE CENTER</del>	1	1	
	NRR/DE/ECGB	1	1		NRR/DE/EELB	1	1	
	NRR/DE/EMEB	1	1		NRR/DRCH/HHFB	1	1	
	NRR/DRCH/HICB	1	1		NRR/DRCH/HOLB	1	1	
	NRR/DRCH/HQMB	1	1		NRR/DRPM/PECB	1	1	
	NRR/DSSA/SPLB	1	1		NRR/DSSA/SRXB	1	1	
	RES/DET/EIB	1	1		RGN1 FILE 01	1	1	
EXTERNAL:	L ST LOBBY WARD	1	1		LITCO BRYCE, J H	1	1	
	NOAC POORE, W.	1	1		NOAC QUEENER, DS	1	1	
	NRC PDR	1	1		NUDOCS FULL TXT	1	1	
NOTES:		1	1					

NOTE TO ALL "RIDS" RECIPIENTS:  
 PLEASE HELP US TO REDUCE WASTE. TO HAVE YOUR NAME OR ORGANIZATION REMOVED FROM DISTRIBUTION LIST OR REDUCE THE NUMBER OF COPIES RECEIVED BY YOU OR YOUR ORGANIZATION, CONTACT THE DOCUMENT CONTROL DESK (DCD) ON EXTENSION 415-2083

FULL TEXT CONVERSION REQUIRED  
 TOTAL NUMBER OF COPIES REQUIRED: LTR 26 ENCL 26

George J. Kuczynski  
General Manager-Susquehanna

Susquehanna Steam Electric Station  
P.O. Box 467, Berwick, PA 18603  
Tel. 717.542.3120 Fax 717.542.1949




FEB 09 1998

U.S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Mail Station P1-137  
Washington, DC 20555

SUSQUEHANNA STEAM ELECTRIC STATION  
LICENSEE EVENT REPORT 50-387/98-001-00  
PLA - 0004847 FILE R41-2

Docket No. 50-387  
License No. NPF-14

Attached is Licensee Event Report 50-387/98-001-00. This report describes an event in which the Unit 1 Reactor Building discharge vent gaseous effluent monitor was declared inoperable per Technical Specification 3.3.7.11. Technical Specification 3.3.7.11 action states, in part, that effluent releases may continue for up to 30 days, provided samples are continuously collected with auxiliary sampling equipment. During the 25 minutes required for connecting the auxiliary sampling equipment, continuous sampling could not be performed. This constitutes reportability per 10CFR50.72(a)(2)(i)(B). No abnormal plant conditions or evidence of any abnormal release occurred prior to, during, or after the subject 25 minute period. In conjunction with the 1998 Improved Technical Specifications implementation plan for Susquehanna, a revision to the required action to allow a period of time to restore continuous sampling will be implemented.

  
G. J. Kuczynski  
General Manager - Susquehanna SES

Attachment

cc: Mr. H. J. Miller  
Regional Administrator  
U. S. Nuclear Regulatory Commission  
475 Allendale Road  
King of Prussia, PA 19406

cc: Mr. Kenneth M. Jenison  
Sr. Resident Inspector  
U.S. Nuclear Regulatory Commission  
P. O. Box 35  
Berwick, PA 18603-0035

*JE22 1/1*

9802170064 980209  
PDR ADDCK 05000387  
S PDR

