


OPERATING DATA REPORT




DOCKET NO. 50-387
 UNIT One
 DATE 4/13/98
 COMPLETED BY K. A. Young
 TELEPHONE (717) 542-3251

OPERATING STATUS

1. Unit Name: Susquehanna Steam Electric Station (U1)
2. Reporting Period: March 1998
3. Design Electrical Rating (Net MWe): 1100
4. Maximum Dependable Capacity (Net MWe): 1090

	This Month	Yr.-to-Date	Cumulative
5. Hours in Reporting Period	744	2160	129,865
6. Number of Hours Reactor Was Critical	744	2160	104,537.8
7. Hours Generator On-Line	744	2160	102,753.1
8. Unit Reserve Shutdown Hours	0	0	0
9. Net Electrical Energy Generated (MWH)	824,217	2,396,861	103,637,676

NOTES:



UNIT SHUTDOWNS

DOCKET NO. 50-387
 UNIT One
 DATE 4/13/98
 COMPLETED BY K. A. Young
 TELEPHONE (717) 542-3251

REPORT MONTH March 1998

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	Cause & Corrective Action to Prevent Recurrence
						No report this month.

Summary:
 The Unit operated at 100% power for the report period.

- F. Forced
- S. Scheduled

2. Reason:
- A - Equipment Failure (Explain)
 - B - Maintenance or Test
 - C - Refueling
 - D - Regulatory Restriction
 - E - Operator Training & Licensee Exam
 - F - Administrative
 - G - Operational Error (Explain)

3. Method:
- 1 - Manual
 - 2 - Manual Scram
 - 3 - Automatic Scram
 - 4 - Continuation from previous
 - 5 - Other

SUSQUEHANNA STEAM ELECTRIC STATION

Docket Number: 50-387

Date: 4/13/98

Completed by: K.A. Young

Telephone: (717) 542-3251

Challenges to Main Steam Safety Relief Valves

None.


Changes to the Offsite Dose Calculation Manual

None.

Major Changes to Radioactive Waste Treatment System

Safety Evaluation 95-3014N Rev. 1 Condensate Filtration System (CFS) Final Tie-In's.

OPERATING DATA REPORT




DOCKET NO. 50-388
 UNIT Two
 DATE 4/13/98
 COMPLETED BY K. A. Young
 TELEPHONE (717) 542-3251

OPERATING STATUS

1. Unit Name: Susquehanna Steam Electric Station (U2)
2. Reporting Period: March 1998
3. Design Electrical Rating (Net MWe): 1100
4. Maximum Dependable Capacity (Net MWe): 1094

	This Month	Yr.-to-Date	Cumulative
5. Hours in Reporting Period	<u>744</u>	<u>2160</u>	<u>115,104</u>
6. Number of Hours Reactor Was Critical	<u>744</u>	<u>2160</u>	<u>97,796.3</u>
7. Hours Generator On-Line	<u>744</u>	<u>2160</u>	<u>96,202.4</u>
8. Unit Reserve Shutdown Hours	<u>0</u>	<u>0</u>	<u>0</u>
9. Net Electrical Energy Generated (MWH)	<u>821,958</u>	<u>2,377,122</u>	<u>98,822,186</u>

NOTES:



UNIT SHUTDOWNS

DOCKET NO. 50-388
 UNIT Two
 DATE 4/13/98
 COMPLETED BY K. A. Young
 TELEPHONE (717) 542-3251

REPORT MONTH March 1998


No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	Cause & Corrective Action to Prevent Recurrence
						No report this month.

The Unit operated at 100% power for most of the report period except for one short duration downpower. On March 6th power was reduced to 68% for a scheduled control rod sequence exchange. Power returned to 100% at 1600 hours March 7th.

1.
 F, Forced
 S, Scheduled

2.
 Reason:
 A - Equipment Failure (Explain)
 B - Maintenance or Test
 C - Refueling
 D - Regulatory Restriction
 E - Operator Training & Licensee Exam
 F - Administrative
 G - Operational Error (Explain)

3.
 Method:
 1 - Manual
 2 - Manual Scram
 3 - Automatic Scram
 4 - Continuation from previous
 5 - Other



SUSQUEHANNA STEAM ELECTRIC STATION

Docket Number: 50-388

Date: 4/13/98

Completed by: K. A. Young

Telephone: (717) 542-3251

Challenges to Main Steam Safety Relief Valves

None.

Changes to the Offsite Dose Calculation Manual

None.

Major Changes to Radioactive Waste Treatment System

(See Docket 50-387 and Attachment).