

CATEGORY 1

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9804270211 DOC. DATE: 98/04/20 NOTARIZED: NO DOCKET #
 FACIL: 50-387 Susquehanna Steam Electric Station, Unit 1, Pennsylva 05000387
 50-388 Susquehanna Steam Electric Station, Unit 2, Pennsylva 05000388
 AUTH. NAME AUTHOR AFFILIATION
 BYRAM, R.G. Pennsylvania Power & Light Co.
 RECIP. NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Responds to NRC verbal request re "Second 10-Year ISI
 Interval Program Request Relief from NUREG-0619, BWR FW
 Nozzle Cracking.

DISTRIBUTION CODE: A047D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 1
 TITLE: OR Submittal: Inservice/Testing/Relief from ASME Code - GL-89-04

NOTES: 05000387

	RECIPIENT		COPIES		
	ID CODE/NAME	LTR	ENCL		
	PD1-2 LA	1	1		
	NERSES, V	1	1		
INTERNAL:	ACRS	1	1		
	<u>FILE CENTER 01</u>	1	1		
	NUDOCS-ABSTRACT	1	1		
	RES/DET/EIB	1	1		
EXTERNAL:	LITCO ANDERSON	1	1		
	NRC PDR	1	1		
NOTES:		1	1		

NOTE TO ALL "RIDS" RECIPIENTS:
 PLEASE HELP US TO REDUCE WASTE. TO HAVE YOUR NAME OR ORGANIZATION REMOVED FROM DISTRIBUTION LISTS
 OR REDUCE THE NUMBER OF COPIES RECEIVED BY YOU OR YOUR ORGANIZATION, CONTACT THE DOCUMENT CONTROL
 DESK (DCD) ON EXTENSION 415-2083

TOTAL NUMBER OF COPIES REQUIRED: LTR 15 ENCL 0

C
A
T
E
G
O
R
Y
1
D
O
C
U
M
E
N
T

Robert G. Byram
Senior Vice President
Generation and Chief Nuclear Officer
Tel. 610.774.7502 Fax 610.774.5019
E-mail: rgbyram@papl.com

PP&L, Inc.
Two North Ninth Street
Allentown, PA 18101-1179
Tel. 610.774.5151
http://www.papl.com/



APR 20 1998

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Mail Station P1-137
Washington, DC 20555

**SUSQUEHANNA STEAM ELECTRIC STATION
ADDITIONAL INFORMATION IN SUPPORT OF
THE SECOND 10-YEAR INSERVICE INSPECTION
INTERVAL PROGRAM REQUEST FOR RELIEF
FROM NUREG-0619, BWR FW NOZZLE AND
CRD RETURN LINE NOZZLE CRACKING
PLA-4886**

FILE R41-2

**Docket Nos. 50-387
and 50-388**


Reference: Letter (PLA-4867), "Second 10-Year Inservice Inspection Interval Program Request for Relief from NUREG-0619, BWR FW Nozzle and CRD Return Line Nozzle Cracking," from R. G. Byram (PP&L, Inc.) to NRC Document Control Desk dated March 30, 1998.

This letter is in response to the NRC Staff's verbal request to provide summary information on any plant-specific fracture mechanics analysis for the feedwater nozzles at Susquehanna SES.

A plant-specific fracture mechanics analysis, based on utilization of the existing low flow controller and routing of the Reactor Water Cleanup (RWCU) System to all feedwater lines, shows that stresses present in the feedwater nozzles will not result in the growth of an initial 0.25 inch crack to greater than 1 inch during the 40 year life of the plant.

If you have any questions, please contact Mr. C. T. Coddington at (717) 542-3294.

Sincerely,


R. G. Byram

copy: NRC Region I
Mr. K. Jenison, NRC Sr. Resident Inspector
Mr. V. Nerses, NRC Sr. Project Manager

9804270211 980420
PDR ADOCK 05000387
P PDR

1/0
A047