



1
2

George J. Kuczynski
General Manager-Susquehanna

Susquehanna Steam Electric Station
P.O. Box 467, Berwick, PA 18603
Tel. 717.542.3120 Fax 717.542.1949



MAY 04 1998

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Mail Station P1-137
Washington, DC 20555

SUSQUEHANNA STEAM ELECTRIC STATION
LICENSEE EVENT REPORT 50-388/98-005-00
PLA - 0004897 FILE R41-2

Docket No. 50-388
License No. NPF-22

Attached is Licensee Event Report 50-388/98-005-00, documenting the unplanned closure of a Unit 2 Containment Atmospheric Control isolation valve. PP&L is considering this valve closure an Engineered Safety Feature (ESF) invalid actuation (equipment failure), reportable per 10CFR50.73(a)(2)(iv). PP&L has concluded that no ESF signal was present at the time and there was no on-going plant event that would have initiated this valve isolation to close. The safety significance of this event is minimal. The cause of the event was identified and repairs effected.

G. J. Kuczynski
General Manager - Susquehanna SES

Attachment

cc: Mr. H. J. Miller
Regional Administrator
U. S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

cc: Mr. Kenneth M. Jenison
Sr. Resident Inspector
U.S. Nuclear Regulatory Commission
P. O. Box 35
Berwick, PA 18603-0035

110014

JK22

9805140018 980504
PDR ADOCK 05000388
S PDR



1
1