

George J. Kuczynski
General Manager-Susquehanna

Susquehanna Steam Electric Station
P.O. Box 467, Berwick, PA 18603
Tel. 717.542.3120 Fax 717.542.1949




June 29, 1998

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Mail Station P1-137
Washington, DC 20555

SUSQUEHANNA STEAM ELECTRIC STATION
LICENSEE EVENT REPORT 50-388/98-007-00
PLA - 0004933 FILE R41-2

Docket No. 50-388
License No. NPF-22

Attached is Licensee Event Report 50-388/98-007-00. This report is being made pursuant to 10CFR50.73(a)(2)(iv) in that primary containment isolation valves to both Unit 2 Containment Radiation Monitors closed, constituting an Engineered Safety Feature actuation. The closure was due to an electrical perturbation on the 13.8 KV system. The Containment Radiation Monitors were quickly restored to service following the event. The safety significance of the event is minimal.


G. J. Kuczynski
General Manager - Susquehanna SES

Attachment

cc: Mr. H. J. Miller
Regional Administrator
U. S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

cc: Mr. Kenneth M. Jenison
Sr. Resident Inspector
U.S. Nuclear Regulatory Commission
P. O. Box 35
Berwick, PA 18603-0035

9807070242 980629
PDR ADDCK 05000388
S PDR

11
JK21

