

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9011130188 DOC.DATE: 90/11/02 NOTARIZED: NO DOCKET # 05000389
 FACIL: 50-389 St. Lucie Plant, Unit 2, Florida Power & Light Co.
 AUTH.NAME: SAGER, D.A. AUTHOR AFFILIATION: Florida Power & Light Co.
 RECIPIENT AFFILIATION: Document Control Branch (Document Control Desk)

SUBJECT: Submits inservice insp steam generator tube plugging rept,
 per Surveillance Requirement 4.4.5.5.a.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 1
 TITLE: OR Submittal: General Distribution

NOTES:

	RECIPIENT		COPIES			RECIPIENT		COPIES		
	ID CODE/NAME		LTR	ENCL		ID CODE/NAME		LTR	ENCL	
	PD2-2 LA		1	1		PD2-2 PD		1	1	
	NORRIS, J		2	2						
INTERNAL:	ACRS		6	6		NRR/DET/ECMB 9H		1	1	
	NRR/DOEA/OTSB11		1	1		NRR/DST 8E2		1	1	
	NRR/DST/SELB 8D		1	1		NRR/DST/SICB 7E		1	1	
	NRR/DST/SRXB 8E		1	1		NUDOCS-ABSTRACT		1	1	
	OC/LFMB		1	0		OGC/HDS2		1	0	
	<u>REG FILE</u> 01		1	1		RES/DSIR/EIB		1	1	
EXTERNAL:	NRC PDR		1	1		NSIC		1	1	

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR 23 ENCL ~~21~~ 0

R
I
D
S
/
A
D
D
S
/
A
D
D
S



November 2, 1990

L-90-383

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

Gentlemen:

Re: St. Lucie Unit 2
Docket Nos. 50-389
Steam Generator Tube Plugging Report
Surveillance Requirement 4.4.5.5.a

As a result of the inservice inspection of steam generator tubes at St. Lucie Unit 2 during the end of cycle 5 refueling outage, 21 tubes in steam generator A and 18 tubes in steam generator B were plugged.

Should you have any questions on this information, please contact us.

Very truly yours,

DASager
D. A. Sager
Vice President
St. Lucie Plant

DAS:JJB:kw

cc: Stewart D. Ebnetter, Regional Administrator, Region II, USNRC
Senior Resident Inspector, USNRC, St. Lucie Plant

DAS/PSL #275

9011130188 901102
PDR ADOCK 05000389
Q FDC

*A001
1/0*