



U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555-0001

DCS-NRC-000457
12 June 2017

Subject: Docket Number 070-03098
CB&I AREVA MOX Services
Mixed Oxide Fuel Fabrication Facility
Closure of Interim Report Notification: Vigor / Oregon Iron Works

Reference: Letter from D. Del Vecchio to U.S. NRC Document Control Desk, DCS-NRC-000435, "Interim Report Notification: Vigor / Oregon Iron Works," dated 27 October 2016

CB&I AREVA MOX Services, LLC (MOX Services), submitted an interim report (Reference) regarding Vigor / Oregon Iron Works and multiple PML gloveboxes where certain electrical penetration holes were found to be out of tolerance as specified in procurement requirements. Evaluation of the condition identified in the interim report has been completed. This condition has been determined to not be reportable in accordance with 10 CFR Part 21.

If you have any questions, please feel free to contact me at (803) 442-6485 or our Licensing and Nuclear Safety Manager, Dealis Gwyn, at (803) 819-2780.

Sincerely,

A handwritten signature in blue ink, appearing to read 'David Del Vecchio'.

David Del Vecchio
President and Project Manager

Document Control Desk
U.S. Nuclear Regulatory Commission
DCS-NRC-000457
12 June 2017
Page 2 of 2

cc:

Scott Cannon, NNSA/SRS
Michael Ernstes, USNRC/RII
David Faubert, NNSA/SRS
William Gloersen, USNRC/RII
Mark Gober, MOX Services
Dealis Gwyn, MOX Services
Catherine Haney, USNRC/RII
Chip Hicks, MOX Services
Dennis Ivey, MOX Services
Charles Nickell, MOX Services
Gilles Rousseau, MOX Services
Kathryn Sutton, ML&B
David Tiktinsky, USNRC/HQ
Paul Whittingham, MOX Services
Bryan Wilkes, MOX Services
Lauren Wylie, MOX Services
Doug Yates, MOX Services
MOX Project Management Office Document Control Administrator (moxpmodca@srs.gov)
EDMS: Corresp\\Outgoing\NRC\2017 NRC