

PRIORITY 1

(ACCELERATED RIDS PROCESSING)

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9503070004 DOC. DATE: 95/03/01 NOTARIZED: NO DOCKET #
 FACIL: 50-388 Susquehanna Steam Electric Station, Unit 2, Pennsylv 05000388
 AUTH. NAME AUTHOR AFFILIATION
 STANLEY, H.G. Pennsylvania Power & Light Co.
 RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Forwards LER 95-001-00 re plant Unit 2 condition prohibited by TSS.

DISTRIBUTION CODE: IE22T COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 144
 TITLE: 50.73/50.9 Licensee Event Report (LER), Incident Rpt, etc.

NOTES:

	RECIPIENT		COPIES		RECIPIENT		COPIES	
	ID	CODE/NAME	LTTR	ENCL	ID	CODE/NAME	LTTR	ENCL
	PD1-2	PD	1	1	POSLUSNY, C		1	1
INTERNAL:	ACRS		1	1	AEOD/SPD/RAB		1	1
	AEOD/SPD/RRAB		1	1	FILE CENTER 02		1	1
	NRR/DE/ECGB		1	1	NRR/DE/EEEB		1	1
	NRR/DE/EMEB		1	1	NRR/DISP/PIPB		1	1
	NRR/DOPS/OECB		1	1	NRR/DRCH/HHFB		1	1
	NRR/DRCH/HICB		1	1	NRR/DRCH/HOLB		1	1
	NRR/DRSS/PRPB		2	2	NRR/DSSA/SPLB		1	1
	NRR/DSSA/SRXB		1	1	RES/DSIR/EIB		1	1
	RGN1	FILE 01	1	1				
EXTERNAL:	L ST LOBBY WARD		1	1	LITCO BRYCE, J H		2	2
	NOAC MURPHY, G.A		1	1	NOAC POORE, W.		1	1
	NRC PDR		1	1	NUDOCS FULL TXT		1	1

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK, ROOM P1-37 (EXT. 504-2083) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

FULL TEXT CONVERSION REQUIRED
 TOTAL NUMBER OF COPIES REQUIRED: LTTR 27 ENCL 27

P
R
I
O
R
I
T
Y

1

D
O
C
U
M
E
N
T





Pennsylvania Power & Light Company

Two North Ninth Street • Allentown, PA 18101-1179 • 610/774-5151


March 1, 1995

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

SUSQUEHANNA STEAM ELECTRIC STATION
LICENSEE EVENT REPORT 95-001-00
PLAS- 622 FILE R41-2

Docket No. 50-388
License No. NPF-22

Attached is Licensee Event Report 95-001-00. This report is being made pursuant to 10CFR50.73(a)(2)(i)(B), in that Susquehanna Unit 2 was in a condition prohibited by the Technical Specifications when the Excore Neutron Flux channel 'B' log power range indicator was declared inoperable and could not be restored within its Limiting Condition for Operation (LCO) action time. Not restoring the instrument within the LCO action time requires the shutdown of the unit per the Technical Specifications. A Notice of Enforcement Discretion was granted by the NRC on February 6, 1995 to avoid an undesirable plant shutdown and to avoid any potential safety consequences and operational risks which might be inappropriate for the current plant condition. The plant will be permitted to operate until the next shutdown of sufficient duration which would permit containment entry, the evaluation, and correction of the condition; not to exceed the seventh refueling outage scheduled to begin in September 1995. The enforcement discretion will be in effect until an emergency Technical Specification change is processed to change the number of required operable Excore Monitor channels from 2 to 1 and to change the LCO Action time from 48 hours to 7 days.


H. G. Stanley
VP - Nuclear Operations

RRW/mjm

cc: Mr. T. T. Martin
Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Ms. Maitri Banerjee
Sr. Resident Inspector
U.S. Nuclear Regulatory Commission
P.O. Box 35
Berwick, PA 18603-0035

9503070004 950301
PDR ADOCK 05000388
S PDR

JE22