

CATEGORY 1

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:9807210390 DOC.DATE: 98/07/14 NOTARIZED: NO DOCKET #
 FACIL:50-387 Susquehanna Steam Electric Station, Unit 1, Pennsylva 05000387
 AUTH.NAME: KUCZYNSKI,G.J. AUTHOR AFFILIATION: Pennsylvania Power & Light Co.
 RECIP.NAME: RECIPIENT AFFILIATION: Records Management Branch (Document Control Desk)

SUBJECT: Forwards LER 97-014-01, re UHS max allowed temp was exceeded on several occasions during period of 1986 to 1993. Supplemental LER is being submitted to update corrective actions.

DISTRIBUTION CODE: IE22T COPIES RECEIVED:LTR 1 ENCL 1 SIZE: 1+4
 TITLE: 50.73/50.9 Licensee Event Report (LER), Incident Rpt, etc.

NOTES:

05000387

	RECIPIENT ID CODE/NAME	COPIES LTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTR ENCL
	PD1-2 PD	1 1	NERSES, V	1 1
INTERNAL:	ACRS	1 1	AEOD/SPD/RAB	2 2
	AEOD/SPD/RRAB	1 1	FILE CENTER	1 1
	NRR/DE/ECGB	1 1	NRR/DE/EELB	1 1
	NRR/DE/EMEB	1 1	NRR/DRCH/HICB	1 1
	NRR/DRCH/HOHB	1 1	NRR/DRCH/HQMB	1 1
	NRR/DRPM/PECB	1 1	NRR/DSSA/SPLB	1 1
	NRR/DSSA/SRXB	1 1	RES/DET/EIB	1 1
	RGN1 FILE 01	1 1		
EXTERNAL:	L ST LOBBY WARD	1 1	LITCO BRYCE, J H	1 1
	NOAC POORE, W.	1 1	NOAC QUEENER, DS	1 1
	NRC PDR	1 1	NUDOCS FULL TXT	1 1
NOTES:		1 1		

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE. TO HAVE YOUR NAME OR ORGANIZATION REMOVED FROM DISTRIBUTION LISTS OR REDUCE THE NUMBER OF COPIES RECEIVED BY YOU OR YOUR ORGANIZATION, CONTACT THE DOCUMENT CONTROL DESK (DCD) ON EXTENSION 415-2083

FULL TEXT CONVERSION REQUIRED

TOTAL NUMBER OF COPIES REQUIRED: LTR 25 ENCL 25

C
A
T
E
G
O
R
Y
1
D
O
C
U
M
E
N
T

George J. Kuczynski
General Manager-Susquehanna

Susquehanna Steam Electric Station
P.O. Box 467, Berwick, PA 18603
Tel. 717.542.3120 Fax 717.542.1949




JUL 14 1998

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Mail Station P1-137
Washington, DC 20555

SUSQUEHANNA STEAM ELECTRIC STATION
LICENSEE EVENT REPORT 50-387/97-014-01
PLA - 0004944 FILE R41-2

Docket No. 50-387
License No. NPF-14

Attached is Licensee Event Report 50-387/97-014-01, which is a supplemental report to Licensee Event Report 50-387/97-014-00. The event was determined to be reportable per 10CFR50.73(a)(2)(ii) in that the Ultimate Heat Sink (UHS) maximum allowed temperature (as supported by recent calculations) was exceeded on several occasions during the period of 1986 to 1993. On these occasions, the UHS may have slightly exceeded its maximum allowed temperature post Loss Of Coolant Accident, constituting a condition which would have placed the plant in a condition outside of its design basis. This supplement is being submitted to update the corrective action. The original report stated that a plant modification would be completed to remove the bypass valve as the most limiting single failure. Further review has indicated that the modification is not merited.


G. J. Kuczynski
General Manager - Susquehanna SES

Tezz

Attachment

cc: Mr. H. J. Miller
Regional Administrator
U. S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

cc: Mr. Kenneth M. Jenison
Sr. Resident Inspector
U.S. Nuclear Regulatory Commission
P. O. Box 35
Berwick, PA 18603-0035

9807210390 980714
PDR ADDCK 05000387
S PDR