

## PUBLIC MEETING ANNOUNCEMENT

Title: NuScale Design Certification Review Discussions

Date(s) and Time(s): June 20, 2017, 11:00 AM to 12:00 PM

Location: Teleconference

Category: This is a Category 1 meeting. The public is invited to observe this meeting and will have one or more opportunities to communicate with the NRC after the business portion of the meeting but before the meeting is adjourned.

Purpose: NEI 12-06, Revision 2, Section 3.2.2, "Minimum Baseline Capabilities," Paragraph 17 indicates that the FLEX fluid connections for core and SFP cooling functions are expected to have a primary and an alternate connection or delivery point. FSAR Tier 2, Section 20.1.2.2 states that a robust makeup line with an external connection point for providing inventory to the SFP is available to support SFP makeup following a BDBEE. It appears that NuScale design has one connection for the makeup line. Clarify the NuScale design relative to this NEI guidance (one line vs. two lines), or justify the differences, if any.

Contact: Omid Tabatabai Demetrius Murray  
301-415-6616 301-415-7646  
[Omid.Tabatabai-Yazdi@nrc.gov](mailto:Omid.Tabatabai-Yazdi@nrc.gov) [Demetrius.Murray@nrc.gov](mailto:Demetrius.Murray@nrc.gov)

Participants: NRC External  
Office of New Reactors NuScale Power LLC

Teleconference:

Docket No: 05200048

# PUBLIC MEETING AGENDA

NuScale Design Certification Review Discussions

June 20, 2017, 11:00 AM to 12:00 PM

Teleconference

***Time***

***Topic***

***Speaker***

Introductions and identification of topics

NRC

Design review discussions

NuScale

Questions from the public

Public

Break

All

Closed Portion

NuScale

The time of the meeting is local to the jurisdiction where the meeting is being held.

The NRC provides reasonable accommodation to individuals with disabilities where appropriate. If reasonable accommodation is needed to participate in this meeting, or if a meeting notice, transcript, or other information from this meeting is needed in another format (e.g., Braille, large print), please notify the NRC meeting contact. Determinations on requests for reasonable accommodation will be made on a case-by-case basis.

ADAMS Accession Number: ML17165A154

OFFICIAL RECORD COPY

Link to meeting details: <https://www.nrc.gov/pmns/mtg?do=details&Code=20170844>