

PRELIMINARY NOTIFICATION - REGION III

June 14, 2017

PRELIMINARY NOTIFICATION OF EVENT OR UNUSUAL OCCURRENCE - PNO-III-2017-001

This preliminary notification constitutes EARLY notice of events of POSSIBLE safety or public interest significance. Some of the information may not yet be fully verified or evaluated by the Region III staff.

Facility

Exelon Generation Company, LLC
Braidwood Station, Units 1 & 2
Braceville, IL
50-456; 50-457

Licensee Emergency Classification

Notification of Unusual Event
 Alert
 Site Area Emergency
 General Emergency
 Not Applicable

SUBJECT: RELEASE OF CIRCULATING WATER CONTAINING TRITIUM USING AN UNAUTHORIZED RELEASE PATH

DESCRIPTION:

On June 12, 2017, Braidwood reported to the NRC in Event Notification (EN) 52802, "Offsite Notification for Discharge of Circulating Water," that they had notified the Illinois Environmental Protection Agency (IEPA) of a release that contained tritium to the ground outside of the Circulating Water Blowdown building. Specifically, a portion of a normal permitted release was pumped to the ground, which was not an approved release pathway.

After being notified of the release, the NRC resident inspectors responded to the Circulating Water Blowdown building and verified that the unauthorized leakage path was isolated and that an approved path was now being utilized.

The NRC determined that this event posed no immediate safety or public health concern. However, the use of an unauthorized path to discharge radioactive material to the environment raises questions and concerns.

The NRC resident inspectors and radiation protection specialists will continue to closely monitor this event and conduct a thorough, independent inspection. The NRC will evaluate the licensee's assessment of the dose impact to the public, how the event occurred, and the licensee's corrective actions. The results of all of these inspections will be documented in a future inspection report.

NRC regulations require that the NRC be informed of any event or situation related to the health and safety of the public or protection of the environment for which a notification to another government agency has been made, prompting the initial report to the NRC.

Region III received initial notification of this event through a telephone call from Braidwood Station on June 12, 2017, at about 2:00 a.m. CDT. The information presented herein has been discussed with the licensee and is current as of June 14, 2017, at 12:00 p.m. CDT.

ADAMS Accession Number ML17165A459.

CONTACT: E. Duncan
(630) 829-9620
Eric.Duncan@nrc.gov