NRC FORM 366 (7-77) U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: [| | | | |] (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

Field	Value
01 Licensee Code (2)	I L D R S 3
License Number (3)	0 0 - 0 0 0 0 0 - 0 0
License Type (4)	4 1 1 1 1
CAT (5)	
CON'T 01 Report Source (6)	L
Docket Number (7)	0 5 0 0 0 2 4 9
Event Date (8)	0 9 1 6 7 8
Report Date (9)	1 0 0 6 7 8

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 During shutdown for maintenance, routine snubber inspection in Drywell and Isolation
03 Condenser and Turbine Pipeways revealed one (#33) hydraulic of four snubbers on
04 Target Rock valve in Drywell with less than required amount of fluid. Subsequent
05 bench test proved snubber inoperable. Safety implications were minimized because
06 redundant systems were operable.

09	
System Code (11)	X X
Cause Code (12)	E
Cause Subcode (13)	B
Component Code (14)	S U P O R T
Comp. Subcode (15)	D
Valve Subcode (16)	Z

(17) LER/RO Report Number

Event Year		Sequential Report No.		Occurrence Code	Report Type		Revision No.
7 8	—	0 3 8	/	0 3	L	—	0

Action Taken (18)	Future Action (19)	Effect on Plant (20)	Shutdown Method (21)	Hours (22)	Attachment Submitted (23)	NPRD-4 Form Sub. (24)	Prime Comp. Supplier (25)	Component Manufacturer (26)
C	Z	Z	Z	0 0 0 0	N	Y	X	B 2 1 0

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 Failure resulted from fluid leakage caused by a loose fitting on each of the two
11 hydraulic lines attached to the control valve of the snubber. Snubber was replaced.
12 The next inspection will be in 4 months +/-25% in accordance with T.S. 4.6.I.

15	
Facility Status (28)	G
% Power (29)	0 0 0
Other Status (30)	NA
Method of Discovery (31)	B
Discovery Description (32)	Observation During Test

16	
Activity Released (33)	Z
Content of Release (34)	Z
Amount of Activity (35)	NA
Location of Release (36)	NA

17 Personnel Exposures	
Number (37)	0 0 6
Type (38)	E
Description (39)	400 MR-Tech Staff; 100 MR-Maint, 100MR- Rad Dept.

18 Personnel Injuries	
Number (40)	0 0 0
Description (41)	NA

19 Loss of or Damage to Facility	
Type (42)	Z
Description (43)	NA

20 Publicity	
Issued (44)	N
Description (45)	NA

NRC USE ONLY

7810170203

C H Hennig X-265

PO 917-926