

Regional Director
Directorate of Regulatory Operations
Region III
U.S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, IL 60137

Telecopies Date 10/2/78
OR
Telegrammed GE 4:26 pm
DC _____
By _____

cc:
Director
Office of Management Information and Program Control
U.S. Nuclear Regulatory Commission
Washington, DC 20555

50237

SUBJECT: DPR-19, Dresden Nuclear Power Station, Unit 2.

This will confirm a conversation with J. BARICK of
your office at 1:30 hrs this date concerning

*NAC System Trip on Low
Suction Pressure. Valve
Line-up changed per temp.
procedure change and operability
proved. Suspect low press. trap
switch out of calibration*

JBK

7811210 356

ORY DOCKET FILE COPY

To Call:
GE - 7-858-2660x16
DC - 9-1-301-492-7617 (auto)
WU - 815-942-4449/4321
Station Dist: Originator (copy)
Incident File (copy)

Red 4:37 (5/1/2)
B. B. Stephenson, Superintendent
Dresden Nuclear Power Station
Commonwealth Edison Company
R.R. #1
Morris, IL 60450
Telephone: 815-942-2920/2921x212

Rev. 12-75