





Commonwealth Edison

# DEVIATION REPORT

DVR NO.	STA	UNIT	YEAR	NO.
	D-12	-3-	78-	77

<b>PART 1</b> TITLE OF DEVIATION	U3 M.S.L. Flow Switch Trip (3-261-2C) above Technical Specifications	OCURRED DATE <u>10-21-78</u> TIME <u>1430</u>
----------------------------------	--	--

SYSTEM AFFECTED	500	PLANT CONDITIONS	TESTING
Rx Protection		MODE <u>Run</u> PWR(MWT) <u>2418</u> LOAD(MWE) <u>796</u>	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO

DESCRIPTION OF EVENT  
While doing DIS 250-1 on U3, found switch 2C initial trip at 120 psi diff. press.

(Tech. Specs.  $\leq$  115 PSI dp.). Repeated loading and trip point came in at 110.2 psi dp.

DESCRIPTION OF CAUSE  
Possible mech. friction of switch mechanism.

OTHER APPLICABLE INFORMATION  
Check dPIS 3-261-2C several times after initial trip and repeated at 110.2PSI diff. press. (No adjustments made)

EQUIPMENT FAILURE	<input type="checkbox"/> YES <input checked="" type="checkbox"/> NO	DR NO.	WR NO.	RESONSIBLE SUPERVISOR	DATE
		NA	NA	Allen R. Zapotocky	10-21-78

**PART 2** OPERATING ENGINEERS COMMENTS  
Redundant switches were operable. Therefore the safety function was not impaired.

TYPE OF DEVIATION REPORTABLE OCCURRENCE	EVENT OF POTENTIAL PUBLIC INTEREST	TECH SPEC VIOLATION	NON-REPORTABLE OCCURRENCE	ANNUAL REPORTING	SAFETY-RELATED WR ISSUED
<input type="checkbox"/> 14 DAY <input type="checkbox"/> 10CFR21	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>
<input checked="" type="checkbox"/> 30 DAY NOTIFICATION 6.6.B.2.a.					

REPORTABLE OCCURRENCE NUMBER	ACTION ITEM NO.	PROMPT ON-SITE NOTIFICATION
<del>50X</del> 78-50-03L-0	NA	A. Roberts Asst. Supt. <u>10/23/78</u> 0900 TITLE DATE TIME
		NA TITLE DATE TIME

24-HOUR NRC NOTIFICATION	PROMPT OFF-SITE NOTIFICATION
<input type="checkbox"/> TPH NA REGION III DATE TIME	F.A. Palmer <u>10/23/78</u> 1:19 TITLE DATE TIME
<input type="checkbox"/> TGM NA REGION III & DOL DATE TIME	J.R. Gilliom <u>10/23/78</u> 1:19 TITLE DATE TIME

RESONSIBLE COMPANY OFFICER INFORMED OF 10CFR21 CONDITIONS AND THEIR REPORT TO NRC

REVIEW AND COMPLETED C.E. Sargent OPERATING ENGINEER 10/23/78 DATE

ACCEPTANCE BY STATION REVIEW AS REQUIRED

DATE 11/15/78

RESOLUTION APPROVED AND AUTHORIZED FOR DISTRIBUTION

Thomas J. Pagan P.M. Pagan 11/18/78

[Signature] STATION SUPERINTENDENT 11/30/78 DATE

NOV 24 1978