NRC FORM 366
(7-77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1	LICENSEE CODE	I L D R S 3 (2)
	LICENSE NUMBER	0 0 - 0 0 0 0 0 - 0 0 (3)
	LICENSE TYPE	4 1 1 1 1 (4)
	CAT	(5)

CON'T 0 1	REPORT SOURCE	L (6)
	DOCKET NUMBER	0 5 0 0 0 2 4 9 (7)
	EVENT DATE	1 1 3 0 7 8 (8)
	REPORT DATE	1 2 1 4 7 8 (9)

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 While performing test on U3 D/G the "D/G 3 Day Tank Level Hi/Lo" alarm annunciated.
0 3 It was found that the fuel oil transfer pump was running, the relief valve was lifted
0 4 and the discharge solenoid valve was energized. However, there was no increase in
0 5 the day tank level. The tank was about half full which would have supplied the D/G
0 6 for 2 hrs. at full load and the redundant D/G was available. The safety significance
0 7 of event was minimal.
0 8

0 9	SYSTEM CODE	CAUSE CODE	CAUSE SUBCODE	COMPONENT CODE	COMP. SUBCODE	VALVE SUBCODE
	E E (11)	E (12)	B (13)	V A L V E X (14)	E (15)	F (16)

(17) LER/RO REPORT NUMBER	EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE	REPORT TYPE		REVISION NO.
	7 8	—	0 5 7	/	0 3	L	—	0

ACTION TAKEN	FUTURE ACTION	EFFECT ON PLANT	SHUTDOWN METHOD	HOURS (22)	ATTACHMENT SUBMITTED	NPRD-4 FORM SUB.	PRIME COMP. SUPPLIER	COMPONENT MANUFACTURER
A (18)	Z (19)	Z (20)	Z (21)	0 0 0 0	N (23)	Y (24)	A (25)	A 4 9 9 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 Apparently the solenoid valve was stuck closed. It was tapped and the tank started
1 1 to fill. Another test also showed the valve functioned properly. Later, the valve
1 2 was replaced. No defect could be found. Because of the singularity of this event,
1 3 no future corrective action is required.
1 4

1 5	FACILITY STATUS	% POWER	OTHER STATUS (30)	METHOD OF DISCOVERY	DISCOVERY DESCRIPTION (32)
	E (28)	1 0 0 (29)	NA	C (31)	D/G test after replacing a meter

1 6	ACTIVITY RELEASED	CONTENT OF RELEASE	AMOUNT OF ACTIVITY (35)	LOCATION OF RELEASE (36)
	Z (33)	Z (34)	NA	NA

PERSONNEL EXPOSURES

1 7	NUMBER	TYPE	DESCRIPTION (39)
	0 0 0 (37)	Z (38)	NA

PERSONNEL INJURIES

1 8	NUMBER	DESCRIPTION (41)
	0 0 0 (40)	NA

LOSS OF OR DAMAGE TO FACILITY (43)

1 9	TYPE	DESCRIPTION
	Z (42)	NA

PUBLICITY

2 0	ISSUED	DESCRIPTION (45)	NRC USE ONLY
	N (44)	NA	

7812270289

NAME OF PREPARER Joe Chan PHONE: 421

GPO 917-926