

ENCLOSURE II

DRESDEN STATION UNIT 2


NRC DOCKET NO. 50-237

7901230252

NEDO-24160
78NED294
Class I
November 1978

SUPPLEMENTAL RELOAD LICENSING SUBMITTAL
FOR
DRESDEN NUCLEAR POWER STATION
UNIT 2 RELOAD 4

Prepared:



R. T. Hill, Senior Licensing Engineer
Operating Licenses I

Approved:



R. E. Engel, Manager
Operating Licenses I

NUCLEAR ENERGY PROJECTS DIVISION • GENERAL ELECTRIC COMPANY
SAN JOSE, CALIFORNIA 95125

7901230252

GENERAL  ELECTRIC

IMPORTANT NOTICE REGARDING
CONTENTS OF THIS REPORT
PLEASE READ CAREFULLY

This report was prepared by General Electric solely for Commonwealth Edison Company (CE) for CE's use with the U.S. Nuclear Regulatory Commission (USNRC) for amending CE's operating license of the Dresden Nuclear Power Station Unit 2. The information contained in this report is believed by General Electric to be an accurate and true representation of the facts known, obtained or provided to General Electric at the time this report was prepared.

The only undertakings of the General Electric Company respecting information in this document are contained in the nuclear fuel agreements, as amended, between Commonwealth Edison Company and General Electric Company for nuclear fuel and related services for the nuclear system for Dresden Nuclear Power Station Units 2 and 3, dated December 13, 1965 and nothing contained in this document shall be construed as changing said agreements. The use of this information except as defined by said agreement, or for any purpose other than that for which it is intended, is not authorized; and with respect to such unauthorized use, neither General Electric Company nor any of the contributors to this document makes any representation or warranty (express or implied) as to the completeness, accuracy or usefulness of the information contained in this document or that such use of such information may not infringe privately owned rights; nor do they assume any responsibility for liability or damage of any kind which may result from such use of such information.

5. STANDBY LIQUID CONTROL SYSTEM SHUTDOWN CAPABILITY (3.3.2.1.3)

<u>ppm</u>	<u>Shutdown Margin (Δk)</u> <u>(20°C, Xenon Free)</u>
600	0.043

6. RELOAD UNIQUE TRANSIENT ANALYSIS INPUTS (3.3.2.1.5 AND 5.2)

	<u>EOC</u>	<u>EOC - 2 GWd/t</u>
Void Coefficient N/A* (¢/% Rg)	-5.77/-7.22	-7.06/-8.82
Void Fraction (%)	30.71	34.10
Doppler Coefficient N/A (¢/°F)	-0.231/-0.219	-0.220/-0.209
Average Fuel Temperature (°F)	1203	1203
Scram Worth N/A (\$)	-39.52/-31.61	-36.5/-29.2
Scram Reactivity vs Time	Figure 2a	Figure 2b

7. RELOAD UNIQUE GETAB TRANSIENT ANALYSIS INITIAL CONDITION PARAMETERS (5.2)

<u>Exposure</u>	<u>7x7</u> <u>EOC</u>	<u>8x8/8x8R</u> <u>EOC</u>
Peaking factors: (local, radial and axial)	1.30/1.53/1.40	1.18/1.82/1.40
R-Factor	1.100	1.051
Bundle Power (MWt)	5.240	6.201
Bundle Flow (10 ³ lb/hr)	113.84	108.74
Initial MCPR	1.24	1.30

8. SELECTED MARGIN IMPROVEMENT OPTIONS (5.2.2)

None

*N = Nuclear Input Data
A = Used in Transient Analysis

9. CORE-WIDE TRANSIENT ANALYSIS RESULTS (5.2.1)

<u>Transient</u>	<u>Exposure</u>	<u>Power (%)</u>	<u>Flow (%)</u>	<u>φ (%)</u>	<u>Q/A (%)</u>	<u>P_{s1} (psig)</u>	<u>P_v (psig)</u>	<u>ΔCPR 7x7</u>	<u>8x8/8x8R</u>	<u>Plant Response</u>
Load Rejection without Bypass	EOC-2Gwd/t to EOC	98	100	265.2	110.8	1214	1248	0.17	0.24	Figure 3
Load Rejection without Bypass	EOC to EOC-2Gwd/t	100	100	235.2	109.3	1206	1238	-	-	Figure 4
Loss of 145°F Feedwater Heating	BOC-EOC	100	100	118.9	118.3	992	1042	0.16	0.18	Figure 5
Feedwater Controller Failure	BOC-EOC	100	100	153.9	107.3	1114	1151	0.08	0.11	Figure 6

10. LOCAL ROD WITHDRAWAL ERROR (WITH LIMITING INSTRUMENT FAILURE) TRANSIENT SUMMARY (5.2.1)

<u>Rod Block Reading</u>	<u>Rod Position (Feet Withdrawn)</u>	<u>ΔCPR 7x7</u>	<u>8x8/8x8R</u>	<u>MLHGR (Kw/ft) 7x7</u>	<u>8x8/8x8R</u>	<u>Limiting Rod Pattern</u>
104	4.0	0.11	0.17	11.18	13.33	Figure 7
105	4.5	0.13	0.19	11.30	13.36	Figure 7
106	5.0	0.15	0.22	11.46	13.61	Figure 7
107*	5.5	0.16	0.24	11.63	13.95	Figure 7
108	6.0	0.18	0.25	11.74	14.28	Figure 7
109	6.5	0.19	0.27	11.77	14.55	Figure 7

11. OPERATING MCPR LIMIT (5.2)

BOC7-EOC7

1.31	(8x8/8x8R fuel)
1.24	(7x7 fuel)

*Indicates setpoint selected

12. OVERPRESSURIZATION ANALYSIS SUMMARY (5.3)

<u>Transient</u>	<u>Power (%)</u>	<u>Core Flow (%)</u>	<u>P_{sl} (psig)</u>	<u>P_v (psig)</u>	<u>Plant Response</u>
MSIV Closure (Flux Scram)	100	100	1277	1311	Figure 8

13. STABILITY ANALYSIS RESULTS (5.4)

• Decay Ratio: Figure 9

Reactor Core Stability:

Decay Ratio, x_2/x_0 0.59

(100% Rod Line - Natural
Circulation Power)

Channel Hydrodynamic Performance

Decay Ratio, x_2/x_0

(100% Rod Line - Natural
Circulation Power)

8x8/8x8R channel 0.27

7x7 channel 0.12

14. LOSS-OF-COOLANT ACCIDENT RESULTS (5.5.2)

See Reference 1.

15. LOADING ERROR RESULTS (5.5.4)

Limiting Event: Rotated bundle


MCPR: 1.07

16. CONTROL ROD DROP ANALYSIS RESULTS (5.5.1)

Maximum incremental control rod worth: 0.56%Δk

REFERENCES:

- (1) "Loss-of-Coolant Accident Analysis Report for Dresden Units 2, 3 and Quad Cities Units 1, 2 Nuclear Power Stations," NEDO-24146, September 1978.



FUEL TYPE	
A = INITIAL FUEL	E = RELOAD 2 (8DB262)
B = RELOAD 1 (7DB230)	F = RELOAD 3 (8DB250)
C = RELOAD 1 (8DB250)	G = RELOAD 4 (8DRB265L)
D = RELOAD 2 (8DB250)	

Figure 1. Dresden Unit 2 Reload 4 Design Reference Core Loading




Figure 2a. Scram Reactivity vs Time (Dresden 2, Cycle 7, EOC7)




Figure 2b. Scram Reactivity vs Time (Dresden 2, Cycle 7, EOC7-2GWd/t)







Figure 3. Load Rejection Without Bypass (EOC)







Figure 4. Load Rejection Without Bypass (EOC - 2 Gwd/t)







Figure 5. Loss of 145°F Feedwater Heating







Figure 6. Feedwater Controller Failure

	02	06	10	14	18	22	26	30
59								00
55				14		06		14
51			10		20		12	
47		14		00				00
41			20		38			
39		06				00		00
35	00		12				32	
31		18		00		00		00

- NOTE: 1. ROD PATTERN IS 1/4 CORE MIRROR SYMMETRIC UPPER LEFT QUADRANT SHOWN ON MAP
 2. NUMBERS INDICATE NUMBER OF NOTCHES WITHDRAWN OUT OF 48. BLANK IS A WITHDRAWN ROD
 3. ERROR ROD IS (22, 39)

Figure 7. Limiting Rod Pattern For Rod Withdrawal Error







Figure 8. MSIV Closure, Flux Scram, EOC (Overpressure Protection Event)




Figure 9. Decay Ratio

APPENDIX A

PLANT PARAMETER CHANGES

Pressure Relief Systems (Table 5-4, pg 5-62, NEDO-24011)

Safety/Relief Valve setpoint (psig)	1115 + 1%
Safety/Relief Valve capacity (% NBR steam flow)	5/29.2
Safety Valve capacity (% NBR steam flow)	8/52.5

Transient Operating Parameters (Table 5-6, pg 5-64, NEDO-24011)

Thermal Power (% of Rated)

BOC to EOC-2 GWd/t	100
EOC-2 GWd/t to EOC	98
Turbine Pressure (psig)	950

GETAB Initial Conditions

Reactor Core Pressure (psia)	1030
Inlet Enthalpy (Btu/lb)	522.5

Loading Error

Linear Heat Generation Rate (kW/ft)	19.4
-------------------------------------	------