

LICENSEE EVENT REPORT

CONTROL BLOCK: 1 (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 I L D R S 3 2 0 0 - 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5
7 8 9 14 15 25 26 30 57 CAT 58

CON'T
01 REPORT SOURCE L 6 0 5 0 0 0 2 4 9 7 0 1 2 0 7 9 8 0 2 0 5 7 9 9
7 8 60 61 68 69 74 75 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10

02 While performing monthly Surv. DIS 250-1, MSL Hi Flow Isol. Sw. DPIS 3-261-2G
03 tripped at 118.5 PSID. (T.S. Limit <= 115.0 PSID at 120% flow; table 3.2.1). The
04 16 MSL Hi Flow Isol. Sw.'s provide containment isolation whenever primary integrity
05 is required. Safety significance minimal. Both trip systems were operable and would
06 have provided containment isolation at 110.0 PSID, conservative to 115.0 PSID T.S.
07 Limit. Similar events are ref. under R.O. #050-249/1977-4; 78-022, 027, 028, 033 &
08 050/03L-0, also of Docket #050-249.
7 8 9 80

09 SYSTEM CODE C D 11 CAUSE CODE E 12 CAUSE SUBCODE E 13 COMPONENT CODE I N S T R U 14 COMP. SUBCODE E 15 VALVE SUBCODE Z 16
7 8 9 10 11 12 13 18 19 20

17 LER/RO REPORT NUMBER 7 9 EVENT YEAR 7 9 SEQUENTIAL REPORT NO. 0 0 1 OCCURRENCE CODE 0 3 REPORT TYPE L REVISION NO. 0
21 22 23 24 26 27 28 29 30 31 32

ACTION TAKEN E 18 FUTURE ACTION Z 19 EFFECT ON PLANT Z 20 SHUTDOWN METHOD Z 21 HOURS 0 0 0 0 ATTACHMENT SUBMITTED N 23 NPD-4 FORM SUB. N 24 PRIME COMP. SUPPLIER N 25 COMPONENT MANUFACTURER B 0 8 0 26
33 34 35 36 37 40 41 42 43 44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27

10 Cause attributable to instrument drift. Inspection revealed no mechanical problems
11 with the switch internals. DPIS 3-261-2G was adjusted to trip open at 109 PSID in-
12 creasing and repeatability verified. MSL Hi Flow Switches will continue to be
13 tested monthly.
14
7 8 9 80

15 FACILITY STATUS G 28 % POWER 0 0 0 29 OTHER STATUS NA 30 METHOD OF DISCOVERY B 31 DISCOVERY DESCRIPTION Surveillance Testing 32
7 8 9 10 12 13 44 45 46 80

16 ACTIVITY CONTENT RELEASED OF RELEASE Z 33 Z 34 AMOUNT OF ACTIVITY NA 35 LOCATION OF RELEASE NA 36
7 8 9 10 11 44 45 80

17 PERSONNEL EXPOSURES NUMBER 0 0 0 37 TYPE Z 38 DESCRIPTION NA 39
7 8 9 11 12 13 80

18 PERSONNEL INJURIES NUMBER 0 0 0 40 DESCRIPTION NA 41
7 8 9 11 12 80

19 LOSS OF OR DAMAGE TO FACILITY TYPE Z 42 DESCRIPTION NA 43
7 8 9 10 80

20 PUBLICITY ISSUED DESCRIPTION N 44 NA 45 NRC USE ONLY
7 8 9 10 68 69 80

7902210262