

Hematite Decommissioning Project	Procedure: HDP-PR-FSS-701, Final Status Survey Plan Development		
	Westinghouse Non-Proprietary Class 3	Revision: 4	Appendix P-6, Page 1 of 2

**APPENDIX P-6
FSS FIELD LOG**

Survey Area:	LSA 08	Description:	Central Open Land Area (Plant Soils Area)
Survey Unit:	08	Description:	Class 1 "Area 4"; (North Process Building Area)

FSS Field Log:

<u>Date/Time:</u>	<u>Observation or Comment:</u>	<u>Technician</u>
03/04/16	Prior to commencing the systematic sampling of LSA 08-08 the FSS Supervisor conducted a task-specific safety brief. The FSS personnel then performed a quality walk-down of the area and verified I&C measures were in place. Weather conditions were overcast and cold at 46°F. All sample points were surveyed prior to isolation to ensure the absence of elevated radioactivity. Sampling was commenced at 1440 and secured at 1555. The FSS personnel returned to the FSS office to prepare the samples for shipment.	Jahmai Williams
03/07/16	Prior to performing the GWS of LSA 08-08, a quality walk down of the area was conducted. Isolation controls consisting of straw wattles and green and white rope were in place. There was no standing water in the area being surveyed. Asphalt and concrete pieces were removed from the area and disposed of properly before the GWS was performed. Weather conditions were warm and mostly sunny at 71 degrees Fahrenheit. Ludlum 2221 and 44-10 "BB" and "B" were used to perform the GWS. The background for instrument "BB" was between 9,500 and 10,500 GCPM. The background for instrument "B" was between 10,000 and 11,000. The GWS was started at 0803 and paused at 1115. The GWS resumed at 1250 and was completed at 1610. LSA 08-08 was exited and the personnel returned to the office to process data and perform instrument post-checks. GWS Files Generated: LSA_08_08_030716_BB_JMB LSA_08_08_030716_B_JW	Jacob Boxdorfer
03/09/16	Prior to performing the GWS of LSA 08-08, a quality walk down of the area was conducted. Isolation controls consisting of straw wattles and green and white rope were in place. There was no standing water in the area being surveyed. Asphalt and concrete pieces were removed from the area and disposed of properly before the GWS was performed. Weather conditions were warm and overcast at 63 degrees Fahrenheit. Ludlum 2221 and 44-10 "BB" were used to perform the GWS. The background for instrument "BB" was between 9,500 and 10,500 GCPM. The GWS was started at 0745 and paused at 0910. LSA 08-08 was exited and the personnel returned to the office to process data and perform instrument post-checks. GWS Files Generated: LSA_08_08_030916_BB_JMB	Jacob Boxdorfer

Hematite Decommissioning Project	Procedure: HDP-PR-FSS-701, Final Status Survey Plan Development		
	Westinghouse Non-Proprietary Class 3	Revision: 4	Appendix P-6, Page 2 of 2

**APPENDIX P-6
FSS FIELD LOG**

Survey Area:	LSA 08	Description:	Central Open Land Area (Plant Soils Area)
Survey Unit:	08	Description:	Class 1 "Area 4"; (North Process Building Area)

FSS Field Log:

<u>Date/Time:</u>	<u>Observation or Comment:</u>	<u>Technician</u>
03/12/16	<p>Prior to commencing the biased sampling of LSA 08-08 the FSS Supervisor conducted a task-specific safety brief. The FSS personnel then performed a quality walk-down of the area and verified I&C measures were in place. Weather conditions were overcast and cold at 52°F. Sampling was commenced at 0850 and secured at 0915. The FSS personnel returned to the FSS office to prepare the samples for shipment.</p> <p>Sample IDs: L08-08-11-T-E-B-00; L08-08-12-T-E-B-00; L08-08-13-T-E-B-00 L08-08-14-T-E-B-00; L08-08-15-T-E-B-00</p>	Jahmai Williams