

LICENSEE EVENT REPORT

CONTROL BLOCK:

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 I L D R S 3 2 0 0 - 0 0 0 0 0 0 0 0 3 4 1 1 1 1 4 5

CON'T REPORT SOURCE L 6 0 5 0 0 0 2 4 9 7 0 3 0 2 7 9 8 0 3 2 9 7 9 9

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10

0 2 During routine surveillance DIS 1700-1 (MSL Hi Rad Scram & Isolation), 3 'B' MSL Rad
0 3 Monitor was found downscale. The Hi voltage light was 'on' but monitor would not
0 4 respond to zero ck, low cal or high cal positions. Safety significance minimal since
0 5 the unit was shutdown and remaining 3 monitors were functioning normally.

0 9 SYSTEM CODE C D 11 CAUSE CODE E 12 CAUSE SUBCODE G 13 COMPONENT CODE I N S T R U 14 COMP. SUBCODE E 15 VALVE SUBCODE Z 16
17 LER/RO REPORT NUMBER 7 9 21 22 SEQUENTIAL REPORT NO. 0 0 3 24 26 OCCURRENCE CODE 0 3 28 29 REPORT TYPE L 30 31 REVISION NO. 0 32
ACTION TAKEN A 18 Z 19 FUTURE ACTION Z 20 EFFECT ON PLANT Z 21 SHUTDOWN METHOD Z 22 HOURS 0 0 0 0 37 40 ATTACHMENT SUBMITTED N 23 41 NPRD-4 FORM SUB. Y 24 42 PRIME COMP. SUPPLIER N 25 43 COMPONENT MANUFACTURER G 0 8 0 26 44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27

1 0 Cause attributed to a faulty diode CR-72 output of the alarm trip circuitry. Diode
1 1 replaced and 3 'B' MSL Rad Monitor was calibrated and returned to service after
1 2 successfully completing DIS 1700-1. Monitors will continue to be tested monthly.
1 3 Monitor mfg. by G.E. model 194X629G7.

1 5 FACILITY STATUS G 28 8 9 % POWER 0 0 0 29 10 11 OTHER STATUS N/A 30 12 13 METHOD OF DISCOVERY B 31 44 45 DISCOVERY DESCRIPTION Surveillance Testing 32 46 47
1 6 ACTIVITY CONTENT Z 33 8 9 RELEASED OF RELEASE Z 34 10 11 AMOUNT OF ACTIVITY NA 35 12 13 LOCATION OF RELEASE NA 36 14 15
1 7 PERSONNEL EXPOSURES 0 0 0 37 8 9 TYPE Z 38 10 11 DESCRIPTION NA 39 12 13
1 8 PERSONNEL INJURIES 0 0 0 40 8 9 DESCRIPTION NA 41 10 11
1 9 LOSS OF OR DAMAGE TO FACILITY Z 42 8 9 TYPE NA 43 10 11
2 0 ISSUED N 44 8 9 DESCRIPTION NA 45 10 11

7904060223

NAME OF PREPARER Carl Lindberg

PHONE: X-289

GPO 17-926