



**Commonwealth Edison**  
Dresden Nuclear Power Station  
R.R. #1  
Morris, Illinois 60450  
Telephone 815/942-2920

DSB

June 12, 1979

BBS LTR #79-470

James G. Keppler, Regional Director  
Directorate of Regulatory Operations - Region III  
U. S. Nuclear Regulatory Commission  
799 Roosevelt Road  
Glen Ellyn, IL 60137

Reportable Occurrence Report #79-010/03L-0, Docket #050-249 is hereby submitted to your office in accordance with Dresden Nuclear Power Station Technical Specification 6.6.B.2.(b), conditions leading to operation in a degraded mode permitted by a limiting condition for operation or plant shutdown required by a limiting condition for operation.

*Arthur M. Roberts*  
for B. Stephenson  
Station Superintendent  
Dresden Nuclear Power Station

BBS:lcg

Enclosure

cc: Director of Inspection & Enforcement  
Director of Management Information & Program Control  
File/NRC

7906190418

JUN 18 1979

*1002*  
*5/11*



Commonwealth Edison

# DEVIATION REPORT

DVR NO.	STA	UNIT	YEAR	NO.
D-12	-	3	-	79-16

<b>PART 1</b> TITLE OF DEVIATION	OCCURRED
"3A" Off Gas Monitor Trip	5/15/79 1730
SYSTEM AFFECTED 5400	DATE TIME
Off Gas System	
PLANT CONDITIONS	TESTING
MODE Run PWR(MWT) 2419 LOAD(MWE) 810	<input type="checkbox"/> YES <input checked="" type="checkbox"/> NO

DESCRIPTION OF EVENT  
During normal operation the 3A off gas monitor drifted hi and tripped on Hi Hi off gas activity.

DESCRIPTION OF CAUSE  
Apparent monitor drift

OTHER APPLICABLE INFORMATION  
IM's were called in to correct the problem.

EQUIPMENT FAILURE <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	DR. NO. N/A	WR NO. N/A	C. E. Sargent	5/17/79
			RESPONSIBLE SUPERVISOR	DATE

**PART 2** OPERATING ENGINEERS COMMENTS  
Minimal safety significance since the "3B" monitor was operable. "3A" was tripped high as required by T.S.

TYPE OF DEVIATION REPORTABLE OCCURRENCE	EVENT OF POTENTIAL PUBLIC INTEREST	TECH SPEC VIOLATION	NON-REPORTABLE OCCURRENCE	ANNUAL REPORTING	SAFETY-RELATED WR ISSUED
<input type="checkbox"/> 14 DAY <input type="checkbox"/> 10CFR21	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>	YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>
<input checked="" type="checkbox"/> 30 DAY NOTIFICATION 6.6.B.2.b					

REPORTABLE OCCURRENCE NUMBER	ACTION ITEM NO.	PROMPT ON-SITE NOTIFICATION
79-10-03L-0	N/A	R. M. Ragan F/B.B.S. 5/17/79 0800
		N/A TITLE DATE TIME

24-HOUR NRC NOTIFICATION	PROMPT OFF-SITE NOTIFICATION
<input type="checkbox"/> TPH N/A	F. A. Palmer 5/17/79 10:20
<input type="checkbox"/> TGM N/A	J. R. Gilliom 5/17/79 10:20
REGION III DATE TIME	TITLE DATE TIME
REGION III & DOL DATE TIME	TITLE DATE TIME

RESPONSIBLE COMPANY OFFICER INFORMED OF 10CFR21 CONDITIONS AND THEIR REPORT TO NRC

REVIEW AND COMPLETED C. E. Sargent 5/17/79  
OPERATING ENGINEER DATE

ACCEPTANCE BY STATION REVIEW AS REQUIRED

*Annex Jones* *C. E. Sargent*  
6-12-79 6/12/79  
*Arthur M. Roberts* 6/13/79  
for STATION SUPERINTENDENT DATE

DATE

RESOLUTION APPROVED AND AUTHORIZED FOR DISTRIBUTION