NRC FORM 366 (7-77)

U.S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: | | | | | | | (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1	LICENSEE CODE: I L D R S 3 (2)	LICENSE NUMBER: 0 0 - 0 0 0 0 0 - 0 0 (3)	LICENSE TYPE: 4 1 1 1 1 (4)	CAT: (5)

CON'T

0 1	REPORT SOURCE: L (6)	DOCKET NUMBER: 0 5 0 0 0 2 4 9 (7)	EVENT DATE: 0 5 1 5 7 9 (8)	REPORT DATE: 0 6 1 2 7 9 (9)

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 During normal operation the off gas log rad monitor 1705 3A drifted high
0 3 and tripped on Hi Hi off gas activity. The safety significance was minimal
0 4 because the redundant monitor 1705 3B continued to operate normally. The
0 5 last similar occurrence on Unit 3 (but attributable to a different root cause) was
0 6 reported by RO #78-53-03L-0, DKT #50-249.
0 7
0 8

	SYSTEM CODE	CAUSE CODE	CAUSE SUBCODE	COMPONENT CODE	COMP. SUBCODE	VALVE SUBCODE
0 9	M B (11)	E (12)	G (13)	I N S T R U (14)	X (15)	Z (16)

(17) LER/RO REPORT NUMBER	EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE	REPORT TYPE		REVISION NO.
	7 9	—	0 1 0	/	0 3	L	—	0

ACTION TAKEN	FUTURE ACTION	EFFECT ON PLANT	SHUTDOWN METHOD	HOURS (22)	ATTACHMENT SUBMITTED	NPRD-4 FORM SUB.	PRIME COMP. SUPPLIER	COMPONENT MANUFACTURER
C (18)	Z (19)	Z (20)	Z (21)	0 0 0 0	N (23)	Y (24)	N (25)	G 0 8 0 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 The cause was attributable to a resistor adjustment which controls filament current
1 1 on the log feedback diode. A spare log rad monitor was installed, calibrated, and
1 2 functioned properly. The removed monitor was repaired. The offgas monitor will
1 3 continue to be calibrated quarterly and functionally tested monthly. No further
1 4 action is deemed necessary.

	FACILITY STATUS	% POWER	OTHER STATUS (30)	METHOD OF DISCOVERY	DISCOVERY DESCRIPTION (32)
1 5	E (28)	0 9 6 (29)	N/A	A (31)	Operator Observation

	ACTIVITY RELEASED	CONTENT OF RELEASE	AMOUNT OF ACTIVITY (35)	LOCATION OF RELEASE (36)
1 6	Z (33)	Z (34)	N/A	N/A

PERSONNEL EXPOSURES

	NUMBER	TYPE	DESCRIPTION (39)
1 7	0 0 0 (37)	Z (38)	N/A

PERSONNEL INJURIES

	NUMBER	DESCRIPTION (41)
1 8	0 0 0 (40)	N/A

7906190432

LOSS OF OR DAMAGE TO FACILITY (43)

	TYPE	DESCRIPTION
1 9	Z (42)	N/A

PUBLICITY

	ISSUED	DESCRIPTION (45)	NRC USE ONLY
2 0	N (44)	N/A	

NAME OF PREPARER: M. Korchynsky PHONE: X-265

GPO 917-924